

## **Contents of Report**

The Title V Operating Permit requires a semi-annual report by January 31 and July 31 of each year. This report for the semi-annual reporting period of January 1, 2000 through June 30, 2000, contains the following sections:

1. Fuel Burning Equipment
2. Kymene Process Area
3. AKD Process Area
4. HRA Process Area
5. Poly-Pale Process Area
6. RAD Process Area
7. Neuphor Process Area
8. Kymene LDAR Monitoring
9. RAD LDAR Monitoring
10. Deviations from Permit Requirements

# **Fuel Burning Equipment**



## **FUEL BURNING REPORT SUMMARY**

As required by 5.B.6 and 5.B.7, monthly records of the type and quantity of fuel combusted are provided in this section. Only natural gas was combusted during this semi-annual reporting period.



Koch Gateway Pipeline Company  
 DETAIL METER STATEMENT  
 FOR THE MONTH OF 01/00

02/07/00 20:13:44  
 PAGE 4

METER ID: 002520-01  
 LOCATION: HATTIESBURG CITY GATE #1  
 TYPE METER: EFM Orifice

SYSTEM: 007:Mississipp  
 SUBSYSTEM: 014:Jackson to Leaksville 16" & 8"  
 PURPOSE: Koch Custody Delivery

CONTRACT TIME: 09:00  
 ANALYST: Matthews, Lloia  
 PHONE #: 5044695903

METER INFORMATION										
EFFECTIVE DATE	REF NUM	STATIC RANGE	DIFF RANGE	TUBE SIZE	PLATE SIZE	TAP TYPE	TAP LOCA	CHART DAYS	MACHINE CONSTANT	CALC TYPE
01/01/00	1	500	100	8.072	3.250	P	U	1	1.0000	14

VOLUME INFORMATION											
DAY ON	DAY OFF	REF NUM	FLOW EXTENT	FLOW HOURS	TEMP	PRES PSIA	DIFF	SPEC GRAV	MCF VOLUME @ 14.730	BTU(D)	Dth
1	2	1	25	24.0	44.9	110.5	6.0	0.5981	1932	1012.7000	1957
2	3	2	19	24.0	50.3	110.9	3.6	0.5981	1431	1012.7000	1449
3	4	3	21	24.0	48.9	110.5	5.3	0.5981	1616	1012.7000	1637
4	5	4	44	24.0	42.0	108.9	20.4	0.5981	3346	1012.7000	3388
5	6	5	42	24.0	42.1	108.6	21.5	0.5981	3234	1012.7000	3275
6	7	6	42	24.0	42.6	107.7	23.1	0.5981	3218	1012.7000	3259
7	8	7	49	24.0	42.7	107.9	23.0	0.5981	3698	1012.7000	3745
8	9	8	36	24.0	45.4	109.1	13.8	0.5981	2731	1012.7000	2766
9	10	9	29	24.0	46.0	109.8	8.0	0.5981	2176	1012.7000	2204
10	11	10	35	24.0	43.2	109.4	13.7	0.5981	2699	1012.7000	2733
11	12	11	36	24.0	44.0	109.9	12.4	0.5981	2748	1012.7000	2783
12	13	12	32	24.0	46.0	110.4	9.3	0.5981	2404	1012.7000	2435
13	14	13	39	24.0	43.7	109.5	19.4	0.5981	3003	1012.7000	3041
14	15	14	52	24.0	43.0	108.5	25.9	0.5981	3971	1012.7000	4021
15	16	15	42	24.0	43.7	109.4	17.3	0.5981	3176	1012.7000	3216
16	17	16	36	24.0	44.5	110.0	12.4	0.5981	2736	1012.7000	2771
17	18	17	29	24.0	46.2	110.5	8.2	0.5981	2180	1012.7000	2208
18	19	18	28	24.0	46.6	110.5	7.6	0.5981	2132	1012.7000	2159
19	20	19	33	24.0	45.3	109.8	11.0	0.5981	2490	1012.7000	2522
20	21	20	51	24.0	43.2	108.3	25.3	0.5981	3849	1012.7000	3898
21	22	21	47	24.0	43.6	108.7	21.8	0.5981	3547	1012.7000	3592
22	23	22	38	24.0	45.5	109.2	14.3	0.5981	2877	1012.7000	2914
23	24	23	46	24.0	43.8	108.4	23.9	0.5981	3489	1012.7000	3533
24	25	24	60	24.0	44.3	106.9	36.7	0.5981	4567	1012.7000	4625
25	26	25	62	23.8	49.4	117.4	34.6	0.5981	4622	1012.7000	4681
26	27	26	60	24.0	49.1	122.2	31.5	0.5981	4527	1012.7000	4584
27	28	27	57	24.0	47.6	121.8	30.5	0.5981	4299	1012.7000	4354
28	29	28	63	24.0	47.1	121.9	34.1	0.5981	4790	1012.7000	4851
29	30	29	61	24.0	46.3	122.3	30.5	0.5981	4613	1012.7000	4672
30	31	30	63	24.0	46.9	122.0	35.6	0.5981	4812	1012.7000	4873
31	1	31	60	24.0	48.0	122.5	31.2	0.5981	4569	1012.7000	4627
Total									101482		102773

GAS QUALITY INFORMATION													
EFFECTIVE DATE	SAMPLE TYPE	WATER CONTENT	N2	CO2	H2S	C1	C2	C3	IC1	NC4	IC5	NC5	CG+
01/01/00	C	4.8	1.0700	2.0260	0.0000	95.1060	1.0090	0.2430	0.0760	0.1080	0.0590	0.0610	0.2420

Koch Gateway Pipeline Company  
DETAIL METER STATEMENT  
FOR THE MONTH OF 02/00

03/07/00 20:11:31  
PAGE 4

METER ID: 002520-01  
LOCATION: HATTIESBURG CITY GATE #1  
TYPE METER: EFM Orifice

SYSTEM: 007:Mississippi  
SUBSYSTEM: 014:Jackson to Leaksville 16" & 8"  
PURPOSE: Koch Custody Delivery

CONTRACT TIME: 09:00  
ANALYST: Matthews, Ljola  
PHONE #: 5044695903

METER INFORMATION											
EFFECTIVE DATE	REF NUM	STATIC RANGE	DIFF RANGE	TUBE SIZE	PLATE SIZE	TAP TYPE	TAP LOCA	CHART DAYS	MACHINE CONSTANT	CALC TYPE	
02/01/00	1	500	100	8.072	3.250	P	U	1	1.0000	14	

VOLUME INFORMATION											
DAY ON	DAY OFF	REF NUM	FLOW EXTENT	FLOW HOURS	TEMP	PRES PSIA	DIFF	SPEC GRAV	MCF VOLUME @ 14.730	BTU(D)	Dth
1	2	1	41	24.0	47.7	122.3	18.5	0.5981	3086	1012.7000	3125
2	3	2	46	24.0	48.7	121.6	30.3	0.5981	3463	1012.7000	3507
3	4	3	41	24.0	45.1	122.3	23.5	0.5981	3114	1012.7000	3154
4	5	4	44	24.0	46.7	122.3	22.0	0.5981	3311	1012.7000	3353
5	6	5	53	24.0	46.3	121.8	31.0	0.5981	4017	1012.7000	4068
6	7	6	49	24.0	45.7	122.0	27.6	0.5981	3713	1012.7000	3760
7	8	7	0	24.0	45.4	122.6	23.0	0.5981	3154	1012.7000	3194
8	9	8	42	24.0	44.9	121.9	29.6	0.5981	3227	1012.7000	3268
9	10	9	39	24.0	42.0	122.5	15.9	0.5981	3010	1012.7000	3048
10	11	10	36	24.0	44.3	122.4	13.0	0.5981	2770	1012.7000	2805
11	12	11	29	24.0	47.0	123.8	8.9	0.5981	2227	1012.7000	2255
12	13	12	26	24.0	47.1	123.5	7.0	0.5981	2015	1012.7000	2041
13	14	13	27	24.0	47.8	123.2	6.9	0.5981	2054	1012.7000	2080
14	15	14	61	24.0	43.7	123.2	41.5	0.5981	4660	1012.7000	4719
15	16	15	65	24.0	45.6	123.6	39.9	0.5981	4928	1012.7000	4991
16	17	16	61	24.0	45.6	123.6	38.7	0.5981	4675	1012.7000	4734
17	18	17	66	24.0	47.4	123.2	44.6	0.5981	5037	1012.7000	5101
18	19	18	66	24.0	47.9	123.4	45.3	0.5981	4916	1012.7000	4978
19	20	19	62	24.0	44.7	123.6	41.7	0.5981	4755	1012.7000	4815
20	21	20	63	24.0	45.3	123.1	40.9	0.5981	4802	1012.7000	4863
21	22	21	61	24.0	44.0	123.2	36.6	0.5981	4657	1012.7000	4716
22	23	22	59	24.0	44.9	123.2	38.1	0.5981	4487	1012.7000	4514
23	24	23	71	24.0	45.5	123.1	56.7	0.5981	5419	1012.7000	5488
24	25	24	73	24.0	45.8	123.6	54.6	0.5981	5525	1012.7000	5595
25	26	25	69	24.0	47.4	123.1	52.0	0.5981	5241	1012.7000	5308
26	27	26	74	24.0	46.4	122.9	50.1	0.5981	5617	1012.7000	5688
27	28	27	76	24.0	44.2	122.6	57.4	0.5981	5772	1012.7000	5846
28	29	28	60	24.0	44.9	122.7	38.6	0.5981	4588	1012.7000	4646
29	1	29	78	24.0	46.1	123.0	55.8	0.5981	5913	1012.7000	5988
Total									120153		121677

GAS QUALITY INFORMATION													
EFFECTIVE DATE	SAMPLE TYPE	WATER CONTENT	N2	CO2	H2S	C1	C2	C3	IC4	NC4	IC5	NC5	C6+
01/01/00	C	4.6	1.0700	2.0260	0.0000	95.1060	1.0090	0.2430	0.0760	0.1080	0.0590	0.0610	0.2420

*Handwritten note:*  
 THE REASON IS  
 INADEQUATE MEASUREMENT OF THESE METERS  
 DUE TO SPONGING & TEMPERATURE  
 ALL BOYS HIGHER.

Koch Gateway Pipeline Company  
 DETAIL METER STATEMENT  
 FOR THE MONTH OF 03/00

04/07/00 20:59:31  
 PAGE 4

METER ID: 002520-01  
 LOCATION: HATTIESBURG CITY GATE #1  
 TYPE METER: EFM Orifice

SYSTEM: 007:Mississippi  
 SUBSYSTEM: 014:Jackson to Leaksville 16" & 8"  
 PURPOSE: Koch Custody Delivery

CONTRACT TIME: 09:00  
 ANALYST: Matthews, L101a  
 PHONE #: 5044695903

----- METER INFORMATION -----										
EFFECTIVE DATE	REF NUM	STATIC RANGE	DIFF RANGE	TUBE SIZE	PLATE SIZE	TAP TYPE	TAP LOCA	CHART DAYS	MACHINE CONSTANT	CALC TYPE
03/01/00	1	500	100	8.072	3.250	P	U	1	1.0000	14

----- VOLUME INFORMATION -----												
DAY ON	DAY OFF	REF NUM	FLOW EXTENT	FLOW HOURS	TEMP	PRES PSIA	DIFF	SPEC GRAV	MCF VOLUME @ 14.730	BTU(D)	Dth	
1	2	1	80	24.0	45.7	123.0	65.7	0.6001	6105	1010.6000	6170	
2	3	2	83	24.0	45.4	122.9	61.6	0.6001	6340	1010.6000	6407	
3	4	3	78	24.0	46.0	122.8	52.4	0.6001	5964	1010.6000	6027	
4	5	4	75	24.0	44.7	122.4	54.7	0.6001	5698	1010.6000	5758	
5	6	5	69	24.0	45.2	122.7	43.4	0.6001	5296	1010.6000	5352	
6	7	6	73	24.0	45.9	123.0	46.8	0.6001	5576	1010.6000	5635	
7	8	7	70	24.0	46.7	123.2	41.3	0.6001	5316	1010.6000	5372	
8	9	8	68	24.0	47.4	123.2	39.0	0.6001	5187	1010.6000	5242	
9	10	9	67	24.0	48.2	123.2	37.8	0.6001	5126	1010.6000	5180	
10	11	10	72	24.0	47.9	123.2	42.9	0.6001	5489	1010.6000	5547	
11	12	11	65	24.0	45.8	122.4	41.7	0.6001	4955	1010.6000	5009	
12	13	12	61	24.0	46.0	122.2	37.7	0.6001	4661	1010.6000	4710	
13	14	13	59	24.0	46.5	122.4	35.2	0.6001	4469	1010.6000	4516	
14	15	14	76	24.0	46.9	122.6	52.5	0.6001	5771	1010.6000	5832	
15	16	15	83	24.0	47.3	122.5	57.9	0.6001	6275	1010.6000	6342	
16	17	16	75	24.0	47.2	122.7	49.2	0.6001	5723	1010.6000	5784	
17	18	17	79	24.0	46.5	122.7	52.7	0.6001	5904	1010.6000	6058	
18	19	18	77	24.0	46.5	122.5	49.7	0.6001	5841	1010.6000	5903	
19	20	19	80	24.0	45.8	122.2	59.3	0.6001	6072	1010.6000	6136	
20	21	20	64	24.0	46.6	122.4	44.1	0.6001	4861	1010.6000	4913	
21	22	21	74	24.0	47.0	122.8	49.8	0.6001	5649	1010.6000	5709	
22	23	22	76	24.0	47.1	122.9	49.8	0.6001	5801	1010.6000	5862	
23	24	23	75	24.0	47.9	123.0	48.4	0.6001	5704	1010.6000	5764	
24	25	24	72	24.0	48.2	123.0	43.5	0.6001	5470	1010.6000	5528	
25	26	25	68	24.0	48.7	123.1	37.8	0.6001	5136	1010.6000	5190	
26	27	26	78	24.0	47.2	122.5	50.9	0.6001	5894	1010.6000	5956	
27	28	27	82	24.0	47.7	122.1	59.3	0.6001	6239	1010.6000	6305	
28	29	28	76	24.0	49.4	122.7	50.5	0.6001	5790	1010.6000	5851	
29	30	29	80	24.0	49.3	122.5	54.0	0.6001	6099	1010.6000	6164	
30	31	30	81	24.0	49.2	122.7	57.6	0.6001	6150	1010.6000	6215	
31	1	31	79	24.0	48.8	122.8	53.5	0.6001	5971	1010.6000	6034	
Total									174623		176471	

----- GAS QUALITY INFORMATION -----													
EFFECTIVE DATE	SAMPLE TYPE	WATER CONTENT	N2	CO2	H2S	C1	C2	C3	IC4	NC4	IC5	NC5	C6+
03/01/00	C	3.1	1.2600	2.1050	0.0000	94.9360	0.8650	0.2230	0.0780	0.1190	0.0730	0.0780	0.2630

Koch Gateway Pipeline Company  
 DETAIL METER STATEMENT  
 FOR THE MONTH OF 04/00

05/05/00 20:29:05  
 PAGE 4

METER ID: 002520-01  
 LOCATION: HATTIESBURG CITY GATE #1  
 TYPE METER: EFM Office

SYSTEM: 007:Mississippi  
 SUBSYSTEM: 014:Jackson to Leaksville 16" & 8"  
 PURPOSE: Koch Custody Delivery

CONTRACT TIME: 09:00  
 ANALYST: Matthews, LToTa  
 PHONE #: 5044695903

METER INFORMATION										
EFFECTIVE DATE	REF NUM	STATIC RANGE	DIFF RANGE	TUBE SIZE	PLATE SIZE	TAP TYPE	TAP LOCA	CHART DAYS	MACHINE CONSTANT	CALC TYPE
04/01/00	1	500	100	8.072	3.250	P	U	1	1.0000	14

VOLUME INFORMATION												
DAY ON	DAY OFF	REF NUM	FLOW EXTENT	FLOW HOURS	TEMP	PRES PSIA	DIFF	SPEC GRAV	MCF VOLUME @ 14.730	BTU(D)	Oth	
1	2	1	75	23.0	49.8	122.8	47.7	0.5955	5494	1015.1000	5577	
2	3	2	77	24.0	50.1	122.8	49.8	0.5955	5883	1015.1000	5972	
3	4	3	86	24.0	48.1	122.3	64.0	0.5955	6538	1015.1000	6637	
4	5	4	51	24.0	49.6	122.2	22.3	0.5955	3860	1015.1000	3918	
5	6	5	76	24.0	49.8	122.5	57.6	0.5955	5786	1015.1000	5873	
6	7	6	82	24.0	50.2	122.6	60.4	0.5955	6193	1015.1000	6287	
7	8	7	81	24.0	50.0	122.7	55.1	0.5955	6157	1015.1000	6250	
8	9	8	63	24.0	48.7	122.3	43.8	0.5955	4823	1015.1000	4896	
9	10	9	76	24.0	48.5	122.3	53.9	0.5955	5751	1015.1000	5838	
10	11	10	76	24.0	49.3	122.6	53.8	0.5955	5817	1016.1000	5905	
11	12	11	79	24.0	49.8	122.8	54.9	0.5955	6018	1015.1000	6109	
12	13	12	82	24.0	49.8	122.7	56.9	0.5955	6272	1015.1000	6367	
13	14	13	84	24.0	49.2	122.4	59.5	0.5955	6419	1015.1000	6516	
14	15	14	82	24.0	49.3	122.3	56.8	0.5955	6230	1015.1000	6324	
15	16	15	75	24.0	49.3	122.3	47.5	0.5955	5697	1015.1000	5783	
16	17	16	75	24.0	50.2	122.6	46.7	0.5955	5674	1015.1000	5760	
17	18	17	76	24.0	50.0	122.6	50.0	0.5955	5797	1015.1000	5885	
18	19	18	78	24.0	50.5	122.7	51.6	0.5955	5940	1015.1000	6030	
19	20	19	77	24.0	53.6	122.9	49.4	0.5955	5823	1015.1000	5911	
20	21	20	77	24.0	52.5	122.9	49.2	0.5955	5840	1015.1000	5928	
21	22	21	78	24.0	51.3	122.5	51.2	0.5955	5943	1015.1000	6033	
22	23	22	75	24.0	51.7	122.6	47.1	0.5955	5690	1015.1000	5776	
23	24	23	75	24.0	50.4	122.3	46.7	0.5955	5703	1015.1000	5789	
24	25	24	75	24.0	50.6	122.3	47.9	0.5955	5665	1015.1000	5751	
25	26	25	77	24.0	50.5	122.3	50.9	0.5955	5877	1015.1000	5966	
26	27	26	69	24.0	49.3	122.4	40.5	0.5955	5227	1015.1000	5306	
27	28	27	68	24.0	50.3	122.4	38.6	0.5955	5186	1015.1000	5264	
28	29	28	71	24.0	50.9	122.5	41.6	0.5955	5381	1015.1000	5462	
29	30	29	67	24.0	51.2	122.6	37.3	0.5955	5091	1015.1000	5168	
30	1	30	66	24.0	51.7	122.8	35.9	0.5955	5000	1015.1000	5076	
Total									170775	173357		

GAS QUALITY INFORMATION													
EFFECTIVE DATE	SAMPLE TYPE	WATER CONTENT	N2	CO2	H2S	C1	C2	C3	IC4	NC4	IC5	NC5	C6+
04/01/00	C	2.4	1.1410	1.7180	0.0000	95.3340	1.0320	0.2250	0.0690	0.1070	0.0640	0.0670	0.2430

*# / M MCF*  
*(7 # / M MCF is standard)*  
*% by volume (in dec %)*  
*grains*

Koch Gateway Pipeline Company  
 DETAIL METER STATEMENT  
 FOR THE MONTH OF 05/00

06/07/00 18:59:44  
 PAGE 4

METER ID: 002520-01  
 LOCATION: HATTIESBURG CITY GATE #1  
 TYPE METER: EFM Orifice

SYSTEM: 007:Mississippi  
 SUBSYSTEM: 014:Jackson to Leaksville 16" & 8"  
 PURPOSE: Koch Custody Delivery

CONTRACT TIME: 09:00  
 ANALYST: Matthews, Lita  
 PHONE #: 5044695903

METER INFORMATION										
EFFECTIVE DATE	REF NUM	STATIC RANGE	DIFF RANGE	TUBE SIZE	PLATE SIZE	TAP TYPE	TAP LOCA	CHART DAYS	MACHINE CONSTANT	CALC TYPE
05/01/00	1	500	100	8.072	3.250	P	U	1	1.0000	14

VOLUME INFORMATION												
DAY ON	DAY OFF	REF NUM	FLOW EXTENT	FLOW HOURS	TEMP	PRES PSIA	DIFF	SPEC GRAV	MCF VOLUME @ 14.730	BTU(D)	DtH	
1	2	1	56	24.0	52.4	122.8	26.9	0.5999	4263	1015.0000	4327	
2	3	2	66	24.0	52.1	122.6	36.1	0.5999	5001	1015.0000	5076	
3	4	3	67	24.0	52.2	122.5	36.9	0.5999	5055	1015.0000	5131	
4	5	4	62	24.0	55.3	122.7	31.9	0.5999	4698	1015.0000	4768	
5	6	5	63	24.0	53.8	122.7	32.7	0.5999	4731	1015.0000	4802	
6	7	6	64	24.0	54.5	122.8	34.0	0.5999	4844	1015.0000	4917	
7	8	7	66	24.0	55.4	122.8	36.4	0.5999	4996	1015.0000	5071	
8	9	8	70	24.0	56.7	122.8	40.2	0.5999	5247	1015.0000	5326	
9	10	9	61	24.0	57.5	123.0	32.0	0.5999	4618	1015.0000	4687	
10	11	10	60	24.0	57.2	123.0	29.9	0.5999	4541	1015.0000	4609	
11	12	11	58	24.0	59.0	123.0	28.0	0.5999	4377	1015.0000	4443	
12	13	12	52	24.0	59.0	123.0	23.6	0.5999	3953	1015.0000	4012	
13	14	13	52	24.0	57.4	123.0	22.4	0.5999	3920	1015.0000	3979	
14	15	14	55	24.0	55.6	122.9	25.2	0.5999	4138	1015.0000	4200	
15	16	15	58	24.0	56.6	122.8	28.0	0.5999	4378	1015.0000	4444	
16	17	16	57	24.0	57.1	122.9	27.0	0.5999	4287	1015.0000	4351	
17	18	17	52	24.0	59.5	122.9	23.5	0.5999	3943	1015.0000	4002	
18	19	18	51	24.0	60.3	123.1	22.9	0.5999	3824	1015.0000	3881	
19	20	19	48	24.0	60.5	123.2	20.9	0.5999	3626	1015.0000	3680	
20	21	20	42	24.0	59.0	122.9	15.5	0.5999	3202	1015.0000	3250	
21	22	21	45	24.0	57.9	122.8	17.2	0.5999	3390	1015.0000	3441	
22	23	22	50	24.0	59.5	123.1	21.8	0.5999	3784	1015.0000	3841	
23	24	23	51	24.0	61.5	123.2	22.7	0.5999	3849	1015.0000	3907	
24	25	24	49	24.0	61.8	123.1	21.2	0.5999	3702	1015.0000	3758	
25	26	25	48	24.0	61.8	123.1	20.0	0.5999	3629	1015.0000	3683	
26	27	26	45	24.0	62.7	123.1	18.5	0.5999	3407	1015.0000	3458	
27	28	27	43	24.0	63.3	123.1	16.0	0.5999	3197	1015.0000	3245	
28	29	28	41	24.0	61.0	123.0	14.2	0.5999	3055	1015.0000	3101	
29	30	29	45	24.0	59.9	123.0	17.4	0.5999	3372	1015.0000	3423	
30	31	30	47	24.0	61.2	123.0	19.1	0.5999	3513	1015.0000	3566	
31	1	31	46	24.0	61.2	123.0	18.7	0.5999	3494	1015.0000	3546	
Total									126034		127925	

GAS QUALITY INFORMATION													
EFFECTIVE DATE	SAMPLE TYPE	WATER CONTENT	N2	CO2	H2S	C1	C2	C3	IC4	NC4	IC5	NC5	C6+
05/01/00	C	2.8	1.2290	1.9370	0.0000	94.9830	0.9570	0.2470	0.0820	0.1280	0.0750	0.0790	0.2830

Koch Gateway Pipeline Company  
 DETAIL METER STATEMENT  
 FOR THE MONTH OF 06/00

07/10/00 19:15:53  
 PAGE 4

METER ID: 002520-01  
 LOCATION: HATTIESBURG CITY GATE #1  
 TYPE METER: EFM Orifice

SYSTEM: 007:Mississippi  
 SUBSYSTEM: 014:Jackson to Leaksville 16" & 8"  
 PURPOSE: Koch Custody Delivery

CONTRACT TIME: 09:00  
 ANALYST: Matthews, LLoTa  
 PHONE #: 5044695903

METER INFORMATION										
EFFECTIVE DATE	REF NUM	STATIC RANGE	DIFF RANGE	TUBE SIZE	PLATE SIZE	TAP TYPE	TAP LOCA	CHART DAYS	MACHINE CONSTANT	CALC TYPE
06/01/00	1	500	100	8.072	3.250	P	U	1	1.0000	14

VOLUME INFORMATION												
DAY ON	DAY OFF	REF NUM	FLOW EXTENT	FLOW HOURS	TEMP	PRES PSIA	DIFF	SPEC GRAV	MCF VOLUME @ 14.730	BTU(D)	Dth	
1	2	1	48	24.0	61.6	123.1	20.5	0.5981	3634	1029.0000	3739	
2	3	2	46	24.0	61.7	123.1	18.8	0.5981	3461	1029.0000	3561	
3	4	3	45	24.0	62.0	123.2	17.8	0.5981	3356	1029.0000	3453	
4	5	4	45	24.0	61.3	123.1	17.6	0.5981	3392	1029.0000	3490	
5	6	5	48	24.0	59.7	122.9	20.1	0.5981	3639	1029.0000	3745	
6	7	6	50	24.0	59.6	123.0	21.3	0.5981	3731	1029.0000	3839	
7	8	7	50	24.0	58.8	122.9	21.0	0.5981	3724	1029.0000	3832	
8	9	8	48	24.0	60.6	123.1	20.2	0.5981	3618	1029.0000	3723	
9	10	9	46	24.0	60.1	123.1	18.5	0.5981	3455	1029.0000	3555	
10	11	10	41	24.0	61.6	123.1	14.4	0.5981	3041	1029.0000	3129	
11	12	11	43	24.0	61.7	123.2	16.0	0.5981	3222	1029.0000	3315	
12	13	12	41	24.0	62.8	123.1	15.0	0.5981	3083	1029.0000	3172	
13	14	13	42	24.0	63.2	122.9	15.2	0.5981	3133	1029.0000	3224	
14	15	14	47	24.0	63.1	122.7	18.6	0.5981	3506	1029.0000	3608	
15	16	15	46	24.0	62.0	122.5	18.2	0.5981	3452	1029.0000	3552	
16	17	16	45	24.0	61.0	122.5	17.7	0.5981	3411	1029.0000	3510	
17	18	17	41	24.0	61.5	122.5	14.9	0.5981	3111	1029.0000	3201	
18	19	18	39	24.0	62.9	122.6	13.1	0.5981	2931	1029.0000	3016	
19	20	19	43	24.0	63.4	122.7	15.6	0.5981	3182	1029.0000	3274	
20	21	20	44	24.0	63.6	122.7	16.7	0.5981	3293	1029.0000	3388	
21	22	21	47	24.0	64.6	122.8	19.0	0.5981	3516	1029.0000	3618	
22	23	22	44	24.0	62.9	122.7	17.0	0.5981	3317	1029.0000	3413	
23	24	23	46	24.0	63.1	122.7	18.4	0.5981	3479	1029.0000	3580	
24	25	24	48	24.0	63.4	122.7	19.4	0.5981	3598	1029.0000	3702	
25	26	25	53	24.0	62.1	122.7	23.5	0.5981	3956	1029.0000	4071	
26	27	26	60	24.0	61.7	122.6	30.0	0.5981	4485	1029.0000	4615	
27	28	27	55	24.0	63.2	122.7	25.5	0.5981	4138	1029.0000	4258	
28	29	28	56	24.0	64.0	122.7	25.7	0.5981	4149	1029.0000	4269	
29	30	29	54	24.0	62.1	122.6	24.0	0.5981	4008	1029.0000	4124	
30	1	30	52	24.0	62.2	122.7	22.3	0.5981	3884	1029.0000	3997	
Total									105905		108973	

GAS QUALITY INFORMATION													
EFFECTIVE DATE	SAMPLE TYPE	WATER CONTENT	N2	CO2	H2S	C1	C2	C3	IC4	NC4	IC5	NC5	C6+
06/01/00	C	4.8	0.9230	1.4770	0.0000	95.0770	1.4750	0.3710	0.1130	0.1480	0.0700	0.0760	0.2700



# **Kymene Process Area**

## **KYMENE PROCESS AREA REPORT SUMMARY**

### **Kymene Reactor Scrubber (AA-001)**

As required by 5.B.14, weekly operator maintenance checks were performed on the Kymene Reactor Scrubber (AA-001). No problems were noted during the weekly operator visual inspections.

The weekly operator maintenance check on the week of 1/3/00 was not recorded, and is reported as a deviation from a permitted requirement in this submittal.

### **Adipic Acid Dust Shaker (AA-002)**

As required by 5.B.14, weekly operator maintenance checks were performed on the Adipic Acid Dust Shaker (AA-002). No problems were noted during the weekly operator visual inspections. Hercules Incorporated began a more thorough inspection of the Dust Shaker on 2/16/00, which included a mechanic removing the shaker door on a weekly basis and performing a visual inspection of the filter bags. Filter bags were replaced on 3/1, 5/25, and 6/19/00.

As required by 5.B.8, the amount of raw material processed and hours operated were recorded daily, and the records are included in this section.

The weekly operator maintenance check was not recorded on the week of 1/3/00, and is reported as a deviation from a permitted requirement in this submittal. The mechanic inspection of the filter bags was not recorded on the weeks of 3/6 and 5/15/00.



**Emission Point - AA002**  
**Adipic Acid Handling System Equipment with a Dust Shaker**

Date	Batch Number	Adipic Acid Addition Time	Adipic Acid Total Charge	Adipic Acid Total Charge	Adipic Acid Total Charge	Comments
(M-D-Y)		minutes	boxes	pounds	ton/hr	
5/8/00	302	90	8	12000	4	
5/9/00	303	90	8	12000	4	
5/10/00	304	90	8	12000	4	
5/11/00	305	90	8	12000	4	
5/12/00	306	90	8	12005	4	
5/12/00	307	90	8	12000	4	
5/15/00	308	90	8	12000	4	
5-15-00	309	90	8	12007	4	
5-17-00	310	90	8	12000	4	
5-18-00	311	90	8	12000	4	
5-19-00	312	90	8	12003	4	
5/20/00	313	90	8	12000	4	
5/21/00	314	90	8	12000	4	
5/21/00	315	90	8	12000	4	
5/24/00	316	90	8	12000	4	
5/24/00	317	90	8	12000	4	
5/25/00	318	90	8	12000	4	
5/26/00	319	90	8	11994	4	
5/27/00	320	90	8	12007	4	
5/28/00	321	90	8	12003	4	
5/30/00	322	90	8	11998	4	
5/30/00	323	90	8	12003	4	
6/1/00	324	90	8	12000	4	
6/2/00	325	90	8	12000	4	
6/4/00	326	90	8	11999	4	
6/4/00	327	90	8	12000	4	
6/7/00	328	90	8	12000	4	
6/7/00	329	90	8	12000	4	
6/8/00	330	90	8	12,004	4	
6/9/00	331	90	8	12,005	4	
6/10/00	332	90	8	12,005	4	
6/10/00	333	90	8	12,000	4	
6-10-00	334	90	8	12007	4	
6-11-00	335	90	8	12005	4	
6-13-00	336	90	8	12000	4	
6-14-00	337	90	8	12000	4	
6/15/00	338	90	8	12000	4	
6/17/00	339	90	8	12,000	4	
6/19/00	340	90	8	12,005	4	
6/28/00	341	90	8	12,005	4	
6/30/00	342	90	8	12,000	4	
6/31/00	343	90	8	12,000	4	
6/31/00	344	90	8	12,000	4	
6/23/00	345	90	8	11999	4	
6-26-00	346	90	8	12000	4	
6-27-00	347	90	8	12003	4	
6-28-00	348	90	8	12003	4	
6/28/00	349	90	8	12005	4	



**Emission Point - AA002**  
**Adipic Acid Handling System Equipment with a Dust Shaker**

Date	Adipic Acid Addition Time	Adipic Acid Total Charge	Adipic Acid Total Charge	Adipic Acid Total Charge	Comments
(M-D-Y)	minutes	boxes	pounds	ton/hr	
3/10/00	90	8	12,000	4	
3/10/00	90	8	12,000	4	
3/11/00	90	8	12,000	4	
3/11/00	90	8	12,000	4	
3/12/00	90	8	12,000	4	
3/12/00	90	8	12,000	4	
3/14/00	90	8	12,000	4	
3/15/00	90	8	12,000	4	
3/16/00	90	8	12,000	4	
3/17/00	90	8	12,000	4	
3/18/00	90	8	12,000	4	
3/20/00	90	8	12,000	4	
3/23/00	90	8	12,000	4	
3/24/00	90	8	12,000	4	
3/24/00	90	8	12,000	4	
3/26/00	90	8	12,000	4	
3/27/00	90	8	12,000	4	
3/28/00	90	8	12,000	4	
3/28/00	90	8	12,000	4	
3/29/00	90	8	12,000	4	
3/30/00	90	8	12,000	4	
3/31/00	90	8	12,000	4	
4/3/00	90	8	12,000	4	
4/3/00	90	8	12,000	4	
4/4/00	90	8	12,000	4	
4/5/00	90	8	12,000	4	
4/6/00	90	8	12,000	4	
4/7/00	90	8	12,000	4	
4/7/00	90	8	11,994	4	
4/8/00	90	8	12,000	4	
4/9/00	90	8	11,996	4	
4/11/00	90	8	11,999	4	
4/12/00	90	8	12,004	4	
4/12/00	90	8	12,000	4	
4/13/00	90	8	12,000	4	
<del>4/14/00</del>	<del>90</del>	<del>8</del>	<del>12,000</del>	<del>4</del>	
4-14-00	90	8	12,005	4	
4-15-00	90	8	12,000	4	
4-18-00	90	8	12,000	4	
4-19-00	90	8	12,000	4	
4/20/00	90	8	12,000	4	
4/20/00	90	8	12,000	4	
4-21-00	90	8	12,000	4	
4-24-00	90	8	12,002	4	



**Emission Point - AA002**  
**Adipic Acid Handling System Equipment with a Dust Shaker**

Date	Adipic Acid Addition Time	Adipic Acid Total Charge	Adipic Acid Total Charge	Adipic Acid Total Charge	Comments
(M-D-Y)	minutes	boxes	pounds	ton/hr	
1-13-2000	90	8	12,000	4	Raise Adipic <sup>Add</sup> 20 lbs
1-14-2000	90	8	12,000	4	
1-15-00	90	8	12,000	4	
1-11-00	90	8	<del>12,000</del>	4	
1/12/2000	90	8	12,000	4	
1/13/2000	90	8	12,000	4	
1/20/2000	90	8	12,000	4,0	
1/21/2000	90	8	12,000	4	
1/22/2000	90	8	12,000	4	
1/25/2000	90	8	12,000	4	
1/31/2000	90	8	12,000	4	
1/27/2000	90	8	12,000	4	
1/29/2000	90	8	12,000	4	
1/29/2000	90	8	12,000	4	
2/1/2000	90	8	12,000	4	
2/2/00	90	8	12,000	4	
2/2/00	90	8	12,000	4	
2/2/00	90	8	12,000	4	
2/5/00	90	8	12,000	4	
2/6/00	90	8	12,000	4	
2/7/00	90	8	12,000	4	
2/9/00	90	8	12,000	4	
3/1/00	90	8	12,000	4	
3/15/00	90	8	12,000	4	
3/16/00	90	8	12,000	4	
3/17/00	90	8	12,000	4	
3/19/00	90	8	12,000	4	
3/21/00	90	8	12,000	4	
3/22/00	90	8	12,000	4	
3/23/00	90	8	12,000	4	
3/23/00	90	8	12,000	4	
3/24/00	90	8	12,000	4	
3/25/00	90	8	12,000	4	
3/26/00	90	8	12,000	4	
3/27/00	90	8	12,000	4	
3/27/00	90	8	12,000	4	
3/29/00	90	8	12,000	4	
3/1/00	90	8	12,000	4	
3/2/00	90	8	12,000	4	
3/2/00	90	8	12,000	4	
3/3/00	90	8	12,000	4	
3/4/00	90	8	12,000	4	
3/5/00	90	8	12,000	4	

(EPAA002b.WK4)

**Emission Point - AA002**  
**Adipic Acid Handling System Equipment with a Dust Shaker**

Date	Adipic Acid Addition Time	Adipic Acid Total Charge	Adipic Acid Total Charge	Adipic Acid Total Charge	Comments
(M-D-Y)	minutes	boxes	pounds	ton/hr	
10-25-99	90	8	11960	4.0	
11-3-99	90	8	11960	4.0	
11-6-99	90	8	11960	4.0	
11-7-99	90	8	11960	4.0	
11-08-99	90	8	11960	4.0	0.150 B <sup>2</sup>
11-12-99	90	8	11960	4.0	
11-13-99	90	8	11960	4.0	
11-17-99	90	8	11960	4.0	
11-16-99	90	8	11960	4.0	
11-16-99	90	8	11960	4.0	
11-17-99	90	8	11960	4.0	
11-18-99	90	8	11980	4.0	Raise Adipic Acid
11-18-99	90	8	11980	4.0	
11-19-99	90	8	11980	4.0	
11-20-99	90	8	11980	4.0	
11-21-99	90	8	11980	4.0	
11-22-99	90	8	11980	4.0	
11-23-99	90	8	11980	4.0	
11-24-99	180	16	23960	4.8.0	Jm 1-19-00
11-26-99	90	8	11980	4.0	
11-27-99	180	16	23960	4.8.0	Jm 1-19-00
11-28-99	90	8	11980	4.0	
11-30-99	90	8	11980	4.0	
12-1-99	180	16	23980	4.8.0	Jm 1-19-00
12-2-99	180	16	2398	4.8.0	Jm 1-19-00
12-8-99	180	8	11980	4.0	
12-9-99	90	8	11980	4.0	
12-14-99	90	8	11980	4.0	
12-14-99	90	8	11980	4.0	
12-21-99	90	8	11980	4.0	
12-22	90	8	11980	4.0	
12-26	90	8	11980	4.0	
12-27	90	8	11980	4.0	
12-27	90	8	11980	4.0	
12-31	90	8	11980	4.0	
1-3-2000	90	8	11980	4.0	
1-4-2000	90	8	11980	4.0	
1-5-00	90	8	11980	4.0	
1-6-00	90	8	11980	4.0	
1-7-00	90	8	11980	4.0	
1-8-00	90	8	11980	4.0	
1-11-00	180	16	23980	4.8.0	Jm 1-19-00
1-9-2000	90	8	11980	4.0	

(EPAA002b.WK4)



# **AKD Process Area**

## **AKD PROCESS AREA REPORT SUMMARY**

### **Paracol Water Scrubber (AB-001)**

As required by 5.B.14, weekly operator maintenance checks were performed on the Paracol Water Scrubber (AB-001). No problems were noted during the weekly operator visual inspections.

As required by 5.B.9, water flowrate through the scrubber was recorded on a weekly basis.

### **Silica Furnace Dust Collector (AL-002)**

As required by 5.B.14, weekly maintenance checks were to be performed on the Silica Furnace Dust Collector (AL-002); however, due to the Defoamer Process Area being shut down, the dust collector did not operate during this semi-annual reporting period.

As required by 5.B.11, the silica processed and the hours operated were not recorded because the process was not in operation.

# Title V -- Maintenance Log AKD Area

Date	Initials	Paracol Vent Scrubber, AB001					Silica Furnace Dust Collector, AL002										
		Melter Operating		Water flow, gpm	Leaks		Furnace Running		Blower OK		Dust Collector OK		Leaks				
		Yes	No		Yes	No	Yes	No	Yes	No	Yes	No	Yes	No			
6-5	BA	✓		5.3		✓		NOT OPERATING	→	NOT OPERATING	→	NOT OPERATING	→				
6-11	ume	✓		5.6		✓		NOT OPERATING	→	NOT OPERATING	→	NOT OPERATING	→				
6-19	JL	✓		5.2		✓		NOT OPERATING	→	NOT OPERATING	→	NOT OPERATING	→				
6-26	BA	✓		5.6		✓		NOT OPERATING	→	NOT OPERATING	→	NOT OPERATING	→				
7-3	ume	✓		5.5		✓		NOT OPERATING	→	NOT OPERATING	→	NOT OPERATING	→				
7-10	JL	✓		5.5		✓		NOT OPERATING	→	NOT OPERATING	→	NOT OPERATING	→				
7-17	BA	✓		5.7		✓		NOT OPERATING	→	NOT OPERATING	→	NOT OPERATING	→				

# Title V -- Maintenance Log AKD Area

Date	Initials	Paracol Vent Scrubber, AB001				Silica Furnace Dust Collector, AL002								
		Melter Operating		Water flow, gpm	Leaks		Furnace Running		Blower OK		Dust Collector OK		Leaks	
		Yes	No		Yes	No	Yes	No	Yes	No	Yes	No	Yes	No
3-13-00	EM	✓		5.5		✓		Not operating	→	Not operating	→	Not operating	→	→
3-20-00	EM	✓		5.7		✓		Not operating	→	Not operating	→	Not operating	→	→
3-27-00	EM	✓		5.5		✓		Not operating	→	Not operating	→	Not operating	→	→
4-3-00	EM	✓		5.8		✓		Not operating	→	Not operating	→	Not operating	→	→
4-10-00	EM	✓		5.8		✓		Not operating	→	Not operating	→	Not operating	→	→
4-17	JL	✓		5.7		✓		Not operating	→	Not operating	→	Not operating	→	→
4-24	EM	✓		5.6		✓		Not operating	→	Not operating	→	Not operating	→	→
5-1-00	EM	✓		5.7		✓		Not operating	→	Not operating	→	Not operating	→	→
5-8-00	EM	✓		5.8		✓		Not operating	→	Not operating	→	Not operating	→	→
5-15-00	EM	✓		5.8		✓		Not operating	→	Not operating	→	Not operating	→	→
5-22	JL	✓		5.8		✓		Not operating	→	Not operating	→	Not operating	→	→
5-29	EM	✓		5.8		✓		Not operating	→	Not operating	→	Not operating	→	→

**Title V -- Maintenance Log  
AKD Area**

Date	Initials	Paracol Vent Scrubber, AB001				Silica Furnace Dust Collector, AL002												
		Melter Operating		Water flow, gpm	Leaks		Furnace Running		Blower OK		Dust Collector OK		Leaks					
		Yes	No		Yes	No	Yes	No	Yes	No	Yes	No	Yes	No				
1-17-00	EM	✓	✓	56.89	1-19-2:00 AM EM	✓	Not operating	✓	Not operating	✓	Not operating	✓	Not operating	✓	Not operating	✓	Not operating	
				MARK ONLY IN ONE COLUMN.			✓	OPERATING	✓	OPERATING	✓	OPERATING	✓	OPERATING	✓	OPERATING	✓	OPERATING
				UNDER COLUMN (WATER LEAK)			✓	OPERATING	✓	OPERATING	✓	OPERATING	✓	OPERATING	✓	OPERATING	✓	OPERATING
				SOME LEAK LIKE COMMS.			✓	OPERATING	✓	OPERATING	✓	OPERATING	✓	OPERATING	✓	OPERATING	✓	OPERATING
				IMPOSSIBLE. CAS 1-18-00			✓	OPERATING	✓	OPERATING	✓	OPERATING	✓	OPERATING	✓	OPERATING	✓	OPERATING
1-24-00	UME	✓	✓	5.50		✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	
1-31-00	EM	✓	✓	6.0		✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	
2-7-00	EM	✓	✓	6.0		✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	
2-14-00	EM	✓	✓	6.0		✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	
2-21-00	UME	✓	✓	5.79		✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	
2-28-00	EM	✓	✓	5.6		✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	
2-7-2000	EM	✓	✓	5.7		✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	✓	NOT OPERATING	

# Title V -- Maintenance Log AKD Area

THE SILICA FROM THE POST GRINDERS NOT GRINDERS.

Date	Initials	Paracol Vent Scrubber, AB001				Silica Furnace Dust Collector, AL002																						
		Melter Operating		Water flow, gpm	Leaks		Furnace Running		Blower OK		Dust Collector OK		Leaks															
		Yes	No		Yes	No	Yes	No	Yes	No	Yes	No	Yes	No														
11-1-99	EM	✓		5,615		✓		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000				
11-8-99	EM	✓		5,785		✓		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		
11-15-99	EM	✓		5,746		✓		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		
				MARK ONLY ONE COLUMN W/ A CHECK GR																								
				IT'S CONFUSING																								
11-22-99	EM	✓		5,807		✓		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		
11-29-99	EM	✓		5,797		✓		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		
12-6-99	EM	✓		5,644		✓		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		
12-20-99	JL	✓		5,491		✓		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		
12-27-99	JL	✓		5,887		✓		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		
1-3-00	BA	✓		5,568		✓		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		
1-10-00	EM	✓		5,263		✓		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		1-19-2000		

# **HRA Process Area**

## **HRA PROCESS AREA REPORT SUMMARY**

### **HRA Water Scrubber (AG-003)**

As required by 5.B.14, weekly operator maintenance checks were performed on the HRA Water Scrubber (AG-003). No problems were noted during the operator visual inspections, which are performed weekly (or more frequent). On 5/31/00 no water flowrate to the scrubber was observed during the 11 to 7 shift and appropriate actions were taken.

### **HRA Flaking Belt Dust Collector (AG-005)**

As required by 5.B.14, weekly maintenance checks were performed on the HRA Flaking Belt Dust Collector (AG-005). No problems were noted during the operator visual inspections, which are performed weekly (or more frequent). Filter bags were replaced on 5/24/00.

As required by 5.B.10, the pressure drop across the baghouse is recorded weekly (or more frequent).

### **Hydrogen Generation Process (AK-000)**

As required by 5.B.14, weekly maintenance checks were to be performed on the Hydrogen Generation Process (AK-000); however, due to this process area being shut down, the area did not operate during the semi-annual reporting period.



# **Poly-Pale Process Area**

## **POLY-PALE PROCESS AREA REPORT SUMMARY**

### **Poly-Pale Water Scrubber #1 (AC-002)**

As required by 5.B.14, weekly maintenance checks were performed on the Poly-Pale Water Scrubber #1 (AC-002). No problems were noted during the weekly operator visual inspections.

### **Poly-Pale Water Scrubber #2 (AC-003)**

As required by 5.B.14, weekly maintenance checks were performed on the Poly-Pale Water Scrubber #2 (AC-003). No problems were noted during the weekly operator visual inspections.

### **Poly-Pale Process Meltor (AC-004)**

As required by 5.B.13, the amount of raw material processed and hours operated were recorded daily, and the records are included in this section.

**EMISSION POINT AC-004 (MELTER)****Report Period:  
Jan. - June, 2000****Note: No activity on those dates not shown.**

<b>DATE</b>	<b># HOURS</b>	<b># DRUMS</b>	<b>TOTAL LBS.</b>	<b>TONS/HR.</b>
02/03/2000	8	20	9921	0.620
02/07/2000	8	60	29762	1.860
02/08/2000	8	40	19841	1.240
02/09/2000	8	20	9921	0.620
02/18/2000	16	120	59524	1.860
02/19/2000	16	80	39683	1.240
02/20/2000	16	120	59524	1.860
02/21/2000	16	100	49604	1.550
02/22/2000	16	100	49604	1.550
02/23/2000	16	94	46627	1.457
02/24/2000	16	120	59524	1.860
02/25/2000	8	20	9921	0.620
02/26/2000	16	120	59524	1.860
02/27/2000	16	100	49604	1.550
02/28/2000	16	120	59524	1.860
02/29/2000	16	92	45635	1.426
03/01/2000	8	60	29762	1.860
03/03/2000	8	60	29762	1.860
03/04/2000	16	120	59524	1.860
03/05/2000	16	100	49604	1.550
03/06/2000	16	100	49604	1.550
03/07/2000	16	88	43651	1.364
03/08/2000	16	98	48611	1.519
03/10/2000	16	100	49604	1.550
03/11/2000	16	67	33234	1.039

**EMISSION POINT AC-004 (MELTER)****Report Period:  
Jan. - June, 2000****Note: No activity on those dates not shown.**

<b>DATE</b>	<b># HOURS</b>	<b># DRUMS</b>	<b>TOTAL LBS.</b>	<b>TONS/HR.</b>
03/12/2000	16	120	59524	1.860
03/14/2000	16	82	40675	1.271
03/16/2000	8	40	19841	1.240
03/19/2000	16	102	50596	1.581
03/20/2000	16	78	38691	1.209
03/21/2000	16	78	38691	1.209
03/22/2000	16	78	38691	1.209
03/23/2000	16	50	24802	0.775
03/24/2000	16	80	39683	1.240
03/25/2000	16	50	24802	0.775
03/26/2000	16	62	30754	0.961
03/27/2000	8	48	23810	1.488
03/28/2000	16	72	35715	1.116
03/29/2000	16	88	43651	1.364
04/04/2000	16	120	59524	1.860
04/05/2000	16	100	49604	1.550
04/06/2000	16	110	54564	1.705
04/07/2000	8	22	10913	0.682
04/10/2000	16	100	49604	1.550
04/11/2000	8	3	1488	0.093
05/11/2000	8	42	20833	1.302
05/15/2000	8	20	9921	0.620

**EMISSION POINT AC-004 (MELTER)**

Report Period:  
Jan. - June, 2000

Note: No activity on those dates not shown.

DATE	# HOURS	# DRUMS	TOTAL LBS.	TONS/HR.
05/16/2000	8	40	19841	1.240
05/17/2000	16	100	49604	1.550
05/18/2000	8	24	11905	0.744
05/19/2000	8	40	19841	1.240
05/20/2000	16	120	59524	1.860
05/21/2000	16	120	59524	1.860
05/22/2000	8	60	29762	1.860
05/24/2000	16	60	29762	0.930
05/25/2000	8	60	29762	1.860
05/26/2000	16	80	39683	1.240
05/27/2000	16	120	59524	1.860
05/28/2000	16	120	59524	1.860
05/29/2000	16	140	69445	2.170
05/30/2000	16	120	59524	1.860
05/31/2000	16	120	59524	1.860
06/01/2000	16	44	21826	0.682
06/02/2000	16	60	29762	0.930
06/03/2000	16	120	59524	1.860
06/04/2000	16	26	12897	0.403
06/05/2000	8	15	7441	0.465
06/06/2000	16	150	74405	2.325
06/08/2000	16	100	49604	1.550
06/10/2000	16	120	59524	1.860
06/11/2000	16	120	59524	1.860
06/12/2000	16	80	39683	1.240
06/13/2000	16	120	59524	1.860

**EMISSION POINT AC-004 (MELTER)**

**Report Period:  
Jan. - June, 2000**

**Note: No activity on those dates not shown.**

<b>DATE</b>	<b># HOURS</b>	<b># DRUMS</b>	<b>TOTAL LBS.</b>	<b>TONS/HR.</b>
06/14/2000	16	108	53572	1.674
06/15/2000	8	6	2976	0.186

# **RAD Process Area**

## **RAD PROCESS AREA REPORT SUMMARY**

### **Ammonia Packed Bed Scrubber (AF-002)**

As required by 5.B.14, weekly maintenance checks were performed on the Ammonia Packed Bed Scrubber (AF-002). No problems were noted during the weekly operator visual inspections. The water filter was changed and the spray nozzle cleaned on 1/11/00 and 4/22/00.

### **EO Packed Bed Scrubber (AF-004)**

As required by 5.B.14, weekly maintenance checks were performed on the EO Packed Bed Scrubber (AF-004). Several minor repairs were made to the scrubber between 1/12/00 and 2/9/00. More minor repairs were made to the scrubber on 5/9/00.



# **Neuphor Process Area**

## **NEUPHOR PROCESS AREA REPORT SUMMARY**

### **Adduct Reactor Scrubber (AD-001)**

As required by 5.B.14, weekly operator maintenance checks were performed on the Adduct Reactor Scrubber (AD-001). No problems were noted during the weekly operator visual inspections.

Hercules Incorporated began a more thorough inspection of the Adduct Reactor Carbon Adsorption Scrubber on 3/17/00, which included a mechanic opening the scrubber drawers on a weekly basis and performing a visual inspection of the carbon bed. The carbon was changed on 6/19/00. The mechanic inspection of the scrubber was not recorded on the weeks of 4/17 and 5/15/00.

### **Dresinol Water Eductor (AD-002)**

As required by 5.B.14, weekly operator maintenance checks were performed on the Dresinol Water Eductor (AD-002). No problems were noted during the weekly operator visual inspections.

# **Kymene LDAR Monitoring**

**7. Number of affected *connectors* in HAP service for which leaks were detected as described in § 63.174(a), the percent leaking, and the total number monitored:**

- 1 affected connector was discovered leaking during the referenced reporting period (>500 ppm, monitored at 608 ppm);
- 0.30% of total affected connectors were leaking; and
- 334 total affected connectors are in the Kymene process.

**8. Number of *connectors* for which leaks were not repaired per § 63.174(d), identifying the number of those that are determined non-repairable:**

- The connector leak was repaired in accordance with § 63.174(d); and
- No leaks were determined non-repairable.

**9. Explain any *delay of repairs*:**

- All applicable repairs were made in a timely fashion.

**10. *Monitoring results* recorded during the semi-annual reporting period:**

- Summary results are attached from the referenced semi-annual reporting period for the Kymene process.

# PERIODIC LEAK MONITORING REPORT

January 1, 2000 through June 30, 2000

Hercules Incorporated  
Hattiesburg, Mississippi

## KYMENE PROCESS AREA (AA-000)

1. **Number of affected *valves* in HAP service for which leaks were detected as described in § 63.168(b), the percent leakers, and the total number monitored:**
  - No affected valves were discovered leaking during the referenced reporting period (>500 ppm);
  - 0.00% of total affected valves were leaking; and
  - 61 total affected valves are in the Kymene process.
2. **Number of *valves* for which leaks were not repaired per § 63.168(f), identifying the number of those that are determined non-repairable:**
  - No affected valves were discovered leaking.
3. **Number of affected *pumps* in HAP service for which leaks were detected as described in § 63.163(b), the percent leakers, and the total number monitored:**
  - No affected pumps were discovered leaking during the referenced reporting period (>5,000 ppm or visible leak);
  - 0.00% of total affected pumps were leaking; and
  - 3 total affected pumps are in the Kymene process.
4. **Number of *pumps* for which leaks were not repaired per § 63.163(c):**
  - No affected pumps were discovered leaking.
5. **Number of affected *agitators* in HAP service for which leaks were detected as described in § 63.173(a) & (b):**
  - No affected agitators were discovered leaking during the referenced reporting period (>10,000 ppm or visible leak);
  - 0.00% of total affected agitators were leaking; and
  - 1 affected agitator is in the Kymene process.
6. **Number of *agitators* for which leaks were not repaired per § 63.173(c):**
  - No affected agitators were discovered leaking.

## **KYMENE LDAR MONITORING**

In Accordance with 40 CFR 63, Subpart W, Subpart H, and Permit Conditions 5.B.1, 5.B.2, 5.B.3, 5.B.4, and 5.C.1, Hercules Incorporated has provided in Attachment A the following required information:

- Report required by 40 CFR 63.182(d)(2);
- Summary report of actual monitoring data; and
- Recordkeeping and reporting of Startup, Shutdown, and Malfunctions per SSM Plan.
  - Form A: SSM Plan Conformance
  - Form B: Nonconformance to SSM Plan

No problems or deviations were noted during the weekly visual inspections.

During the annual and monthly Kymene LDAR monitoring required by 5.B.3(b) [ref.: 40 CFR 63.180(b)] and conducted on January 28, February 3, and March 2, 2000, the monitoring device was only calibrated using 0, 500, 1000, 2000, and 10,000 ppm methane gas. Since three (3) Phase II pumps were checked for leaks on each occasion, the monitoring equipment should have also been calibrated using a 5,000 ppm methane gas. This error is reported as a deviation from a permitted requirement in this submittal.

# **ATTACHMENT A**

**Results of Leak Monitoring  
KYMENE PROCESS  
January 1, 2000 through June 30, 2000**

**SEMIANNUAL REPORT WORKSHEET**

**UNIT: KYMENE**

**REPORTING PERIOD: 1/1/2000 - 6/30/2000**

Specify Month ----->	MONTH 1 JAN	MONTH 2 FEB	MONTH 3 MARCH	MONTH 4 APRIL	MONTH 5 MAY	MONTH 6 JUNE
Total valves monitored**	58	2	3	1	1	56
Number valves leaking	0	0	0	0	0	0
Number valves not repaired in 15 days	0	0	0	0	0	0
Total PRV monitored	1	0	0	0	0	5
Number PRV's leaking	0	0	0	0	0	0
Number PRV's not repaired in 15 days	0	0	0	0	0	0
Total agitator monitored	1	1	1	1	1	1
Number agitators leaking	0	0	0	0	0	0
Number agitators not repaired in 15 days	0	0	0	0	0	0
Total pump monitored	3	3	3	3	3	3
Number pumps leaking	0	0	0	0	0	0
Number pumps not repaired in 15 days	0	0	0	0	0	0
Total compressor monitored	0	0	0	0	0	0
Number compressors leaking	0	0	0	0	0	0
Number compressors not repaired in 15 days	0	0	0	0	0	0
Total connector monitored	332	5	10	10	10	0
Number connectors leaking	1	0	0	0	0	0
Number connectors not repaired in 15 days	0	0	0	0	0	0
Number components on DOR	0	0	0	0	0	0

\* - Only one regulation per worksheet unless otherwise instructed by client.

\*\* - Total count of valves monitored includes light monitoring unless otherwise instructed by client.



### Startup, Shutdown, and Malfunction Plan Checklist - Form A

Date	Startup, Shutdown, Malfunction Plan Properly Followed?		Kymene Scrubber gpm	Was Form B Completed?		Was there a Malfunction?		Action Taken for - Section 6.2,6.3,6.4
	Yes	No		Yes	No	Yes	No	
3/4/00	✓		12		✓		✓	Flow restriction
3/5/00	✓		12		✓		✓	Flow restriction - fine in pipe Open FPI line and run along spout in R-Hall leaking water line on scrubber water line. Repaired.
3/13/00	✓				✓		✓	Mix Cooler Leaking Repaired by Tighting.
3/13/00	✓		13.32		✓		✓	Mix Cooler Leaking again. Repaired + replaced
4/12/00	✓		13.00		✓		✓	
4/12/00	✓		12.60		✓		✓	Mix Cooler Leaking Open FPI line and run along spout in R-Hall
4/17/00	✓		13.45		✓		✓	
5/12/00	✓				✓		✓	

Startup, Shutdown, and Malfunction Plan Checklist - Form A

Date	Startup, Shutdown, Malfunction Plan Property Followed?		Kymene Scrubber gpm	Was Form B Completed?		Was there a Malfunction?		Action Taken for - Section 6.2,6.3,6.4
	Yes	No		Yes	No	Yes	No	
1/29/99	X		10	X		X		Mix Cooler plugged due to power failure. Cooler required to power failure. Cooler leaking. Line above Epi pump leaking. (LDPE) inspection, replace GPC Pin Hole, leak on Schrader Valve, Line repaired.
4/25/99	X		10	X		X		NO STRENGTH > GF Shut down to repair Mix Cooler. Repaired & R.
9/27/99	✓		16.4	✓		✓		Repaired Made to Mix Cooler
9/14/99	✓		16.7	✓		✓		open & Epi Line & unplugged - Repair
10/1/99	-		12.21	✓		✓		No malfunction (S.S.) tighten up on 10/1 on auto valve (0097)
10/6/99	-		12.23	✓		✓		Manual Valve (0085) snuffed with oil & snuffer TRR
10/11/99	-		12.25	✓		✓		
<del>10/19/99</del>			<del>18.30</del>					
11/24/99	✓		13.26	X		X		
								NOTE: BOTH LEAKS WERE BELOW LEAKS LIMIT. REQ'D FOR OFFICER REPORTING. HOWEVER, I MADE DECISION TO REPAIR BOTH. GFS 12/13/99
								"CALIBRATED SNITCH" REFERRED TO WAS NOT AN LIAR INST
								AND WAS ONLY USED FOR GROSS DETERMINATION.
03/24/2000	-		0.0	X		X		GFS 12/13/99 Water Valve Was Working going to service. Both Leaking, when they went down the process. It has been replaced.
2/12/2000	✓		14	✓		✓		Repair Leak Valve @ A Valve. The station - Able to Empty K110.

# **RAD LDAR Monitoring**

## **RAD LDAR MONITORING**

In Accordance with 40 CFR 63, Subpart PPP, Subpart H, and future Permit Conditions, Hercules Incorporated has provided in Attachment B the following required information:

- Report required by 40 CFR 63.182(d)(2);
- Summary report of actual monitoring data; and
- Recordkeeping and reporting of Startup, Shutdown, and Malfunctions per SSM Plan.
  - Form A: SSM Plan Conformance
  - Form B: Nonconformance to SSM Plan

No problems or deviations were noted during the monthly RAD LDAR monitoring required by 40 CFR 63.1434(a) and 63.180(b).

The RAD LDAR visual inspection was not performed on April 3, 2000. This was reported to MDEQ as a deviation by certified letter dated April 7, 2000, because the Hercules Startup, Shutdown, and Malfunction Plan requested daily inspections. This procedure has since been revised to coincide with the weekly visual inspections required by 40 CFR 63, Subpart H (ref.: 63.163(b)(3)).

# **ATTACHMENT B**

**Results of Leak Monitoring  
POLYRAD PROCESS  
January 1, 2000 through June 30, 2000**

# PERIODIC LEAK MONITORING REPORT

January 1, 2000 through June 30, 2000

Hercules Incorporated  
Hattiesburg, Mississippi

## POLYRAD PROCESS AREA (AF-000)

1. **Number of affected *valves* in HAP service for which leaks were detected as described in § 63.168(b), the percent leakers, and the total number monitored:**
  - No affected valves were discovered leaking during the referenced reporting period (>10,000 ppm);
  - 0.00% of total affected valves were leaking; and
  - 103 total affected valves are in the PolyRAD process.
  
2. **Number of *valves* for which leaks were not repaired per § 63.168(f), identifying the number of those that are determined non-repairable:**
  - No affected valves were discovered leaking.
  
3. **Number of affected *pressure relief valves* in HAP service for which leaks were detected as described in § 63.168(b), the percent leakers, and the total number monitored:**
  - No affected valves were discovered leaking during the referenced reporting period (>500 ppm);
  - 0.00% of total affected valves were leaking; and
  - 19 total affected valves are in the PolyRAD process.
  
4. **Number of *pressure relief valves* for which leaks were not repaired per § 63.168(f), identifying the number of those that are determined non-repairable:**
  - No affected valves were discovered leaking.
  
5. **Number of affected *pumps* in HAP service for which leaks were detected as described in § 63.163(b), the percent leakers, and the total number monitored:**
  - No affected pumps were discovered leaking during the referenced reporting period (>10,000 ppm or visible leak);
  - 0.00% of total affected pumps were leaking; and
  - 3 total affected pumps are in the PolyRAD process.

**6. Number of *pumps* for which leaks were not repaired per § 63.163(c):**

- No affected pumps were discovered leaking.

**7. Number of affected *connectors* in HAP service for which leaks were detected as described in § 63.174(a), the percent leaking, and the total number monitored:**

- No affected connectors were discovered leaking during the referenced reporting period (>500 ppm);
- 0.00% of total affected connectors were leaking; and
- 752 total affected connectors are in the PolyRAD process.

**8. Number of *connectors* for which leaks were not repaired per § 63.174(d), identifying the number of those that are determined non-repairable:**

- No affected connectors were discovered leaking.

**9. Explain any *delay of repairs*:**

- All applicable repairs were made in a timely fashion.

**10. *Monitoring results* recorded during the semi-annual reporting period:**

- Summary results are attached from the referenced semi-annual reporting period for the PolyRAD process.



**SEMIANNUAL REPORT WORKSHEET**

**UNIT: RAD**

**REPORTING PERIOD: 1/1/2000 - 6/30/2000**

Specify Month ----->	MONTH 1 JAN	MONTH 2 FEB	MONTH 3 MARCH	MONTH 4 APRIL	MONTH 5 MAY	MONTH 6 JUNE
Total valves monitored**	0	8	93	0	0	107
Number valves leaking	0	0	0	0	0	0
Number valves not repaired in 15 days	0	0	0	0	0	0
Total PRV monitored	0	18	1	0	0	14
Number PRV's leaking	0	0	0	0	0	0
Number PRV's not repaired in 15 days	0	0	0	0	0	0
Total agitator monitored	0	0	0	0	0	0
Number agitators leaking	0	0	0	0	0	0
Number agitators not repaired in 15 days	0	0	0	0	0	0
Total pump monitored	3	3	3	3	3	3
Number pumps leaking	0	0	0	0	0	0
Number pumps not repaired in 15 days	0	0	0	0	0	0
Total compressor monitored	0	0	0	0	0	0
Number compressors leaking	0	0	0	0	0	0
Number compressors not repaired in 15 days	0	0	0	0	0	0
Total connector monitored	0	53	0	0	0	0
Number connectors leaking	0	0	0	0	0	0
Number connectors not repaired in 15 days	0	0	0	0	0	0
Number components on DOR	0	0	0	0	0	0

\* - Only one regulation per worksheet unless otherwise instructed by client.

\*\* - Total count of valves monitored includes light monitoring unless otherwise instructed by client.





**Startup, Shutdown, and Malfunction Plan Checklist - Form A**  
**--PolyRAD/Surfactant Unit--**

Date	Startup, Shutdown, Malfunction Plan Properly Followed?		Was Form B Completed?		Was there a Malfunction?		Action Taken for - Section 6.2, 6.3, 6.4
	Yes	No: See Fm. B	Yes	No	Yes	No	
1-30-00	✓		✓			✓	Shut down Polyrad unit at 4:15 PM
1-30-2000	✓		✓		✓		Shut down E.O. Surfactant 3:15 PM
1-30-2000	✓		✓		✓	<sup>Fmt</sup>	Started up E.O. Surfactant at 9:30 PM
1-31-00	✓		✓		✓		At 2 AM started up Polyrad unit, reculture OK
2-1-00	✓		✓		✓		Shut down. Her down at 12:00 (H <sub>2</sub> O Leaks)
2-1-2000	✓		✓		✓		at 6 PM started up E.O. Surfactant morning OK
2-3-00	✓		✓		✓		Shut down E.O. Surfactant at 11:30 PM 720 E.O. Working
2-8-00	✓		✓		✓		Started E.O. Surfactant at 11:00 PM. At 1:50 PM 12:00 Shut down Polyrad unit
2-9-00	✓		✓		✓		Shut down E.O. Surfactant unit at 11:30 PM
2-9-00	✓		✓		✓		Started up E.O. Surfactant at 6:55 PM, RR: 1:50 at 7:15
2-12-00	✓		✓		✓		Shut down E.O. Surfactant and Polyrad unit at 5:00 PM, 7:00 PM
3-1-00	✓		✓		✓		Started up E.O. Surfactant, reculture TR E.O.
3-1-00	✓		✓		✓		Shut E.O. Surfactant down.
4-3-00	✓		✓		✓		Visual inspection not performed. (1) State verbally informed on 4-5-00 (2) Follow-up letter sent to state on 4-7-00

Next Page

**Startup, Shutdown, and Malfunction Plan Checklist - Form A**  
**--POLYRAD/Surfactant Unit--**

Date	Startup, Shutdown, Malfunction Plan Properly Followed?		Was Form B Completed?		Was there a Malfunction?		Action Taken for - Section 6.2, 6.3, 6.4
	Yes	No: See Fm. B	Yes	No	Yes	No	
1-19-00	✓			✓		✓	Started up the E.O. Scrubber during shift (7-3 shift)
1-19-00	✓			✓		✓	Started up the Polyrad unit (7-3 & 3-11 shift)
1-19-00	✓			✓	✓	✓	Shut down scrubber and Polyrad, (11-7 shift)
1-19-00	✓			✓		✓	See log page 112 11-7 shift.
1-20-00	✓			✓		✓	Started scrubber, see log page 112 (11-7 shift)
1-20-00	✓			✓		✓	Bleaching ethylene chloride to scrubber, see log page 113 (1-3 & 3-11 shifts)
1-20-00	✓			✓	✓	✓	Scrubber down, see log page 113 (3-11 shift)
1-21-00	✓			✓		✓	Started up scrubber, see log page 115 (3-11 shift)
1-21-00	✓			✓		✓	Started up the Polyrad unit (11-7 shift)
1-23-00	✓			✓	✓	✓	Scrubber and Polyrad down see log page 118 (7-3 shift)
1-26-00	✓			✓		✓	Scrubber polyrad down
1-27-00	✓			✓		✓	Scrubber Polyrad down
1-28-00	✓			✓		✓	Started E.O. scrubber back up.
1-28-00	✓			✓	✓	✓	Shut down E.O. Scrubber (no acid) on 3-11 shift. (8 shift)
1-29-00	✓			✓		✓	Started E.O. scrubber back up.



# **Deviations from Permit Requirements**



# **DEVIATIONS FROM PERMIT REQUIREMENTS**

**January 1, 2000 through June 30, 2000**

**Hercules Incorporated  
Hattiesburg, Mississippi**

As required by 5.A.4 of the Title V Operating Permit, deviations from permit requirements must be clearly identified and reported. The deviations from any emission point or process specific monitoring required in the permit are detailed below:

1. During the annual and monthly Kymene Process LDAR monitoring required by 5.B.3(b) [ref.: 40 CFR 63.180(b)] and conducted on January 28, February 3, and March 2, 2000, the monitoring device was only calibrated using 0, 500, 1000, 2000, and 10,000 ppm methane gas. Since three (3) Phase II pumps were checked for leaks on each occasion, the monitoring equipment should have also been calibrated using a 5,000 ppm methane gas.
2. The Kymene Process Area (AA-001 and AA-002) weekly maintenance check required by 5.B.14 was not recorded on the week of January 3, 2000.
3. The RAD LDAR visual inspection was not performed on April 3, 2000. This was reported to MDEQ as a deviation by certified letter dated April 7, 2000, because the Hercules Startup, Shutdown, and Malfunction Plan requested daily inspections. This procedure has since been revised to coincide with the weekly visual inspections required by 40 CFR 63, Subpart H (ref.: 63.163(b)(3)).

**HERCULES**

0800-00001  
Forrest

**Hercules Incorporated**  
613 West 7th Street  
P.O. Box 1937  
Hattiesburg, MS 39403-1937  
(601) 545-3450  
FAX: (601) 584-3226  
<http://www.herc.com>

July 23, 1999

Earl Mahaffey  
Environmental Compliance and Enforcement Division  
Office of Pollution Control  
101 West Capitol Street  
Jackson, MS 39201



RE: Hercules Incorporated – Permit # 0800-00001  
Semi-Annual Reporting

Dear Mr. Mahaffey:

As required by Title V Conditions 5.A.4.(ref: APC-S-6, Section III. A. 3.c. (1)), and 5.C.1, (b), 40CFR 63.182, (ref: 40CFR 63.528(b)), and conditions 5.B.6, 5.B.7, 5.B.8, 5.B.11, and 5.B.13, attached is the required monitoring data for the period ending June 30, 1999. As Responsible Official for Hercules Incorporated, I certify that based on information and belief formed after reasonable inquiry, the statements and information in the attached document are true, accurate, and complete.

Please contact Mr. Charles Jordan at (601) 584-3360 should you have any questions or need any further information.

Sincerely,  
HERCULES INCORPORATED

Walter D. Langhans  
Plant Manager

WDL/vrf

Attachment:

Cc: ✓ Scott Hodges – Bureau of Pollution Control  
Evan Tullos – ECO Systems

MONITORING, RECORDKEEPING & REPORTING REQUIREMENT 5.A.4

YEAR	EMISSION POINT	DESCRIPTION	GAS USAGE - MCF														
			JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	OCT	NOV	DEC			
1999	AC001	Poly-pale nat. gas Dowtherm boiler	2042	0	1560	1200	3240	1320									
	AF001	RAD nat. gas Dowtherm boiler	360	2661	0	0	0	1800									
	AG001	HRA nat. gas Dowtherm boiler	1332	1235	3040	9110	8260	1368									
	AG002	HRA nat. gas Dowtherm boiler	0	0	0	0	0	0									
	AJ001	Rosin dist. nat. gas Dowtherm boiler	948	133	2230	4790	7440	297									
	AK001	Hydrogen nat. gas Dowtherm boiler	0	0	0	0	0	0									
	AL001	Silica nat. gas Dowtherm boiler	0	0	0	0	0	0									
	AM001	No. 5 package boiler	38437	43307	43392	34194	31661	29911									
	AM002	No. 6 package boiler	0	0	0	0	0	0									
	AN001	Reg. furnace nat. gas boiler	1300	1200	2200	1100	2000	0									

T5ngas



Koch Gateway Pipeline Company  
 DETAIL METER STATEMENT  
 FOR THE MONTH OF 06/99

07/08/99 19:17:54  
 PAGE 4

METER ID: 002520-01  
 LOCATION: HATTIESBURG CITY GATE #1  
 TYPE METER: EFM Orifice

SYSTEM: 007:Mississippi  
 SUBSYSTEM: 014:Jackson to Leaksville 16" & 8"  
 PURPOSE: Koch Custody Delivery

CONTRACT TIME: 09:00  
 ANALYST: Matthews, Lloja  
 PHONE #: 5044695903

----- METER INFORMATION -----										
EFFECTIVE DATE	REF NUM	STATIC RANGE	DIFF RANGE	TUBE SIZE	PLATE SIZE	TAP TYPE	TAP LOCA	CHART DAYS	MACHINE CONSTANT	CALC TYPE
06/01/99	1	500	100	8.072	3.250	P	U	1	1.0000	14

----- VOLUME INFORMATION -----											
DAY ON	DAY OFF	REF NUM	FLOW EXTENT	FLOW HOURS	TEMP	PRES PSIA	DIFF	SPEC GRAV	MCF VOLUME @ 14.730	BTU(A)	Dth
1	2	1	18	24.0	61.9	112.5	2.9	0.6017	1323	1016.3000	1345
2	3	2	17	24.0	63.1	112.8	2.6	0.6017	1260	1016.3000	1281
3	4	3	17	24.0	63.7	112.8	2.7	0.6017	1275	1016.3000	1296
4	5	4	16	24.0	64.8	112.9	2.3	0.6017	1164	1016.3000	1183
5	6	5	15	24.0	65.2	112.9	2.0	0.6017	1101	1016.3000	1119
6	7	6	16	24.0	63.6	112.7	2.4	0.6017	1216	1016.3000	1236
7	8	7	18	24.0	62.8	112.7	3.0	0.6017	1347	1016.3000	1369
8	9	8	18	24.0	62.5	112.4	3.0	0.6017	1349	1016.3000	1371
9	10	9	18	24.0	63.9	112.4	3.1	0.6017	1366	1016.3000	1388
10	11	10	19	24.0	63.3	112.4	3.3	0.6017	1408	1016.3000	1431
11	12	11	18	24.0	62.1	112.4	3.1	0.6017	1374	1016.3000	1396
12	13	12	17	24.0	63.1	112.5	2.7	0.6017	1282	1016.3000	1303
13	14	13	17	24.0	63.4	112.4	2.8	0.6017	1295	1016.3000	1316
14	15	14	19	24.0	63.6	112.4	3.3	0.6017	1413	1016.3000	1436
15	16	15	19	24.0	62.4	112.3	3.4	0.6017	1430	1016.3000	1453
16	17	16	19	24.0	62.2	112.2	3.5	0.6017	1451	1016.3000	1475
17	18	17	20	24.0	61.5	112.3	3.8	0.6017	1522	1016.3000	1547
18	19	18	20	24.0	60.6	112.3	3.5	0.6017	1472	1016.3000	1496
19	20	19	18	24.0	61.7	112.3	2.9	0.6017	1332	1016.3000	1364
20	21	20	18	24.0	62.3	112.4	2.9	0.6017	1313	1016.3000	1334
21	22	21	19	24.0	65.1	112.4	3.2	0.6017	1403	1016.3000	1426
22	23	22	20	24.0	64.2	112.2	3.6	0.6017	1469	1016.3000	1493
23	24	23	19	24.0	65.5	112.3	3.1	0.6017	1384	1016.3000	1407
24	25	24	18	24.0	66.5	112.3	3.0	0.6017	1338	1016.3000	1360
25	26	25	18	24.0	65.0	112.2	3.1	0.6017	1370	1016.3000	1392
26	27	26	17	24.0	65.8	112.2	2.8	0.6017	1302	1016.3000	1323
27	28	27	16	24.0	68.6	112.4	2.3	0.6017	1169	1016.3000	1188
28	29	28	17	24.0	69.3	112.2	2.7	0.6017	1255	1016.3000	1275
29	30	29	17	24.0	67.7	112.2	3.0	0.6017	1266	1016.3000	1287
30	1	30	15	24.0	69.3	112.4	2.2	0.6017	1132	1016.3000	1150
Total									39781	40430	

----- GAS QUALITY INFORMATION -----													
EFFECTIVE DATE	SAMPLE TYPE	WATER CONTENT	N2	CO2	H2S	C1	C2	C3	IC4	NC4	IC5	NC5	CG+
06/01/99	C	9.6	1.1550	2.0400	0.0000	94.7810	1.0770	0.3020	0.0940	0.1240	0.0630	0.0700	0.2940

**EMISSION POINT AC-004 (MELTER)****Report Period:  
Jan.- June, 1999****Note: No activity on those dates not shown.**

<b>DATE</b>	<b># HOURS</b>	<b># DRUMS</b>	<b>TOTAL LBS.</b>	<b>TONS/HR.</b>
12/29/98	16	87	43155	1.349
1/5/99	8	42	20833	1.302
1/6/99	16	130	64485	2.015
1/7/99	16	120	59524	1.860
1/8/99	16	116	57540	1.798
1/9/99	16	100	49604	1.550
1/11/99	16	112	55556	1.736
1/12/99	16	58	28770	0.899
1/13/99	16	93	46131	1.442
1/14/99	16	80	39683	1.240
1/19/99	8	40	19841	1.240
1/20/99	8	30	14881	0.930
1/22/99	8	50	24802	1.550
3/16/99	16	102	50596	1.581
3/17/99	16	125	62004	1.938
3/18/99	16	120	59524	1.860
3/19/99	16	120	59524	1.860
3/20/99	16	120	59524	1.860

**EMISSION POINT AC-004 (MELTER)****Report Period:  
Jan.- June, 1999****Note: No activity on those dates not shown.**

<b>DATE</b>	<b># HOURS</b>	<b># DRUMS</b>	<b>TOTAL LBS.</b>	<b>TONS/HR.</b>
3/21/99	16	100	49604	1.550
3/23/99	16	122	60516	1.891
3/24/99	8	40	19841	1.240
3/25/99	16	120	59524	1.860
3/27/99	16	100	49604	1.550
3/28/99	8	30	14881	0.930
3/29/99	16	66	32738	1.023
3/31/99	16	50	24802	0.775
4/1/99	16	94	46627	1.457
4/2/99	16	100	49604	1.550
4/3/99	16	102	50596	1.581
4/5/99	8	32	15873	0.992
4/6/99	8	60	29762	1.860
4/7/99	16	120	59524	1.860
4/8/99	16	120	59524	1.860
4/9/99	16	120	59524	1.860
4/10/99	16	89	44147	1.380

**EMISSION POINT AC-004 (MELTER)**

**Report Period:  
Jan.- June, 1999**

**Note: No activity on those dates not shown.**

<b>DATE</b>	<b># HOURS</b>	<b># DRUMS</b>	<b>TOTAL LBS.</b>	<b>TONS/HR.</b>
4/11/99	16	104	51588	1.612
4/12/99	16	96	47619	1.488
4/17/99	16	90	44643	1.395
4/26/99	16	124	61508	1.922
4/28/99	8	40	19841	1.240
5/3/99	8	60	29762	1.860
5/4/99	16	80	39683	1.240
5/5/99	16	98	48611	1.519
5/6/99	16	110	54564	1.705
5/7/99	16	120	59524	1.860
5/8/99	16	120	59524	1.860
5/9/99	16	120	59524	1.860
5/10/99	16	120	59524	1.860
5/11/99	16	120	59524	1.860
5/12/99	16	124	61508	1.922
5/13/99	16	100	49604	1.550
5/14/99	16	70	34722	1.085



Emission Point - AA002

Adipic Acid Handling System Equipment with a Dust Shaker

Date (M-D-Y)	Adipic Acid Addition Time minutes	Adipic Acid Total Charge boxes	Adipic Acid Total Charge pounds	Adipic Acid Total Charge ton/hr	Comments
12/31/98	180	16	23900	4.0	
12/31/98	90	8	11966	4.0	
1/2/99	90	8	11960	4.0	
1/4/99	180	16	23920	4.0	
1/5/99	90	8	11960	4.0	
1/6/99	90	8	11960	4.0	
1/7/99	180	16	23920	4.0	
1/8/99	90	8	11960	4.0	
1/9/99	90	8	11960	4.0	
1/10/99	90	8	11960	4.0	
1/12/99	90	8	11960	4.0	
1/13/99	90	8	11960	4.0	
1/15/99	180	16	23920	4.0	
1/17/99	90	8	11960	4.0	
1/18/99	90	8	11960	4.0	
1/19/99	90	8	11960	4.0	
1/21/99	90	8	11960	4.0	
1/23/99	180	16	23920	4.0	
1/24/99	180	16	23920	4.0	
1/25/99	90	8	11960	4.0	
1/26/99	90	8	11960	4.0	
1/28/99	90	8	11960	4.0	



Emission Point - AA002

Adipic Acid Handling System Equipment with a Dust Shaker

Date (M-D-Y)	Adipic Acid Addition Time minutes	Adipic Acid Total Charge boxes	Adipic Acid Total Charge pounds	Adipic Acid Total Charge ton/hr	Comments
1/29/99	90	8	11960	4.0	
1/31/99	180	16	23920	4.0	
2/1/99	90	8	11960	4.0	
2/2/99	90	8	11960	4.0	
2/3/99	90	8	11960	4.0	
2/4/99	90	8	11960	4.0	
2/5/99	90	8	11960	4.0	
2/7/99	180	16	23920	4.0	
2/9/99	90	8	11960	4.0	
2/10/99	90	8	11960	4.0	
2/11/99	90	8	11960	4.0	
2/12/99	90	8	11960	4.0	
2/13/99	90	8	11960	4.0	
2/14/99	180	16	23920	4.0	
2/16/99	90	8	11960	4.0	
2/17/99	90	8	11960	4.0	
2/18/99	90	8	11960	4.0	
2/19/99	90	8	11960	4.0	
2/20/99	90	8	11960	4.0	
2/22/99	90	8	11960	4.0	
2/23/99	90	8	11960	4.0	
2/24/99	90	8	11960	4.0	
2/25/99	90	8	11960	4.0	
2/26/99	90	8	11960	4.0	
2/27/99	90	8	11960	4.0	
2/28/99	180	16	23920	4.0	

Emission Point - AA002

Adipic Acid Handling System Equipment with a Dust Shaker

Date (M-D-Y)	Adipic Acid Addition Time minutes	Adipic Acid Total Charge boxes	Adipic Acid Total Charge pounds	Adipic Acid Total Charge ton/hr	Comments
3/1/99	90	8	11960	4.0	
3/2/99	90	8	11960	4.0	
3/3/99	90	8	11960	4.0	
3/4/99	90	8	11960	4.0	
3/6/99	90	8	11960	4.0	
3/7/99	180	16	23920	4.0	
3/8/99	90	8	11920	4.0	
3/9/99	90	8	11960	4.0	
3/11/99	90	8	11960	4.0	
3/12/99	90	8	11960	4.0	
3/15/99	180	16	23920	4.0	
3/16/99	90	8	11960	4.0	
3/17/99	90	8	11960	4.0	
3/18/99	180	16	23920	4.0	
3/19/99	90	8	11960	4.0	
3/20/99	90	8	11960	4.0	
3/25/99	90	8	11960	4.0	
3/26/99	180	16	23920	4.0	
3/28/99	90	8	11960	4.0	







Emission Point - AA002

Adipic Acid Handling System Equipment with a Dust Shaker

*Every Batch*

Date (M-D-Y)	Adipic Acid Addition Time minutes	Adipic Acid Total Charge boxes	Adipic Acid Total Charge pounds	Adipic Acid Total Charge ton/hr	Comments
5/28/99	90	8	11960	4.6	
5/29/99	180	16	23920	4.0	
5/30/99	180	16	23920	4.0	
5/31/99	90	8	11960	4.6	
6/4/99	90	8	11960	4.0	
6/7/99	180	16	23920	4.0	
6/8/99	90	8	11960	4.6	
6/9/99	90	8	11960	4.6	
6/10/99	180	16	23920	4.0	
6/12/99	90	8	11960	4.6	
6/13/99	90	8	11960	4.0	
6/17/99	90	8	11960	4.0	
6/20/99	90	8	11960	4.0	
6/21/99	90	8	11960	4.0	
6/21/99	90	8	11960	4.0	
6/23/99	90	8	11960	4.0	
6/26/99	90	8	11960	4.0	
6-27-99	90	8	11960	4.0	
6-28-99	90	8	11960	4.0	
6-30-99	90	8	11960	4.0	
7-1-99	90	8	11960	4.0	
7-5-99	90	8	11960	4.0	
7-6-99	90	8	11960	4.0	
7-6-99	90	8	11960	4.0	
7/7/99	90	8	11960	4.0	
7/14/99	90	8	11960	4.0	
7/15/99	90	8	11960	4.0	
7/16/99	90	8	11960	4.0	
7/18/99	90	8	11960	4.0	
7/20/99	90	8	11960	4.0	

**Emission Point - AL002**  
**Defoamer Process Silica Furnance Dust Collector**

Date (M-D-Y)	Silica Addition Time minutes	Silica Total Charge bages	Silica Total Charge pounds	Silica Total Charge ton/hr	Comments
12/31/98					NO Operation of silica drying process in December 1998
1/31/99					NO operation of silica dryer process in January 1999
2/28/99					No operation of silica dryer process in the month of February 1999
3/31/99					no operation of silica dryer process in the month of March 1999
4/26/99					no operation of silica dryer process in the month of April 1999
5/24/99					No operation of the silica dryer process in the month of May 1999
6/27/99					No operation of the silica dryer process in the month of June 1999. See operator log sheet data 6/99. Subsequent to 6/99.



**PERIODIC LEAK  
MONITORING REPORT  
January, 1999 To June, 1999**

**KYMENE PROCESS**

for

**HERCULES, INCORPORATED  
CHEMICAL SPECIALTIES  
Hattiesburg, Mississippi**

Forrest County

*prepared by:*

**ECO-SYSTEMS, INC.  
ENVIRONMENTAL ENGINEERS AND SCIENTISTS  
Jackson, Mississippi**

**June, 1999**

**PERIODIC LEAK MONITORING REPORT - KYMENE PROCESS**  
**For Compliance Period - January, 1999 through June, 1999**

Hercules, Incorporated  
Hattiesburg, Mississippi

1. ***Number of affected valves for which leaks were detected; percent leakers; total number of valves:***
  - No affected valves were discovered leaking during compliance period (greater than 500 ppm and/or a visible leak);
  - 0.00% of total affected valves were leaking;
  - 60 total affected valves are in the Kymene process.
  
2. ***Number of valves which were not repaired during this period:***
  - No affected valves were discovered leaking.
  
3. ***Number of pumps for which leaks were detected; percent leakers; total number of pumps:***
  - No affected pumps were discovered leaking during the compliance period (greater than 5,000 ppm or a visible leak);
  - 0.00% of affected pumps were leaking;
  - 3 total affected pumps are in the Kymene process.
  
4. ***Number of pumps which were not repaired during this period:***
  - No affected pumps were discovered leaking during this compliance period.
  
5. ***Number of agitators for which leaks were detected; percent leakers; total number of agitators:***
  - No affected agitators were discovered leaking during compliance period (greater than 10,000 ppm or a visible leak);
  - 0.00% of affected agitators were leaking;
  - 1 total affected agitator is in the Kymene process.
  
6. ***Number of agitators which were not repaired during this period:***
  - No affected agitators required repair.

7. ***Number of connectors (flanges, screwed fittings and others) for which leaks were detected; percent leakers; total number of connectors:***
  - 1 affected connector (flange) was discovered leaking during compliance period (greater than 500 ppm);
  - 0.33% of total affected connectors were leaking;
  - 302 total affected connectors are in the Kymene process.
  
8. ***Number of connectors which were not repaired during this period:***
  - Leaking connector was successfully repaired.
  
9. ***Provide explanation of any repairs that were unable to be made:***
  - Repairs of all affected leaking components were successful.
  
10. ***Provide results of all monitoring conducted during compliance period:***
  - All results for the specified reporting period may be found in Attachment A to this report.



## **ATTACHMENT A**

**Results Of Leak Monitoring  
Kymene Process  
January, 1999 - June, 1999**



**FUGITIVE EMISSIONS SCREENING REPORT  
FOR LEAK DETECTION AND REPAIR (LDAR) PROGRAM**

**prepared for**

**Hercules, Inc.  
Specialty Chemicals  
Hattiesburg, Mississippi**

**prepared by**

***Eco-Systems, Inc.*  
Environmental Engineers and Scientists**

**Jackson, MS · Little Rock, AR · Houston, TX**

**January, 1999**

## **1.0 INTRODUCTION**

---

Hercules, Inc.(Hercules) owns and operates a specialty chemicals facility in Hattiesburg, Mississippi. The facility is located on West Seventh Street in Hattiesburg, Forrest County, Mississippi on approximately 200 acres of land. More specifically, the Site is located in Township 4 North, Range 13 West, within sections 4 and 5 just north of Hattiesburg, Mississippi. The facility has been in operation since 1923 and is surrounded by both industrial and residential properties.

The facility's operations consist of extraction, fractionation, refining, distillation, and processing of rosin to produce various products. Over 250 products are produced from the above-referenced operations and include: modified resins, polyamides, ketene dimer, crude tall oil wax emulsions, and synthetic rubber. Structures at the facility include offices, laboratories, powerhouses, wastewater treatment plant, settling ponds, landfills, and central loading and packaging areas.

The facility is classified as a major source as defined in section 112(a) of the Clean Air Act based on emissions of Hazardous Air Pollutants (HAPs), and is, therefore, subject to regulation under 40 CFR 63 Subpart W (National Emission Standards for Hazardous Air Pollutants for Epoxy Resins Production and Non-Nylon Polyamides Production). Specifically, Hercules stores and uses Epichlorohydrin (a HAP) in the Kymene process. Therefore, in accordance with 40 CFR 63 Subpart W, all process equipment that is in organic HAP service must be monitored for leaks and repaired as defined in Subpart W and Subpart H of 40 CFR 63.524 through 63.528 and 63.160 through 63.182. Process equipment is considered to be in organic HAP service if that equipment either contains or contacts a fluid (liquid or gas) that is at least 5 percent by weight of the designated organic HAP (i.e., Epichlorohydrin).

Hercules is utilizing the services of *Eco-Systems, Inc. (Eco-Systems)* to assist in implementing the Leak Detection and Repair (LDAR) program for the Epichlorohydrin process. *Eco-Systems*, utilizing tags previously placed on affected components, screened each applicable piece of equipment on January 14, 1999 (see Table 1). This report contains information on the scope of work, methodology, results (Section 2.0), and conclusions (Section 3.0).

## **2.0 SCOPE OF WORK, METHODOLOGY, AND RESULTS**

---

### **2.1 Leak Criteria**

Prior to initiating screening activities, *Eco-Systems* identified the “leak criteria” for each type of equipment potentially screened. At Hercules’ request, each source was screened for leaks based on Phase II criteria outlined in 40 CFR 63. In accordance with 40 CFR 63.162, sources in the Kymene process that met the following criteria were not screened:

- Equipment not in organic HAP service;
- Equipment in vacuum service; and
- Equipment that is in organic HAP service less than 300 hours per calendar year;

### **2.2 Equipment Used and Testing Methodology**

After identifying each source to be screened, Method 21 was followed to screen equipment for leaks in accordance with the regulations. A Thermo-Environmental 680 flame ionization detector (FID) was used to screen a total of 370 sources. Attachment I presents information and specifications for the FID which meets the criteria for Method 21 specified in 40 CFR 60 Appendix A and has the following specifications:

- Response time of approximately 2 seconds for 90% of final reading;
- Response factor of 2.1 for Epichlorohydrin; and
- Calibration accuracy of  $\pm 10\%$ , for a range of 1-10,000 ppm.

Prior to beginning screening activities, the FID was assembled, started and calibrated with a 10 ppmv and a 10,000 ppmv methane in air mixture. Screening of individual components were conducted in accordance with 40 CFR 60 Appendix A, Method 21, Section 4.3 Individual Source Surveys. Background readings were noted for each area and subtracted from the FID reading for each applicable source screened.

### **2.3 Monitoring Results**

Screening results along with other pertinent information are presented in Table 1. One source (a connector) was identified as leaking:

- Tag # 0022.00 - Located in the Epichlorohydrin loading area near Pump 0001.00.

The leaking source was identified with a weatherproof and readily visible tag indicating that the component was leaking and required repair. Hercules personnel were notified of the leaking component so that repair activities could be initiated.

***Hercules, Inc.  
Hattiesburg, Mississippi***



During screening activities, the presence of visual leaks (i.e., liquid visibly dripping from a connection or seal) was noted for each component. No visual leaks were identified for the components screened.

To satisfy the requirements of 40 CFR 63.162(c) and as part of this scope of work, *Eco Systems* has identified all sources subject to 40 CFR 63 and has distinguished those sources from sources that are not subject to 40 CFR 63.

*Hercules, Inc.*  
*Hattiesburg, Mississippi*



### **3.0 CONCLUSION**

---

Based on the screening results, one (1) leaking unit (a connector) was identified: component # 0022.00. During the next scheduled monitoring event (mid-February, 1999) and upon repair of the leaking component, *Eco-Systems* will perform follow-up monitoring in accordance with the regulations to confirm successful repair of the leaking unit.

**TABLE 1**  
**LDAR Screening Results**

**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0001.00	Pump	Epichlorohydrin	Truck Loading	1/14/99	9.4
0001.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0001.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0002.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0003.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0004.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0005.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	32.0
0006.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0006.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0007.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0008.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0009.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0010.01	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0010.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0010.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0011.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0012.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0013.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0014.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.04	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.05	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.06	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.07	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.08	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.09	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.10	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.11	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.12	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.13	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.14	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.15	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.16	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0016.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0017.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0018.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0019.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	20.5
0020.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0

**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0021.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.04	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0022.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	> 500.0
0023.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0024.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0025.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0025.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0025.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0025.03	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.04	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.05	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.06	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.07	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.08	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.09	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.10	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.11	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.12	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0026.00	Pump	Epichlorohydrin	Truck Loading	1/14/99	0.0
0027.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0028.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0028.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0028.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0029.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0030.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0031.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0032.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.04	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.05	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.06	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.07	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0034.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0035.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	10.7
0035.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0035.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0035.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0



**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0036.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0037.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0038.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0039.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0040.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0040.01	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0040.02	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0040.03	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0041.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0042.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0042.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0042.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0043.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0043.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0043.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0044.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.03	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.04	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.05	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.06	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0046.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0046.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0046.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.03	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.04	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.05	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.06	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.07	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.08	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0048.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0049.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0050.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0051.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0052.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0053.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0054.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0

**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0055.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0056.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0057.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0058.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0059.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0059.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0059.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0060.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0061.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0062.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0063.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0063.01	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.02	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.03	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.04	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.05	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.06	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.07	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.08	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.09	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.10	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0064.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.03	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.04	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.06	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0065.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0066.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0067.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0067.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0067.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0068.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0069.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0070.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0071.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0071.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0071.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0072.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0073.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0073.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0073.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0

**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0074.00	Valve	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0074.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0074.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0075.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0076.00	Valve	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0077.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0078.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.02	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.02	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.04	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.05	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.06	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.07	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.08	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.09	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0079.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0079.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0079.02	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0080.00	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0080.01	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0080.02	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0080.03	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0080.04	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0080.05	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0081.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0082.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0082.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0083.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0084.00	Valve	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0085.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0086.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0087.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0088.00	Valve	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0089.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0090.00	Valve	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0091.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0091.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0092.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0093.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0093.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0093.02	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0

**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0094.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0095.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0096.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0097.00	Valve	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0098.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0099.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0100.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0101.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0102.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0103.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0104.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0105.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0106.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0107.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0108.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0109.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0110.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0111.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0112.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0113.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0114.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0115.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0116.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0117.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0118.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0119.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0120.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0120.01	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0121.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0122.00	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.01	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.02	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.03	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.04	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.05	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.06	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.00	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.01	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.02	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.03	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.00	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.01	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0

**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0124.02	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.03	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.04	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.05	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.06	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.07	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0125.00	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0126.00	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0127.00	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0156.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0157.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0157.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0158.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0159.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0160.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0160.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0160.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0160.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0161.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0161.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0161.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0162.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0163.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0165.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0165.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0165.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0166.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0166.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0166.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0167.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0167.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0167.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0168.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0168.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0168.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0



**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0169.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.04	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0172.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0172.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0172.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0173.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0173.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0173.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0174.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0174.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0174.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0175.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0175.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0175.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0176.00	Agitator	Epichlorohydrin	Top of R-401	1/14/99	0.0
0177.00	Pump	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.02	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.03	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.04	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.05	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0178.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0178.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0178.02	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0179.00	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0179.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.00	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.02	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.03	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0181.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0181.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0182.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0183.00	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0

**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0183.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0184.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0184.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0185.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0185.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0186.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0187.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0188.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0189.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0189.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0189.02	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0189.03	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0189.04	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.02	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.03	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.04	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0191.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0191.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.02	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.03	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0193.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0193.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0194.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0194.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0195.00	Valve	Epichlorohydrin	Tank Farm - A408	1/14/99	0.0
0196.00	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0
0196.01	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0
0196.02	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0
0196.03	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0

**Table 1a**  
**Epichlorohydrin Screening Results - Agitators**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0176.00	Agitator	Epichlorohydrin	Top of R-401	1/14/99	0.0
<b>Percent Leakers</b>					<b>0%</b>



**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0001.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0001.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0002.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0003.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0005.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	32.0
0006.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0006.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0007.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0008.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0009.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0010.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0010.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0011.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0012.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0014.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.04	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.05	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.06	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.07	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.08	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.09	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.10	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.11	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.12	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.13	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.15	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.16	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0016.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0018.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0019.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	20.5
0021.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.04	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0022.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	> 500.0
0024.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0025.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0025.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0

**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0025.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0025.03	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.04	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.05	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.06	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.07	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.08	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.09	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.10	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.11	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.12	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0027.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0028.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0028.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0029.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0031.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0032.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.04	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.05	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.06	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.07	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0034.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0035.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0035.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0035.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0036.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0038.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0039.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0040.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0040.01	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0040.02	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0040.03	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0041.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0042.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0042.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0042.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0043.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0043.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0

**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0043.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0044.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.03	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.04	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.05	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.06	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0046.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0046.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0046.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.03	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.04	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.05	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.06	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.07	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.08	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0048.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0050.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0051.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0053.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0054.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0055.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0057.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0058.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0059.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0059.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0060.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0061.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0062.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0063.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0063.01	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.02	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.03	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.04	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.05	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.06	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.07	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0

**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0063.08	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.09	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.10	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0064.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.03	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.04	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.06	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0065.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0066.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0067.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0067.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0067.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0068.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0069.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0070.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0071.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0071.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0071.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0072.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0073.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0073.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0073.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0074.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0074.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0075.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0077.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0078.00	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.01	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.02	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.02	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.04	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.05	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.06	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.07	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.08	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.09	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0079.00	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0079.01	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0079.02	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0080.00	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0080.01	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0

**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
 Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0080.02	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0080.03	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0080.04	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0080.05	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0081.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0082.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0082.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0083.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0085.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0086.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0087.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0089.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0091.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0091.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0092.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0093.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0093.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0093.02	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0094.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0095.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0096.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0098.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0099.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0100.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0102.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0104.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0106.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0107.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0109.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0110.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0112.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0113.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0114.00	Connector	Epichlorohydrin	Grd Level-R401	1/14/99	0.0
0115.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0117.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0118.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0120.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0120.01	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0121.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0122.01	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.02	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.03	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0



**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0122.04	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.05	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.06	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.01	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.02	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.03	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.00	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.01	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.02	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.03	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.04	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.06	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.07	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0126.00	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0127.00	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0156.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0157.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0157.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0158.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0159.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0160.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0160.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0160.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0161.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0161.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0162.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0163.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0165.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0165.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0165.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0166.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0166.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0166.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0167.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0167.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0168.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0168.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0

**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0169.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.04	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0172.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0172.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0173.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0173.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0174.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0174.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0175.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0175.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0175.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0177.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.02	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.03	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.04	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.05	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0178.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0178.02	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0179.00	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0179.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.00	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.02	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.03	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0181.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0183.00	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0183.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0184.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0185.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0189.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0189.02	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0189.03	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0189.04	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.02	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.03	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0

**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0190.04	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0191.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.02	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.03	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0193.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0194.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0196.00	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0
0196.01	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0
0196.02	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0
0196.03	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0
<b>Percent Leakers</b>					<b>0.33%</b>



**Table 1c**  
**Epichlorohydrin Screening Results - Valves**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0004.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0010.01	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0013.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.14	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0017.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0020.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0023.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0028.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0030.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0035.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	10.7
0037.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0049.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0052.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0056.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0059.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0074.00	Valve	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0076.00	Valve	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0084.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0088.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0090.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0097.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0101.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0103.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0105.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0108.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0111.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0116.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0119.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0122.00	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.00	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.05	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0125.00	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0160.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0161.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0167.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0168.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0

**Table 1c**  
**Epichlorohydrin Screening Results - Valves**  
 Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0172.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0173.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0174.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0178.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0181.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0182.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0184.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0185.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0186.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0187.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0188.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0189.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0191.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0193.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0194.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0195.00	Valve	Epichlorohydrin	Tank Farm - A408	1/14/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**Table 1d**  
**Epichlorohydrin Screening Results - Pumps**  
Hercules, Inc.



<b>Tag ID</b>	<b>Component Type</b>	<b>Chemical Stream</b>	<b>Location</b>	<b>Screen Date</b>	<b>Screen Reading (ppm)</b>
0001.00	Pump	Epichlorohydrin	Truck Loading	1/14/99	9.4
0026.00	Pump	Epichlorohydrin	Truck Loading	1/14/99	0.0
0177.00	Pump	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
<b>Percent Leakers</b>					<b>0%</b>




## **ATTACHMENT I**

### **Foxboro 108 Flame Ionization Detector Information and Specifications**

# MODEL 680


## PORTABLE HYDROCARBON VAPOR METER



### Advanced Technology For Applications In:

- EPA Method 21 Compliance Testing
- Fugitive Emissions Monitoring
- Detection of Soil and Water Contaminants
- Leaking Underground Storage Tank Monitoring
- Industrial Hygiene Monitoring
- \*New Features for 1995:
  - New and Improved Laser Scanner
  - Bar Code Editing
  - Optional 512K Memory Expansion
  - Additional Database Interfaces
  - On Demand Detector Purge

## KEY DESIGN FEATURES



\* New and Improved for 199

## ADVANCED TECHNOLOGY

The Model 680 Hydrocarbon Vapor Meter (HVM) microprocessor based design offers capabilities previously unavailable with portable flame ionization instrumentation, including, system diagnostics (check-out) upon power-up, bidirectional RS-232 communications, maximum concentration hold, Time Weighted Averaging (TWA) report capability and auto-ranging over the entire 0-20,000 ppm concentration range.

However, the technological advances within this state-of-the-art design does not end here. Thermo Environmental Instruments engineers implemented an interchangeable battery assembly resulting in extended field

operation and pressure transducer technology for monitoring hydrogen flow status and operating time indication.

The user programmable software capabilities entail response factor settability, self-calibration adjustment, storage of up to 10 calibrations in memory, and automatic data logging of up to 4000 sample readings by time, date, concentration value, location code.

Additionally, the Model 680 HVM is an ergonomic success with its pistol grip display gun and light-weight sidepack layout. This will result in increased field comfort for all types of operators.

# A Truly Portable, Truly Integrated, Intrinsically Safe FUGITIVE EMISSIONS MONITORING SYSTEM

The regulations to be promulgated by the Environmental Protection Agency in support of the Clean Air Act Amendments of 1990 impose stringent demands on process component leak measurement and management.

Existing Fugitive Emissions Monitoring technologies are labor intensive, suffer from erroneous interpretation of data, utilize manual reporting techniques, or require one to be an octopus to operate the system components effectively.

The Model 680 HVM utilizes an integrated system approach which incorporates the flame-ionization detector assembly, data logger, and bar code scanning device into a single sidepack/hand-held gun package. This integrated system addresses the shortcomings of past technologies while providing fugitive emissions monitoring personnel with enhanced capabilities including:


- Integral manual or automatic logging of up to 4000 individual data points by location code, time, date and sample concentration.
- Lock-in of maximum concentration reading. This is useful in isolating or pin-pointing the source of a gaseous chemical leak.
- Increased operator safety via an intrinsically safe design which includes the laser based bar code reading device. The Model 680 HVM is Factory Mutual (FM) certified for use in Class I, Division 1 Groups A, B, C, D hazardous locations.

Leak Detection and Repair (LDAR) programs require extensive documentation and follow-up. The Model 680 HVM addresses LDAR requirements via its ROUTE VIEW function which is illustrated in the flow diagram below. As a self-contained fugitive emissions monitoring system, the Model 680 HVM improves LDAR management efficiency by offering:

- Reread capability for situations in which an exceedance (violation) measurement is encountered and subsequent repair attempted.
- Report identification of any missed component tags.
- Ability to measure and record a background measurement which can subsequently be automatically subtracted from the fugitive emission measurement.
- Ability to generate process component leak reports.

Additionally, via bidirectional RS-232 communications, the Model 680 HVM interfaces directly with several commercially available fugitive emission data base computer software systems. This combination results in the ultimate utilization of the Model 680 HVM microprocessor capabilities by allowing LDAR personnel to download a pre-programmed survey route from a personal computer to the 680. Subsequently, the Model 680 will guide the operator through the designated leak survey route. Please contact us for database software compatibility.


## ROUTE VIEW FUNCTION





# Customized Liquid Crystal Display

- Digital & Graphical Sample Concentration Level
- Maximum Concentration Signal Hold
- Alarm Exceedance Indication
- Low Battery Warning
- Low Hydrogen Warning
- Flame Status



## Specifications

### Measurement:

Technique:	Flame Ionization Detection (FID) of most organic vapors. Note that sample also serves as source of combustion air.
Ranges:	Liquid Crystal Display (LCD) - Auto ranging over entire 0-20,000ppm concentration range. Displayed concentration reading resolution as follows: 0-100ppm (resolution to 0.1ppm) 0-20,000ppm (resolution to 1.0ppm)
Minimum Detectable:	0.5ppm methane in air matrix
Sensitivity:	0.1ppm methane
System Time Constant:	4.0 seconds at 800ml/min sample flow (10.0% to 90.0% of final reading)
Sampling Rate:	800ml/min
Sample Conditioning:	Changeable Teflon filter which also functions as water trap

### Power Requirements:

Battery:	Internally rechargeable (external charger provided with unit.)
Service Life:	Ten hours per internal battery charge, operates from charger indefinitely. Battery is interchangeable. Therefore, battery based operation can be extended indefinitely.
Charger Requirements:	115/220 VAC, 50Hz

### Controls, Panel:

Readout:	Highly visible (0.4"H x 0.2"W) seven (7) segment concentration readout; 2 line by 17 character message display; 1 line by 17 character key function display; calibrated bar graph; symbolic status messages including flame out/fit, low battery charge, low H <sub>2</sub> pressure and concentration level exceedance. Current time and date also available for display.
Keypad:	Three keys control instrument software functions. Keys offer tactile feedback with current function displayed at all times.

### Gases:

Combustion Air:	Provided by sample at a flow rate of 800 ml/min.
Hydrogen:	Provided by refillable internal cylinder. 1800 psig capacity offers 14 hours operation. H <sub>2</sub> flow is 13 ml/min.

### Physical Dimensions:

Case Size:	HWD 12.5 x 11.5 x 2.6 inches
Weight:	Side Pack - 10.5 lbs; Gun - 12 oz.

### Communication:

- 9 Pin RS-232 Port
- 0 - 1V Analog Signal

### Approvals:

Factory Mutual (FM) Class I, Division 1, Groups A, B, C, D  
CENELEC EEx ib d IIC T4

### Patents:

Covered by U.S. Patent 5,356,594

**For Price and Delivery Information, Contact:**

 **Thermo Environmental  
Instruments Inc.**

**Thermo Electron Ltd.**, 910 Birchwood Blvd., Warrington, Cheshire, WA3 7QN, ENGLAND / Telephone: 0925 / 813600

**Thermo Instrument Systems, GMBH**, Martenerstrasse 539, 4600 Dortmund 70, WEST GERMANY / Telephone: :231 / 6170 78

**ThiS Analytical B.V.**, Heerbaan 220, 4817 Breda, HOLLAND / Telephone: 76 / 713717

**Thermo Instrument Systems**, Spinnerslaan 2A, Lokeren, BELGIUM / Telephone: 93/485841

8 West Forge Parkway  
Franklin, MA 02038

(508) 520-0430

FAX: (508) 520-1460



March 8, 1999

Mr. Charles Jordan  
Environmental Supervisor  
Hercules, Inc.  
P.O. Box 1937  
Hattiesburg, Mississippi 39403-1937

**Re: *Environmental Engineering/Consulting Services  
Leak Detection and Repair  
Kymene Process***

Dear Mr. Jordan:

*Eco-Systems* appreciates the opportunity to again provide services to Hercules, Inc. We performed monthly Leak Detection Monitoring services on the affected pumps and agitator of the Kymene process on February 25, 1999. A total of three (3) pumps and one (1) agitator were identified during the initial event in January, 1999. No unit was identified as leaking. A leaking pump is defined in this case as one which has a vapor emission of greater than 5,000 parts per million (ppm). All applicable pumps were tested using a Thermo Environmental Model 680B organic vapor meter. Results of these tests are shown on Table 1 and Table 2 (attached). This report may be placed in the previously provided binder in the First Quarter, 1999 section. Please do not hesitate to contact us at (601) 936-4440 should you have any questions.

Sincerely,  
*Eco-Systems, Inc.*

Wade Steinriede  
Staff Scientist

Jeffrey L. Allen, P.E.  
Senior Engineer

Enclosures

**Table 1**  
**Epichlorohydrin Screening Results - Pumps**  
**February, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0001.00	Pump	Epichlorohydrin	Truck Loading	2/25/99	0.0
0026.00	Pump	Epichlorohydrin	Truck Loading	2/25/99	0.0
0177.00	Pump	Epichlorohydrin	Bottom of R-401	2/25/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**Table 2**  
**Epichlorohydrin Screening Results - Agitators**  
**February, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0176.00	Agitator	Epichlorohydrin	Top of R-401	2/25/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

# **Eco-Systems, Inc.**

Consultants, Engineers and Scientists



April 19, 1999

Mr. Charles Jordan  
Environmental Supervisor  
Hercules, Inc.  
P.O. Box 1937  
Hattiesburg, Mississippi 39403-1937

**Re: *Environmental Engineering/Consulting Services  
Leak Detection and Repair  
Kymene Process***

Dear Mr. Jordan:

*Eco-Systems* appreciates the opportunity to again provide services to Hercules, Inc. We performed monthly Leak Detection Monitoring services on the affected pumps and agitator of the Kymene process on March 25, 1999. A total of three (3) pumps and one (1) agitator were identified during the initial event in January, 1999. No unit was identified as leaking. A leaking pump is defined in this case as one which has a vapor emission of greater than 5,000 parts per million (ppm). All applicable components were tested using a Thermo Environmental Model 680B organic vapor meter. Results of these tests are shown on Table 1 and Table 2 (attached). This report may be placed in the previously provided binder in the First Quarter, 1999 section. The next monitoring event is tentatively scheduled for mid-April, 1999.

*Eco-Systems* appreciates providing environmental assistance to Hercules. Please do not hesitate to contact us at (601) 936-4440 should you have any questions.

Sincerely,  
*Eco-Systems, Inc.*

Wade Steinriede  
Staff Scientist

Evan M. Tullos  
Project Scientist

Enclosures



**Table 1**  
**Epichlorohydrin Screening Results - Pumps**  
**March, 1999**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0001.00	Pump	Epichlorohydrin	Truck Loading	3/25/99	0.0
0026.00	Pump	Epichlorohydrin	Truck Loading	3/25/99	0.0
0177.00	Pump	Epichlorohydrin	Bottom of R-401	3/25/99	0.0
<b>Percent Leakers</b>					<b>0%</b>



**Table 2**  
**Epichlorohydrin Screening Results - Agitators**  
**March, 1999**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0176.00	Agitator	Epichlorohydrin	Top of R-401	3/25/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**INSTRUMENT CALIBRATION**

Methane Mix	Initial Reading	Final Reading
0 (air)	1.4	0.06
95 ppmv	98.2	94.7
980 ppmv	932	978

**Calibration Check**

Methane Mix	Reading	Percent
95 ppmv	95.2	100%



# **Eco-Systems, Inc.**

Consultants, Engineers and Scientists



May 6, 1999

Mr. Charles Jordan  
Environmental Supervisor  
Hercules, Inc.  
P.O. Box 1937  
Hattiesburg, Mississippi 39403-1937


**Re: *Environmental Engineering/Consulting Services  
Leak Detection and Repair  
Kymene Process***


Dear Mr. Jordan:

*Eco-Systems* appreciates the opportunity to again provide services to Hercules, Inc. We performed monthly Leak Detection Monitoring services on the affected pumps and agitator of the Kymene process on April 14, 1999. A total of three (3) pumps and one (1) agitator were identified during the initial event in January, 1999. No unit was identified as leaking. A leaking pump is defined in this case as one which has a vapor emission of greater than 5,000 parts per million (ppm). All applicable components were tested using a Thermo Environmental Model 680B organic vapor meter. Results of these tests are shown on Table 1 and Table 2 (attached). This report may be placed in the previously provided binder in the Second Quarter, 1999 section. The next monitoring event is tentatively scheduled for mid-May, 1999.

*Eco-Systems* appreciates providing environmental assistance to Hercules. Please do not hesitate to contact us at (601) 936-4440 should you have any questions.

Sincerely,  
*Eco-Systems, Inc.*

  
Wade Steinriede  
Staff Scientist

  
Evan M. Tullos  
Project Scientist

Enclosures



**Table 1**  
**Epichlorohydrin Screening Results - Pumps**  
**April, 1999**  
 Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0001.00	Pump	Epichlorohydrin	Truck Loading	4/14/99	0.0
0026.00	Pump	Epichlorohydrin	Truck Loading	4/14/99	0.0
0177.00	Pump	Epichlorohydrin	Bottom of R-401	4/14/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**INSTRUMENT CALIBRATION**

Methane Mix	Initial Reading	Final Reading
0 (air)	3.5	-1.5
95 ppmv	100	95.2
980 ppmv	958	972

**Calibration Check**

Methane Mix	Reading	Percent
95 ppmv	95.9	101%



**Table 2**  
**Epichlorohydrin Screening Results - Agitators**  
**April, 1999**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0176.00	Agitator	Epichlorohydrin	Top of R-401	4/14/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

# **Eco-Systems, Inc.**

Consultants, Engineers and Scientists



June 11, 1999

Mr. Charles Jordan  
Environmental Supervisor  
Hercules, Inc.  
P.O. Box 1937  
Hattiesburg, Mississippi 39403-1937

**Re: Environmental Engineering/Consulting Services  
Leak Detection and Repair  
Kymene Process**

Dear Mr. Jordan:

*Eco-Systems* appreciates the opportunity to again provide services to Hercules, Inc. We performed monthly Leak Detection Monitoring services on the affected pumps and agitator of the Kymene process on May 25, 1999. A total of three (3) pumps and one (1) agitator were identified during the initial event in January, 1999. No unit was identified as leaking. A leaking pump is defined in this case as one which has a vapor emission of greater than 5,000 parts per million (ppm). All applicable components were tested using a Thermo Environmental Model 680B organic vapor meter. Results of these tests are shown on Table 1 and Table 2 (attached). This report may be placed in the previously provided binder in the Second Quarter, 1999 section. The next monitoring event is tentatively scheduled for mid-June 1999.

*Eco-Systems* appreciates providing environmental assistance to Hercules. Please do not hesitate to contact us at (601) 936-4440 should you have any questions.

Sincerely,  
*Eco-Systems, Inc.*

Wade Steinriede  
Staff Scientist

Evan M. Tullos  
Project Scientist

Enclosures



**Table 1**  
**Epichlorohydrin Screening Results - Pumps**  
**May, 1999**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0001.00	Pump	Epichlorohydrin	Truck Loading	5/25/99	0.0
0026.00	Pump	Epichlorohydrin	Truck Loading	5/25/99	0.0
0177.00	Pump	Epichlorohydrin	Bottom of R-401	5/25/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**INSTRUMENT CALIBRATION**

Methane Mix	Initial Reading	Final Reading
0 (air)	2.7	0
95 ppmv	108	96
980 ppmv	1150	980

**Calibration Check**

Methane Mix	Reading	Percent
95 ppmv	95	100%



**Table 2**  
**Epichlorohydrin Screening Results - Agitators**  
**May, 1999**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0176.00	Agitator	Epichlorohydrin	Top of R-401	5/25/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

# Eco-Systems, Inc.

Consultants, Engineers and Scientists



July 1, 1999

Mr. Charles Jordan  
Environmental Supervisor  
Hercules, Inc.  
P.O. Box 1937  
Hattiesburg, Mississippi 39403-1937

COPY

**Re: *Environmental Engineering/Consulting Services  
Quarterly Leak Detection Monitoring for Valves,  
and Monthly for Pumps, Kymene Process***

Dear Mr. Jordan:

*Eco-Systems* appreciates the opportunity to again provide services to Hercules, Inc. We performed quarterly leak detection services on the affected valves in the Kymene process and monthly monitoring on the pumps in the Kymene process on June 28, 1999. A total of 60 valves, three (3) pumps, and one (1) agitator were identified during the initial event in January, 1999. A leaking valve in this case is one which has an organic vapor emission of greater than 500 parts per million (ppm) and/or a visible leak. A leaking pump or agitator is one which has an organic vapor emission of greater than 5,000 ppm or 10,000 ppm, respectively. All applicable components were tested by *Eco-Systems* using a Thermo Environmental Model 680 organic vapor meter and no leaking units were discovered. Results of these tests are shown on the attached tables.

*Eco-Systems* will contact Hercules concerning timing of the next monitoring event tentatively scheduled for mid-July, 1999. *Eco-Systems* appreciates the opportunity to provide environmental assistance to Hercules. Please do not hesitate to contact us at (601) 936-4440 should you have any questions.

Sincerely,  
*Eco-Systems, Inc.*

Wade Steinriede  
Staff Scientist

Evan Tullos  
Project Scientist

Attachment



**Table 1a**  
**Epichlorohydrin Screening Results for June, 1999 - Valves**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0004.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0010.01	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0013.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0015.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0015.14	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0017.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0020.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0023.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0028.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0030.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0035.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0037.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0049.00	Valve	Epichlorohydrin	EPI Storage	6/28/99	0.0
0052.00	Valve	Epichlorohydrin	EPI Storage	6/28/99	0.0
0056.00	Valve	Epichlorohydrin	EPI Storage	6/28/99	0.0
0059.00	Valve	Epichlorohydrin	EPI Storage	6/28/99	0.0
0064.00	Valve	Epichlorohydrin	EPI Storage	6/28/99	0.0
0074.00	Valve	Epichlorohydrin	2nd Lvl-Weigh Tks	6/28/99	0.0
0076.00	Valve	Epichlorohydrin	2nd Lvl-Weigh Tks	6/28/99	0.0
0084.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	6/28/99	0.0
0088.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	6/28/99	0.0
0090.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	6/28/99	0.0
0097.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	6/28/99	0.0
0101.00	Valve	Epichlorohydrin	Grd Level-R-401	6/28/99	0.0
0103.00	Valve	Epichlorohydrin	Grd Level-R-401	6/28/99	0.0
0105.00	Valve	Epichlorohydrin	Grd Level-R-401	6/28/99	0.0
0108.00	Valve	Epichlorohydrin	Grd Level-R-401	6/28/99	0.0
0111.00	Valve	Epichlorohydrin	Grd Level-R-401	6/28/99	0.0
0116.00	Valve	Epichlorohydrin	Grd Level-R-401	6/28/99	0.0
0119.00	Valve	Epichlorohydrin	Grd Level-R-401	6/28/99	0.0
0122.00	Valve	Epichlorohydrin	Loading St. - N Side	6/28/99	0.0
0123.00	Valve	Epichlorohydrin	Loading St. - N Side	6/28/99	0.0
0124.05	Valve	Epichlorohydrin	Loading St. - N Side	6/28/99	0.0
0125.00	Valve	Epichlorohydrin	Loading St. - N Side	6/28/99	0.0
0160.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0161.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0164.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0167.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0168.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0169.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0170.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0171.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0

**Table 1a**  
**Epichlorohydrin Screening Results for June, 1999 - Valves**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0172.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0173.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0174.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0178.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0181.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0182.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0184.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0185.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0186.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0187.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0188.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0189.00	Valve	Epichlorohydrin	Near P-401	6/28/99	0.0
0190.00	Valve	Epichlorohydrin	Near P-401	6/28/99	0.0
0191.00	Valve	Epichlorohydrin	Near P-401	6/28/99	0.0
0192.00	Valve	Epichlorohydrin	Near P-401	6/28/99	0.0
0193.00	Valve	Epichlorohydrin	Near P-401	6/28/99	0.0
0194.00	Valve	Epichlorohydrin	Near P-401	6/28/99	0.0
0195.00	Valve	Epichlorohydrin	Tank Farm - A408	6/28/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**Table 1b**  
**Epichlorohydrin Screening Results for June, 1999 - Agitators**  
Hercules, Inc.

<b>Tag ID</b>	<b>Component Type</b>	<b>Chemical Stream</b>	<b>Location</b>	<b>Screen Date</b>	<b>Screen Reading (ppm)</b>
0176.00	Agitator	Epichlorohydrin	Top of R-401	6/28/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**Table 1c**  
**Epichlorohydrin Screening Results for June, 1999 - Pumps**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0001.00	Pump	Epichlorohydrin	Truck Loading	6/28/99	0.0
0026.00	Pump	Epichlorohydrin	Truck Loading	6/28/99	0.0
0177.00	Pump	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**INSTRUMENT CALIBRATION**

Methane Mix	Initial Reading	Final Reading
0 (air)	3.2	0
95 ppmv	101	95.4
980 ppmv	1122	1002

**Calibration Check**

Methane Mix	Reading	Percent
95 ppmv	97.2	102.3%

**Eco-Systems, Inc.**

Consultants, Engineers and Scientists



July 1, 1999

Mr. Charlie Jordan  
Hercules, Inc.  
P.O. Box 1937  
Hattiesburg, Mississippi 39403-1937

**Re: Equipment Leak Monitoring for January and February**

Dear Mr. Jordan:

On January 15, 1999, Wade Steinrede of *Eco-Systems* visited the Hercules facility to perform equipment leak monitoring as required by 40 CFR 63, Subpart H. During this monitoring, it was discovered that a connector was leaking. According to your office, the leak was physically repaired within 15 days as required by Subpart H. *Eco-Systems* re-tested the connector on February 25, 1999 and determined that it was in compliance as specified by the standard. We are currently gathering field records that document the February monitoring event and will provide them to Hercules, Inc. as soon as possible.

Sincerely,  
Eco-Systems, Inc.

Wade Steinrede  
Staff Scientist

Evan Tullos  
Project Scientist



July 13, 1999

Mr. Charlie Jordan  
Hercules, Inc.  
P.O. Box 1937  
Hattiesburg, Mississippi 39403-1937

**Re: Equipment Re-Testing Certification for  
January and February of 1999**

Dear Mr. Jordan:

This letter is provided as a follow-up to the letter dated July 1, 1999 regarding the leak monitoring performed during January and February of 1999. On January 15, 1999, Wade Steinrede of *Eco-Systems* visited the Hercules facility to perform equipment leak monitoring as required by 40 CFR 63, Subpart H. During this monitoring, it was discovered that a connector was leaking. *Eco-Systems* re-tested the connector on February 25, 1999 and determined that it was in compliance as specified by the standard.

We have been unsuccessful at locating the field records pertaining to the re-testing of the repaired component. However, we wish to reiterate in this communication our certification that the connector was re-tested on February 25 and determined in compliance, and that the instrument was calibrated prior to measurement as is our standard practice.

Sincerely,  
*Eco-Systems, Inc.*

Wade Steinrede  
Staff Scientist

Evan Tullos  
Project Scientist

# Hercules

## Master Equipment List

### Rad Unit



Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	RXR Load	5101	Rail car E/O unloading line tap	VLV	0.750	No	
RAD	RXR Load	5101.1	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5101.2	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5102	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5102.1	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5103	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5103.1	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5104	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5104.1	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5105	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5105.1	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5108	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5108.1	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5107	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5107.1	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5107.2	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5108	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5108	Rail car E/O unloading line tap	CON	0.750	No	
RAD	RXR Load	5108X	Rail car E/O unloading line tap	VLV	2.000	No	
RAD	RXR Load	5108Y	Rail car E/O unloading line tap	FLG	2.000	No	
RAD	RXR Load	5110	Rail car E/O unloading line tap	FLG	2.000	No	
RAD	RXR Load	5110X	Rail car E/O unloading line tap	VLV	0.750	No	
RAD	RXR Load	5110Y	Rail car E/O unloading line tap	FLG	0.750	No	
RAD	RXR Load	5111	Rail car E/O unloading line tap	FLG	0.750	No	
RAD	RXR Load	5111X	Rail car E/O unloading line tap	VLV	2.000	No	
RAD	RXR Load	5111Y	Rail car E/O unloading line tap	FLG	2.000	No	
RAD	RXR Load	5112	Rail car E/O unloading line tap	FLG	2.000	No	
RAD	RXR Load	5112X	Rail car E/O unloading line tap	VLV	1.000	No	
RAD	RXR Load	5112Y	Rail car E/O unloading line tap	VLV	1.000	No	
RAD	RXR Load	5112.1	Rail car E/O unloading line tap	FLG	1.000	No	
RAD	RXR Load	5112.1	Rail car E/O unloading line tap	CON	1.000	No	



Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	RXR Load	5113	Rail car E/O unloading line top	VLV	1.000	No	
RAD	RXR Load	5113X	Rail car E/O unloading line top	FLG	1.000	No	
RAD	RXR Load	5113Y	Rail car E/O unloading line top	FLG	1.000	No	
RAD	RXR Load	5114	Rail car E/O unloading line top	CHV	1.000	No	
RAD	RXR Load	5114X	Rail car E/O unloading line top	FLG	1.000	No	
RAD	RXR Load	5114Y	Rail car E/O unloading line top	FLG	1.000	No	
RAD	RXR Load	5115	Rail car E/O unloading line	CON	1.000	No	
RAD	RXR Load	5115X	Rail car E/O unloading line sight glass	FLG	1.000	No	
RAD	RXR Load	5115Y	Rail car E/O unloading line sight glass	FLG	1.000	No	
RAD	RXR Load	5116	Rail car E/O unloading line	VLV	1.000	No	
RAD	RXR Load	5118.1	Rail car E/O unloading line top	CON	1.000	No	
RAD	RXR Load	5118.2	Rail car E/O unloading line top	CON	1.000	No	
RAD	RXR Load	5118.3	Rail car E/O unloading line	CON	1.000	No	
RAD	RXR Load	5118.4	Rail car E/O unloading line	CON	1.000	No	
RAD	RXR Load	5117	Rail car E/O unloading line top	FLG	0.500	No	
RAD	RXR Load	5118	Rail car E/O unloading line top	CON	0.500	No	
RAD	RXR Load	5118.1	Rail car E/O unloading line top	CON	0.500	No	
RAD	RXR Load	5119	Rail car E/O unloading line top	CON	0.500	No	
RAD	RXR Load	5120	Rail car E/O unloading line top	CON	1.000	No	
RAD	RXR Load	5120.1	Rail car E/O unloading line top	CON	1.000	No	
RAD	RXR Load	5121	Rail car E/O unloading line top	FLG	2.000	No	
RAD	RXR Load	5122	Rail car E/O unloading line top	CON	2.000	No	
RAD	RXR Load	5122.1	Rail car E/O unloading line top	CON	2.000	No	
RAD	RXR Load	5123	Rail car E/O unloading line top	VLV	0.500	No	
RAD	RXR Load	5123X	Rail car E/O unloading line top	FLG	0.500	No	
RAD	RXR Load	5123Y	Rail car E/O unloading line top	FLG	0.500	No	
RAD	RXR Load	5124	Rail car E/O unloading line top	VLV	0.500	No	
RAD	RXR Load	5124.1	Rail car E/O unloading line top	CON	0.500	No	
RAD	RXR Load	5124.2	Rail car E/O unloading line top	CON	0.500	No	
RAD	RXR Load	5125	Rail car E/O unloading line top	FLG	0.500	No	

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	RXR Load	5128	Rail car E/O unloading line top	VLV	0.750	No	
RAD	RXR Load	5128X	Rail car E/O unloading line top	FLG	0.750	No	
RAD	RXR Load	5128Y	Rail car E/O unloading line top	FLG	0.750	No	
RAD	RXR Load	5127	Rail car E/O unloading line top	FLG	0.750	No	
RAD	RXR Load	5128	Rail car E/O unloading line top	CHV	0.750	No	
RAD	RXR Load	5128X	Rail car E/O unloading line top	FLG	0.750	No	
RAD	RXR Load	5128Y	Rail car E/O unloading line top	FLG	0.750	No	
RAD	RXR Load	5129	Rail car E/O unloading line top	FLG	0.750	No	
RAD	RXR Load	5130	Rail car E/O unloading line top	FLG	2.000	No	
RAD	RXR Load	5131	Rail car E/O unloading Pump	FLG	1.500	No	
RAD	RXR Load	5132	Rail car E/O unloading Pump	FLG	1.500	No	
RAD	RXR Load	5133	Rail car E/O unloading Pump	PMP	1.500	No	
RAD	RXR Load	5134	Rail car E/O unloading Pump disc. Line	FLG	1.000	No	
RAD	RXR Load	5135	Rail car E/O unloading Pump disc. Line	FLG	0.500	No	
RAD	RXR Load	5136	Rail car E/O unloading Pump disc. Line	FLG	0.500	No	
RAD	RXR Load	5137	Rail car E/O unloading Pump	VLV	2.000	No	
RAD	RXR Load	5137X	Rail car E/O unloading Pump	FLG	2.000	No	
RAD	RXR Load	5137Y	Rail car E/O unloading Pump	FLG	2.000	No	
RAD	RXR Load	5138	Rail car E/O unloading Pump drain	VLV	0.500	No	
RAD	RXR Load	5138.1	Rail car E/O unloading Pump drain	CON	0.500	No	
RAD	RXR Load	5138.2	Rail car E/O unloading Pump drain	CON	0.500	No	
RAD	RXR Load	5139	Rail car E/O unloading Pump OH	FLG	1.000	No	
RAD	RXR Load	5140	Rail car E/O unloading Pump OH	PRV	1.000	No	
RAD	RXR Load	5140X	Rail car E/O unloading Pump OH	FLG	1.000	No	
RAD	RXR Load	5140Y	Rail car E/O unloading Pump OH	FLG	1.000	No	
RAD	RXR Load	5141	Rail car E/O unloading Pump filter	FLG	2.000	No	
RAD	RXR Load	5142	Rail car E/O unloading Pump filter	VLV	2.000	No	
RAD	RXR Load	5142X	Rail car E/O unloading Pump filter	FLG	2.000	No	
RAD	RXR Load	5142Y	Rail car E/O unloading Pump-filter	FLG	2.000	No	
RAD	RXR Load	5143	Rail car E/O unloading Pump-filter	VLV	0.750	No	

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	RXR Load	5143X	Rail car E/O unloading Pump-filter	FLG	0.750	No	
RAD	RXR Load	5143Y	Rail car E/O unloading Pump-filter	FLG	0.750	No	
RAD	RXR Load	5144	Rail car E/O unloading Pump-filter	FLG	0.750	No	
RAD	RXR Load	5145	Rail car E/O unloading Pump-filter	VLV	0.750	No	
RAD	RXR Load	5145X	Rail car E/O unloading Pump-filter	FLG	0.750	No	
RAD	RXR Load	5145Y	Rail car E/O unloading Pump-filter	VLV	0.750	No	
RAD	RXR Load	5146	Rail car E/O unloading Pump-filter	FLG	0.750	No	
RAD	RXR Load	5146X	Rail car E/O unloading Pump-filter	FLG	0.750	No	
RAD	RXR Load	5146Y	Rail car E/O unloading Pump-filter	VLV	0.750	No	
RAD	RXR Load	5147	Rail car E/O unloading Pump-filter	FLG	0.750	No	
RAD	Load RXR	5147X	Rail car E/O unloading Pump-filter	FLG	0.750	No	
RAD	RXR Load	5147Y	Rail car E/O unloading Pump-filter	FLG	0.750	No	
RAD	RXR Load	5148	Rail car E/O unloading Pump-filter	FLG	2.000	No	
RAD	RXR Load	5149	Rail car E/O unloading Pump-filter	FLG	2.000	No	
RAD	RXR Load	5150	Rail car E/O unloading Pump-filter	VLV	2.000	No	
RAD	RXR Load	5150X	Rail car E/O unloading Pump-filter	FLG	2.000	No	
RAD	RXR Load	5150Y	Rail car E/O unloading Pump-filter	FLG	2.000	No	
RAD	RXR Load	5151	Rail car E/O unloading Pump-filter	VLV	2.000	No	
RAD	RXR Load	5151X	Rail car E/O unloading Pump-filter	FLG	1.000	No	
RAD	RXR Load	5151Y	Rail car E/O unloading Pump-filter	CON	1.000	No	
RAD	RXR Load	5152	Rail car E/O unloading Pump-filter	VLV	1.000	No	
RAD	RXR Load	5152X	Rail car E/O unloading Pump-filter	FLG	1.000	No	
RAD	RXR Load	5152Y	Rail car E/O unloading Pump-filter	FLG	1.000	No	
RAD	RXR Load	5153	Rail car E/O unloading Pump-filter	FLG	1.000	No	
RAD	RXR Load	5154	Rail car E/O unloading Pump-filter	VLV	1.000	No	
RAD	RXR Load	5154X	Rail car E/O unloading Pump-filter	FLG	1.000	No	
RAD	RXR Load	5154Y	Rail car E/O unloading Pump-filter	FLG	1.000	No	
RAD	RXR Load	5155	Rail car E/O unloading Pump-filter	CON	6.000	No	
RAD	RXR Load	5156	Rail car E/O unloading Pump-filter	FLG	2.000	No	
RAD	RXR Load	5157	Rail car E/O unloading Pump-filter	FLG	2.000	No	

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	RXR Load	5158	Rail car E/O unloading Pump-filter	FLG	2,000	No	
RAD	RXR Load	5159	Rail car E/O unloading Pump-filter	FLG	2,000	No	
RAD	RXR Load	5160	Rail car E/O unloading Pump-filter	FLG	2,000	No	
RAD	RXR Load	5161	Rail car E/O unloading Pump-filter	FLG	1,000	No	
RAD	RXR Load	5162	Rail car E/O unloading Pump-filter	VLV	1,000	No	
RAD	RXR Load	5162X	Rail car E/O unloading Pump-filter	FLG	1,000	No	
RAD	RXR Load	5162Y	Rail car E/O unloading Pump-filter	FLG	1,000	No	
RAD	RXR Load	5163	Rail car E/O unloading Pump-filter	PRV	1,000	No	
RAD	RXR Load	5163X	Rail car E/O unloading Pump-filter	FLG	1,000	No	
RAD	RXR Load	5164	Rail car E/O unloading Pump-filter	VLV	1,000	No	
RAD	RXR Load	5164X	Rail car E/O unloading Pump-filter	FLG	1,000	No	
RAD	RXR Load	5164Y	Rail car E/O unloading Pump-filter	FLG	1,000	No	
RAD	RXR Load	5165	Rail car E/O unloading Pump-filter	VLV	1,000	No	
RAD	RXR Load	5165.1	Rail car E/O unloading Pump-filter	CON	1,000	No	
RAD	RXR Load	5165.2	Rail car E/O unloading Pump-filter	CON	1,000	No	
RAD	RXR Load	5166	Rail car E/O unloading Pump-filter	FLG	2,000	No	
RAD	RXR Load	5167	Rail car E/O unloading Pump-filter	VLV	2,000	No	
RAD	RXR Load	5167X	Rail car E/O unloading Pump-filter	FLG	2,000	No	
RAD	RXR Load	5167Y	Rail car E/O unloading Pump-filter	FLG	2,000	No	
RAD	RXR Load	5168	Rail car E/O unloading Pump-filter	VLV	2,000	No	
RAD	RXR Load	5168X	Rail car E/O unloading Pump-filter	FLG	2,000	No	
RAD	RXR Load	5168Y	Rail car E/O unloading Pump-filter	FLG	2,000	No	
RAD	RXR Load	5168	Rail car E/O unloading Pump-filter	FLG	2,000	No	
RAD	RXR Load	5170	Rail car E/O unloading Pump-filter	PRV	1,000	No	
RAD	RXR Load	5170X	Rail car E/O unloading Pump-filter	FLG	1,000	No	
RAD	RXR Load	5170Y	Rail car E/O unloading Pump-filter	FLG	1,000	No	
RAD	RXR Load	5171	Rail car E/O unloading Pump-filter	FLG	2,000	No	
RAD	RXR Load	5172	Rail car E/O unloading Pump-filter	FLG	2,000	No	
RAD	RXR Load	5173	Rail car E/O unloading Top under tool box	FLG	1,000	No	
RAD	RXR Load	5174	Rail car E/O unloading Top under tool box	FLG	1,000	No	

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	RXR Load	5175	Rail car E/O unloading Top under tool box	FLG	1,000	No	
RAD	RXR Load	5178	Rail car E/O unloading Top under tool box	FLG	4,000	No	
RAD	RXR Load	5177	Rail car E/O unloading Top under tool box	FLG	1,000	No	
RAD	RXR Load	5178	Rail car E/O unloading Top catwalk	FLG	1,000	No	
RAD	RXR Load	5179	Rail car E/O unloading Top catwalk	FLG	4,000	No	
RAD	RXR Load	5180	Rail car E/O unloading Top catwalk	FLG	4,000	No	
RAD	RXR Load	5181	Rail car E/O unloading Top catwalk	FLG	4,000	No	
RAD	RXR Load	5182	Rail car E/O unloading	FLG	2,000	No	
RAD	RXR Load	5183	Rail car E/O unloading east end OH	FLG	2,000	Yes	GRT 8FT OH
RAD	RXR Load	5184	Rail car E/O unloading east end OH	FLG	2,000	Yes	GRT 8FT OH
RAD	P/R	5185	E/O line east end N. of sulfuric acid tank OH	FLG	2,000	Yes	GRT 8FT OH
RAD	P/R	5188	Vent line E. end S. of sulfuric acid tank OH	FLG	4,000	No	
RAD	P/R	5188	Vent line east end S. of sulfuric acid tank OH	FLG	4,000	No	
RAD	P/R	5189	Vent line S. of sulfuric acid tank OH	FLG	4,000	No	
RAD	P/R	5190	Vent line top of scrubber	VLV	4,000	Yes	GRT 8FT OH
RAD	P/R	5190X	Vent line top of scrubber	FLG	4,000	Yes	GRT 8FT OH
RAD	P/R	5190Z	Vent line top of scrubber	FLG	4,000	Yes	GRT 8FT OH
RAD	P/R	5190Y	Vent line top of scrubber	FLG	4,000	Yes	GRT 8FT OH
RAD	P/R	5191	Vent line top of scrubber	VLV	0,500	Yes	GRT 8FT OH
RAD	P/R	5191X	Vent line top of scrubber	FLG	0,500	Yes	GRT 8FT OH
RAD	P/R	5191Y	Vent line top of scrubber	FLG	0,500	Yes	GRT 8FT OH
RAD	P/R	5192	Vent line top of scrubber	FLG	4,000	Yes	GRT 8FT OH
RAD	P/R	5193	Vent line top of scrubber	PRV	1,000	Yes	GRT 8FT OH
RAD	P/R	5194	Vent line top of scrubber Man lift	FLG	1,000	Yes	GRT 8FT OH
RAD	P/R	5195	Vent line top of scrubber Man lift	FLG	1,000	Yes	GRT 8FT OH
RAD	Scrubber	5198	Scrubber west side N. Side of Sulfuric acid thk	FLG	4,000	No	
RAD	Scrubber	5197	Scrubber west side N. Side of Sulfuric acid thk	VLV	1,000	No	
RAD	Scrubber	5197X	Scrubber west side N. Side of Sulfuric acid thk	FLG	1,000	No	
RAD	Scrubber	5197Y	Scrubber west side N. Side of Sulfuric acid thk	FLG	1,000	No	
RAD	Scrubber	5197.1	Scrubber west side N. Side of Sulfuric acid thk	CON	0,250	No	

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	Scrubber	5187.2	Scrubber west side N. Side of Sulfuric acid tk	CON	0.250	No	
RAD	Scrubber	5188	Scrubber west side N. Side of Sulfuric acid tk	FLG	1.500	No	
RAD	Scrubber	5189	Scrubber west side N. Side of Sulfuric acid tk	FLG	1.000	No	
RAD	Scrubber	5200	Scrubber west side N. Side of Sulfuric acid tk	VLV	2.000	No	
RAD	P/R	5203	N. west side Sulfuric acid tk below platform	FLG	1.500	Yes	
RAD	Scrubber	5200X	Scrubber west side N. Side of Sulfuric acid tk	FLG	2.000	No	
RAD	Scrubber	5200Y	Scrubber west side N. Side of Sulfuric acid tk	FLG	2.000	No	
RAD	Scrubber	5201	Scrubber west side N. Side of Sulfuric acid tk	FLG	3.000	No	
RAD	Scrubber	5202	Scrubber west side N. Side of Sulfuric acid tk	CON	1.000	No	
RAD	P/R	5205	N.E. Of RA-30 acetic acid tank OH manift	FLG	1.000	Yes	GRT 6FT OH
RAD	P/R	5206	N.W. Of RA-28 platform o	FLG	1.000	Yes	GRT 6FT OH
RAD	RXR Load	5207	E/O unloading East side ....	CHV	1.000	No	
RAD	RXR Load	5207Y		FLG	1.000	No	
RAD	RXR Load	5207X	E/O unloading vent line	FLG	1.000	No	
RAD	RXR Load	5208	E/O unloading vent line	VLV	1.000	No	
RAD	RXR Load	5208.1	E/O unloading vent line	CON	1.000	No	
RAD	RXR Load	5208.2	E/O unloading vent line	CON	1.000	No	
RAD	RXR Load	5208.3	E/O unloading vent line..	CON	1.000	No	
RAD	RXR Load	5208.4	E/O unloading vent line...	CON	1.000	No	
RAD	RXR Load	5209	E/O unloading vent line	FLG	1.000	No	
RAD	RXR Load	5210	E/O unloading vent line OH	FLG	1.000	Yes	GRT 6FT OH
RAD	RXR Load	5211	E/O unloading vent line OH	FLG	1.000	Yes	GRT 6FT OH
RAD	RXR Load	5212	E/O unloading vent line OH	FLG	1.000	Yes	GRT 6FT OH
RAD	RXR Load	5213	E/O unloading vent line OH	FLG	2.000	No	
RAD	RXR Load	5214	E/O unloading vent line	VLV	0.500	No	
RAD	RXR Load	5214.1	E/O unloading vent line	CON	0.500	No	
RAD	RXR Load	5214.2	E/O unloading vent line	CON	0.500	No	
RAD	RXR Load	5215	E/O unloading vent line	FLG	0.750	No	
RAD	RXR Load	5216	E/O unloading vent line	FLG	0.750	No	
RAD	RXR Load	5217	E/O unloading vent line	FLG	2.000	No	

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	RXR Load	5218	E/O unloading vent line	FLG	0.750	No	
RAD	RXR Load	5219	E/O unloading vent line	FLG	2.000	No	
RAD	RXR Load	5220	E/O unloading vent line	FLG	2.000	No	
RAD	RXR Load	5221	E/O unloading vent line	FLG	2.000	No	
RAD	RXR Load	5222	E/O unloading vent line OH	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5223	N. Of E/O unloading vent line OH	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5224	W. Of Sulfuric Acid Tank OH Vent line	FLG	2.000	No	
RAD	P/R	5225	N. Of Sulfuric Acid Tank OH Vent line platform	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5226	N. Of Sulfuric Acid Tank OH Vent line platform	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5227	N. Of Sulfuric Acid Tank OH Vent line platform	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5228	S. Of RA-41 M-844 Tank OH Vent line manifold	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5229	S.W. of RA-40 M-843 Tank OH Vent line manifold	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5230	N. of RA-29 M-720 Tank OH Vent line manifold	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5231	Platform N. of M-718 OH Vent line manifold	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5232	S. of LD station 13 Vent line OH manifold	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5233	W. of LD station 13 bldg. Vent line OH TF to RX	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5234	W. of LD station 13 bldg OH TF to RX line	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5235	W. of LD station 13 bldg OH Vent line	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5236	W. of LD station #13 bldg OH E/O line	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5237	W. of LD station #13 bldg OH Vent line	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5238	W. of LD station #13 bldg OH Vent line	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5239	W. of LD station #13 bldg OH E/O line	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5242	N. of LD station #13 bldg OH Vent line	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5243	W. of LD station #13 bldg OH E/O line	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5240	N. of LD station #13 bldg OH Vent line	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5241	N. of LD station #13 bldg OH E/O line	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5244	N. of LD station #13 bldg OH Vent line	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5245	N. of LD station #13 bldg OH E/O line	VLV	2.000	Yes	GRT 6FT OH
RAD	P/R	5245X	N. of LD station #13 bldg OH E/O line	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5245Y	N. of LD station #13 bldg OH E/O line	FLG	2.000	Yes	GRT 6FT OH

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	P/R	5246	N.of LD station #13 bldg OH E/O line	PRV	2.000	Yes	GRT 6FT OH
RAD	P/R	5247	N.of LD station #13 bldg OH E/O line	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5248	N.of LD station #13 bldg OH Vent line	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5393	N.of LD station #13 bldg OH Vent line		2.000	No	
RAD	E/O Tank	5393	E. Side E/O tank @ Ref. Unit	FLG	2.000	No	
RAD	E/O Tank	5394	E. Side E/O tank @ Ref. Unit	FLG	2.000	No	
RAD	E/O Tank	5395	E. Side E/O tank @ Ref. Unit	FLG	2.000	No	
RAD	E/O Tank	5396	E. Side E/O tank @ Ref. Unit	FLG	2.000	No	
RAD	E/O Tank	5397	E. Side E/O tank @ Ref. Unit	FLG	2.000	No	
RAD	E/O Tank	5398	E. Side E/O tank RA-50 M-741	PMP	0.000	No	
RAD	E/O Tank	5399	E. Side E/O tank @ Pump	FLG	0.000	No	
RAD	E/O Tank	5400	E. Side E/O tank @ Pump	FLG	2.000	No	
RAD	E/O Tank	5401	N. Side E/O tank RA-50 M-741	FLG	2.000	No	
RAD	E/O Tank	5402	N. Side E/O tank RA-50 M-741	VLV	1.000	No	
RAD	E/O Tank	5402X	N. Side E/O tank RA-50 M-741	FLG	1.000	No	
RAD	E/O Tank	5402Y	N. Side E/O tank RA-50 M-741	FLG	1.000	No	
RAD	E/O Tank	5403	N. Side E/O tank RA-50 M-741	VLV	1.000	No	
RAD	E/O Tank	5403X	N. Side E/O tank RA-50 M-741	FLG	2.000	No	
RAD	E/O Tank	5403Y	N. Side E/O tank RA-50 M-741	FLG	2.000	No	
RAD	E/O Tank	5404	N. Side E/O tank RA-50 M-741	VLV	2.000	No	
RAD	E/O Tank	5404X	N. Side E/O tank RA-50 M-741	FLG	2.000	No	
RAD	E/O Tank	5404Y	N. Side E/O tank RA-50 M-741	FLG	2.000	No	
RAD	E/O Tank	5405	Top E/O tank RA-50 M-741	PRV	6.000	No	
RAD	E/O Tank	5405X	Top E/O tank RA-50 M-741	FLG	8.000	No	
RAD	E/O Tank	5405Y	Top E/O tank RA-50 M-741	FLG	6.000	No	
RAD	E/O Tank	5406	Top E/O tank RA-50 M-741	VLV	0.250	No	
RAD	E/O Tank	5406.1	Top E/O tank RA-50 M-741	CON	0.250	No	
RAD	E/O Tank	5406.2	Top E/O tank RA-50 M-741	CON	0.250	No	
RAD	E/O Tank	5406.3	Top E/O tank RA-50 M-741	CON	0.250	No	
RAD	E/O Tank	5407	Top E/O tank RA-50 M-741	VLV	0.250	No	



**Master Equipment List 1999  
Hercules RAD FACILITY**

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	E/O Tank	5408	Top E/O tank RA-50 M-741	VLV	0.250	No	
RAD	E/O Tank	5409	Top E/O tank RA-50 M-741	PRV	4.000	No	
RAD	E/O Tank	5409X	Top E/O tank RA-50 M-741	FLG	4.000	No	
RAD	E/O Tank	5409Y	Top E/O tank RA-50 M-741	FLG	4.000	No	
RAD	E/O Tank	5410	Top E/O tank RA-50 M-741	FLG	4.000	No	
RAD	E/O Tank	5411	Top E/O tank RA-50 M-741	VLV	4.000	No	
RAD	E/O Tank	5411X	Top E/O tank RA-50 M-741	FLG	4.000	No	
RAD	E/O Tank	5411Y	Top E/O tank RA-50 M-741	FLG	4.000	No	
RAD	E/O Tank	5412	Top E/O tank RA-50 M-741	PRV	4.000	No	
RAD	E/O Tank	5412X	Top E/O tank RA-50 M-741	FLG	2.000	No	
RAD	E/O Tank	5413	Top E/O tank RA-50 M-741	FLG	2.000	No	
RAD	E/O Tank	5414	Top E/O tank RA-50 M-741	FLG	2.000	No	
RAD	E/O Tank	5437	Top E/O tank RA-50 M-741	FLG	2.000	No	
RAD	E/O Tank	5415	Top E/O tank RA-50 M-741	PRV	1.000	No	
RAD	E/O Tank	5415X	Top E/O tank RA-50 M-741	FLG	1.000	No	
RAD	E/O Tank	5415Y	Top E/O tank RA-50 M-741	FLG	1.000	No	
RAD	E/O Tank	5418	Top E/O tank RA-50 M-741	PRV	1.000	No	
RAD	E/O Tank	5418X	Top E/O tank RA-50 M-741	FLG	1.000	No	
RAD	E/O Tank	5418Y	Top E/O tank RA-50 M-741	FLG	1.000	No	
RAD	E/O Tank	5417	Top E/O tank RA-50 M-741	VLV	1.000	No	
RAD	E/O Tank	5417.1	Top E/O tank RA-50 M-741	CON	1.000	No	
RAD	E/O Tank	5417.2	Top E/O tank RA-50 M-741	CON	1.000	No	
RAD	E/O Tank	5417.3	Top E/O tank RA-50 M-741	CON	1.000	No	
RAD	E/O Tank	5418	Top E/O tank RA-50 M-741	VLV	1.000	No	
RAD	E/O Tank	5418.1	Top E/O tank RA-50 M-741	CON	1.000	No	
RAD	E/O Tank	5418.2	Top E/O tank RA-50 M-741	CON	1.000	No	
RAD	E/O Tank	5418.3	Top E/O tank RA-50 M-741	CON	1.000	No	
RAD	E/O Tank	5419	Top E/O tank RA-50 M-741	VLV	1.000	No	
RAD	E/O Tank	5419.3	Top E/O tank RA-50 M-741	CON	1.000	No	
RAD	E/O Tank	5419.1	Top E/O tank RA-50 M-741	CON	1.000	No	

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	EJO Tank	5418.2	Top EJO tank RA-50 M-741	CON	1.000	No	
RAD	EJO Tank	5420	Top EJO tank RA-50 M-741	PRV	1.000	No	
RAD	EJO Tank	5420.1	Top EJO tank RA-50 M-741	CON	1.000	No	
RAD	EJO Tank	5420.2	Top EJO tank RA-50 M-741	CON	1.000	No	
RAD	EJO Tank	5421	Top EJO tank RA-50 M-741	FLG	2.000	No	
RAD	EJO Tank	5422	Top EJO tank RA-50 M-741	VLV	1.500	No	
RAD	EJO Tank	5422X	Top EJO tank RA-50 M-741	FLG	1.500	No	
RAD	EJO Tank	5422Y	Top EJO tank RA-50 M-741	FLG	1.500	No	
RAD	EJO Tank	5423	Top EJO tank RA-50 M-741	VLV	1.500	No	
RAD	EJO Tank	5423X	Top EJO tank RA-50 M-741	FLG	1.500	No	
RAD	EJO Tank	5423Y	Top EJO tank RA-50 M-741	FLG	1.500	No	
RAD	EJO Tank	5424	Top EJO tank RA-50 M-741	VLV	1.500	No	
RAD	EJO Tank	5424X	Top EJO tank RA-50 M-741	FLG	1.500	No	
RAD	EJO Tank	5424Y	Top EJO tank RA-50 M-741	FLG	1.500	No	
RAD	EJO Tank	5425	Top EJO tank RA-50 M-741	FLG	1.500	No	
RAD	EJO Tank	5426	Top EJO tank RA-50 M-741	VLV	1.000	No	
RAD	EJO Tank	5426.1	Top EJO tank RA-50 M-741	CON	1.000	No	
RAD	EJO Tank	5426.2	Top EJO tank RA-50 M-741	CON	1.000	No	
RAD	EJO Tank	5427	Top EJO tank RA-50 M-741	CHV	1.000	No	
RAD	EJO Tank	5427X	Top EJO tank RA-50 M-741	FLG	1.000	No	
RAD	EJO Tank	5428	Top EJO tank RA-50 M-741	VLV	2.000	No	
RAD	EJO Tank	5428X	Top EJO tank RA-50 M-741	FLG	2.000	No	
RAD	EJO Tank	5428Y	Top EJO tank RA-50 M-741	FLG	2.000	No	
RAD	EJO Tank	5429	Top EJO tank RA-50 M-741	PRV	1.000	No	
RAD	EJO Tank	5429X	Top EJO tank RA-50 M-741	FLG	1.000	No	
RAD	EJO Tank	5430	Top EJO tank RA-50 M-741	FLG	2.000	No	
RAD	EJO Tank	5431	Top EJO tank RA-50 M-741	FLG	2.000	No	
RAD	EJO Tank	5432	Top EJO tank RA-50 M-741	VLV	1.000	No	
RAD	EJO Tank	5432.1	Top EJO tank RA-50 M-741	CON	1.000	No	
RAD	EJO Tank	5432.2	Top EJO tank RA-50 M-741	CON	1.000	No	

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	E/O Tank	5432.3	Top E/O tank RA-50 M-741	CON	1,000	No	
RAD	E/O Tank	5432.4	Top E/O tank RA-50 M-741	CON	1,000	No	
RAD	E/O Tank	5432.5	Top E/O tank RA-50 M-741	CON	1,000	No	
RAD	E/O Tank	5433	Top E/O tank RA-50 M-741	FLG	1,500	No	
RAD	E/O Tank	5434	Top E/O tank RA-50 M-741	FLG	2,000	No	
RAD	E/O Tank	5435	Top E/O tank RA-50 M-741	VLV	2,000	No	
RAD	E/O Tank	5435X	Top E/O tank RA-50 M-741	FLG	2,000	No	
RAD	E/O Tank	5435Y	Top E/O tank RA-50 M-741	FLG	2,000	No	
RAD	E/O Tank	5436	Top E/O tank RA-50 M-741	VLV	2,000	No	
RAD	E/O Tank	5436X	Top E/O tank RA-50 M-741	FLG	2,000	No	
RAD	E/O Tank	5436Y	Top E/O tank RA-50 M-741	FLG	2,000	No	
RAD	P/R	5248	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5250	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5251	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5252	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5253	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5254	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5255	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5256	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5257	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5258	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5259	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5260	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5261	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5262	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5263	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5264	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5265	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5266	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5267	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	1,500	Yes	GRT 6FT OH

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	P/R	5268	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5269	Pipe rack N. Of loading station #13 Bldg. OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5270	Pipe rack N. E. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5271	Pipe rack N. E. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5272	Pipe rack N. E. Of Hydrogen Unit OH JLG	FLG	1.500	Yes	GRT 6FT OH
RAD	P/R	5273	Pipe rack N. E. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5274	Pipe rack N. E. Of Hydrogen Unit OH JLG	FLG	1.500	Yes	GRT 6FT OH
RAD	P/R	5275	Pipe rack N. E. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5276	Pipe rack N. E. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5277	Pipe rack N. E. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5278	Pipe rack N. E. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5279	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	1.500	Yes	GRT 6FT OH
RAD	P/R	5280	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5281	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5282	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	1.500	Yes	GRT 6FT OH
RAD	P/R	5283	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5284	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5285	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5286	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5287	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5289	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5288	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5290	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	1.500	Yes	GRT 6FT OH
RAD	P/R	5281	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5292	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5293	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5294	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5295	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5296	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH
RAD	P/R	5297	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2.000	Yes	GRT 6FT OH

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	P/R	5298	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5299	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5300	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5301	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5302	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5303	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5304	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5308	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5307	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5308	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5309	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5310	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5311	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5312	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5313	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5314	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5315	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5316	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5317	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5318	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5319	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5320	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5321	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5322	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5323	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5324	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5325	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5328	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5327	Pipe rack N. Of Hydrogen Unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5328	Pipe rack S.E. Of EPO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	PIR	5328	Pipe rack S.E. Of EJO tank OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5330	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5331	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5332	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5333	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5334	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5335	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5336	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5337	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5338	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5339	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5340	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5341	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5342	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5343	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5344	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5345	Pipe rack S.E. Of EJO tank OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5346	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5347	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5348	Pipe rack S.E. Of EJO tank OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5349	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5350	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5351	Pipe rack S.E. Of EJO tank OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5352	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5353	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5354	Pipe rack S.E. Of EJO tank OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5355	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5356	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5357	Pipe rack S.E. Of EJO tank OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5358	Pipe rack S.E. Of EJO tank OH JLG	FLG	2,000	Yes	GRT 6FT OH

Master Equipment List 1989  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip Size	Difficult to Monitor	Difficult Why
RAD	PIR	5359	Pipe rack S.E. Of E/O tank OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5360	Pipe rack S.E. Of E/O tank OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5361	Pipe rack S.E. Of E/O tank OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5362	Pipe rack S.E. Of E/O tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5363	Pipe rack S.E. Of E/O tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5364	Pipe rack S.E. Of E/O tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5365	Pipe rack S.E. Of E/O tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5366	Pipe rack S.E. Of E/O tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5367	Pipe rack S.E. Of E/O tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5368	Pipe rack S.E. Of E/O tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5369	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5370	PIR above Refrigeration unit OH JLG	PRV	1,000	Yes	GRT 6FT OH
RAD	PIR	5370X	PIR above Refrigeration unit OH JLG	FLG	1,000	Yes	GRT 6FT OH
RAD	PIR	5371	PIR above Refrigeration unit OH JLG	VLV	1,000	Yes	GRT 6FT OH
RAD	PIR	5371X	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5371Y	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5372	PIR above Refrigeration unit OH JLG	VLV	2,000	Yes	GRT 6FT OH
RAD	PIR	5372X	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5372Y	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5373	PIR above Refrigeration unit OH JLG	CHV	2,000	Yes	GRT 6FT OH
RAD	PIR	5373X	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5373Y	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5374	PIR above Refrigeration unit OH JLG	VLV	2,000	Yes	GRT 6FT OH
RAD	PIR	5374X	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5374Y	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5375	PIR above Refrigeration unit OH JLG	CHV	2,000	Yes	GRT 6FT OH
RAD	PIR	5375X	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5375Y	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5376	PIR above Refrigeration unit OH JLG	VLV	2,000	Yes	GRT 6FT OH
RAD	PIR	5376X	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip. Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	PIR	5376Y	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5377	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5378	PIR above Refrigeration unit OH JLG	PRV	1,000	Yes	GRT 6FT OH
RAD	PIR	5378X	PIR above Refrigeration unit OH JLG	FLG	1,000	Yes	GRT 6FT OH
RAD	PIR	5379	PIR above Refrigeration unit OH JLG	PRV	1,000	Yes	GRT 6FT OH
RAD	PIR	5379X	PIR above Refrigeration unit OH JLG	FLG	1,000	Yes	GRT 6FT OH
RAD	PIR	5380	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5381	PIR above Refrigeration unit OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5382	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5383	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5384	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5385	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5386	PIR above Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5387	PIR W.OF Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5388	PIR W.OF Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5389	PIR W.OF Refrigeration unit OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5390	PIR E.OF E/O Tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5391	PIR E.OF E/O Tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5392	PIR E.OF E/O Tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5438	PIR E.OF E/O Tank OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	PIR	5439	East side RA-25 off platform OH	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5440	N.E side RA-17 M-735 tank off platform	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5441	N. side RA-18 M-737 tank OH	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5442	N. side RA-18 M-737 tank OH	CON	1,000	Yes	GRT 6FT OH
RAD	PIR	5443	N. side RA-18 M-737 tank OH	VLV	1,500	Yes	GRT 6FT OH
RAD	PIR	5443X	N. side RA-18 M-737 tank OH	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5443Y	N. side RA-18 M-737 tank OH	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5444	Top of CCR E side Roof	FLG	1,500	Yes	GRT 6FT OH
RAD	PIR	5445	Top of CCR E side Roof	FLG	1,500	No	
RAD	PIR	5446	Secondary RX west side OH	FLG	1,500	Yes	GRT 6FT OH



**Master Equipment List 1999  
Hercules RAD FACILITY**

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	Reactor	5447	Sencondary RX south side	FLG	1.500	No	
RAD	Reactor	5448	Sencondary RX south side	VLV	0.750	No	
RAD	Reactor	5448.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5448.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5448.3	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5448.4	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5449	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5449.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5449.2	Sencondary RX south side	FLG	0.750	No	
RAD	Reactor	5450	Sencondary RX south side	VLV	1.500	No	
RAD	Reactor	5450X	Sencondary RX south side	FLG	1.500	No	
RAD	Reactor	5450Y	Sencondary RX south side	FLG	1.500	No	
RAD	Reactor	5451	Sencondary RX south side	CON	1.500	No	
RAD	Reactor	5451.1	Sencondary RX south side	CON	1.500	No	
RAD	Reactor	5452	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5452.1	Sencondary RX south side	CON	1.500	No	
RAD	Reactor	5453	Sencondary RX south side	FLG	1.500	No	
RAD	Reactor	5454	Sencondary RX south side	VLV	1.500	No	
RAD	Reactor	5454X	Sencondary RX south side	FLG	1.500	No	
RAD	Reactor	5454Y	Sencondary RX south side	FLG	1.500	No	
RAD	Reactor	5455	Sencondary RX south side	VLV	1.500	No	
RAD	Reactor	5455X	Sencondary RX south side	FLG	1.500	No	
RAD	Reactor	5455Y	Sencondary RX south side	FLG	1.500	No	
RAD	Reactor	5456	Sencondary RX south side	VLV	0.500	No	
RAD	Reactor	5456.1	Sencondary RX south side	CON	0.500	No	
RAD	Reactor	5456.2	Sencondary RX south side	CON	0.500	No	
RAD	Reactor	5456.3	Sencondary RX south side	CON	0.500	No	
RAD	Reactor	5456.4	Sencondary RX south side	CON	0.500	No	
RAD	Reactor	5457	Sencondary RX south side	CON	0.500	No	
RAD	Reactor	5457.1	Sencondary RX south side	CON	0.750	No	

**Master Equipment List 1999  
Hercules RAD FACILITY**

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	Reactor	5458	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5458.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5459	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5459.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5480	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5480.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5480.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5481	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5481.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5482	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5482.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5483	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5483.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5484	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5484.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5485	Sencondary RX south side	VLV	0.250	No	
RAD	Reactor	5485.1	Sencondary RX south side	CON	0.250	No	
RAD	Reactor	5485.2	Sencondary RX south side	CON	0.250	No	
RAD	Reactor	5485.3	Sencondary RX south side	CON	0.250	No	
RAD	Reactor	5488	Sencondary RX south side	VLV	0.250	No	
RAD	Reactor	5488.1	Sencondary RX south side	CON	0.250	No	
RAD	Reactor	5488.2	Sencondary RX south side	CON	0.250	No	
RAD	Reactor	5488.3	Sencondary RX south side	CON	0.250	No	
RAD	Reactor	5487	Sencondary RX south side	VLV	1.500	No	
RAD	Reactor	5487X	Sencondary RX south side	FLG	1.500	No	
RAD	Reactor	5487Y	Sencondary RX south side	FLG	1.500	No	
RAD	Reactor	5488	Sencondary RX south side	VLV	1.500	No	
RAD	Reactor	5488X	Sencondary RX south side	FLG	1.500	No	
RAD	Reactor	5488Y	Sencondary RX south side	FLG	1.500	No	
RAD	Reactor	5489	Sencondary RX south side	FLG	1.500	No	

**Master Equipment List 1999**  
**Hercules RAD FACILITY**

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	Reactor	5470	Sencondary RX south side	VLV	0.250	No	
RAD	Reactor	5470.1	Sencondary RX south side	CON	0.250	No	
RAD	Reactor	5470.2	Sencondary RX south side	CON	0.250	No	
RAD	Reactor	5471	Sencondary RX south side	FLG	1.500	No	
RAD	Reactor	5472	Sencondary RX south side	FLG	1.500	No	
RAD	Reactor	5473	Sencondary RX south side	VLV	1.500	No	
RAD	Reactor	5473.1	Sencondary RX south side	CON	1.500	No	
RAD	Reactor	5473.2	Sencondary RX south side	CON	1.500	No	
RAD	Reactor	5473.3	Sencondary RX south side	CON	1.500	No	
RAD	Reactor	5474	Sencondary RX south side	CON	1.500	No	
RAD	Reactor	5474.1	Sencondary RX south side	CON	1.500	No	
RAD	Reactor	5475	Sencondary RX south side	CON	1.500	No	
RAD	Reactor	5475.1	Sencondary RX south side	CON	1.000	No	
RAD	Reactor	5478	Sencondary RX south side	VLV	0.750	No	
RAD	Reactor	5478.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5478.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5477	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5477.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5478	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5479	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5480	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5480.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5481	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5481.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5482	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5483	Sencondary RX south side	FLG	0.750	No	
RAD	Reactor	5484	Sencondary RX south side	FLG	0.750	No	
RAD	Reactor	5484.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5484.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5485	Sencondary RX south side	VLV	0.750	No	

**Master Equipment List 1999**  
**Hercules RAD FACILITY**

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	Reactor	5485.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5485.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5485.3	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5486	Sencondary RX south side	VLV	0.750	No	
RAD	Reactor	5486.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5486.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5487	Sencondary RX south side	FLG	0.750	No	
RAD	Reactor	5488	Sencondary RX south side	FLG	0.750	No	
RAD	Reactor	5489	Sencondary RX south side	CHV	0.750	No	
RAD	Reactor	5490	Sencondary RX south side	CHV	0.750	No	
RAD	Reactor	5491	Sencondary RX south side	FLG	0.750	No	
RAD	Reactor	5492	Sencondary RX south side	VLV	0.750	No	
RAD	Reactor	5492.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5492.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5492.3	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5493	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5493.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5494	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5495	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5496	Sencondary RX south side	FLG	0.750	No	
RAD	Reactor	5497	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5498	Sencondary RX south side	FLG	0.750	No	
RAD	Reactor	5499	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5499.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5499.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5499.3	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5500	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5500.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5500.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5500.3	Sencondary RX south side	CON	0.750	No	

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	Reactor	5601	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5601.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5601.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5601.3	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5602	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5602.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5602.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5603	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5603.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5604	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5604.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5605	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5605.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5605.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5608	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5608.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5610	Sencondary RX south side	CHV	0.750	No	
RAD	Reactor	5610.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5610.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5611	Sencondary RX south side	CHV	0.750	No	
RAD	Reactor	5612	Sencondary RX south side	CHV	0.750	No	
RAD	Reactor	5613	Sencondary RX south side	FLG	0.750	No	
RAD	Reactor	5614	Sencondary RX south side	VLV	0.750	No	
RAD	Reactor	5614.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5614.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5615	Sencondary RX south side	FLG	0.750	No	
RAD	Reactor	5616	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5616.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5616.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5617	Sencondary RX south side	CON	0.750	No	

**Master Equipment List 1999**  
**Hercules RAD FACILITY**

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	Reactor	5617.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5619	Sencondary RX south side	VLV	0.750	No	
RAD	Reactor	5619.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5619.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5619.3	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5619.4	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5620	Sencondary RX south side	VLV	0.750	No	
RAD	Reactor	5620.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5620.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5620.3	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5620.4	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5620.5	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5621	Sencondary RX south side	FLG	0.750	No	
RAD	Reactor	5622	Sencondary RX south side	VLV	0.750	No	
RAD	Reactor	5622.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5622.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5623	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5623.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5623.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5624	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5624.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5625	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5625.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5626	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5626.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5626.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5627	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5628	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5628.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5629	Sencondary RX south side	CON	0.750	No	

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	Reactor	5629.1	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5630	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5630.1	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5631	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5631.1	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5631.2	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5632	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5633	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5634	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5634.1	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5634.2	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5635	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5635.1	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5636	Secondary RX south side	VLV	0.750	No	
RAD	Reactor	5636.1	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5636.2	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5636.3	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5637	Secondary RX south side	VLV	0.750	No	
RAD	Reactor	5637.1	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5637.2	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5637.3	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5638	Secondary RX south side	PRV	0.750	No	
RAD	Reactor	5638.1	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5638.2	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5638.3	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5638.4	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5639	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5640	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5640.1	Secondary RX south side	CON	0.750	No	
RAD	Reactor	5641	Secondary RX south side	CON	0.750	No	

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	Reactor	5641.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5642	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5642.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5643	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5643.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5643.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5644	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5644.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5645	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5645.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5646	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5646.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5646.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5647	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5647.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5647.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5648	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5648.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5648.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5649	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5649.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5650	Sencondary RX south side	PMP	0.750	No	
RAD	Reactor	5651	Sencondary RX south side	VLV	0.750	No	
RAD	Reactor	5651.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5651.2	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5652	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5652.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5653	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5653.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5654	Sencondary RX south side	CON	0.750	No	



Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	Reactor	5654.1	Sencondary RX south side	CON	0.750	No	
RAD	Reactor	5655	Sencondary RX south side	VLV	1.000	No	
RAD	Reactor	5655.1	Sencondary RX south side	FLG	1.000	No	
RAD	Reactor	5655.2	Sencondary RX south side	FLG	1.000	No	
RAD	Reactor	5656	Sencondary RX south side	FLG	1.000	No	
RAD	Reactor	5657	Sencondary RX south side	VLV	1.000	No	
RAD	Reactor	5657.1	Sencondary RX south side	FLG	1.000	No	
RAD	Reactor	5657.2	Sencondary RX south side	FLG	1.000	No	
RAD	Reactor	5658	Sencondary RX south side	FLG	1.000	No	
RAD	Reactor	5659	Sencondary RX south side	VLV	1.000	No	
RAD	Reactor	5659.1	Sencondary RX south side	FLG	1.000	No	
RAD	Reactor	5659.2	Sencondary RX south side	FLG	1.000	No	
RAD	Reactor	5660	Top Sencondary RX	FLG	1.500	No	
RAD	Reactor	5661	Top Sencondary RX	FLG	1.500	No	
RAD	Reactor	5662	Top Sencondary RX	FLG	1.500	Yes	GRT 6FT OH
RAD	Reactor	5663	Top Sencondary RX	FLG	1.500	No	
RAD	Reactor	5664	Top Sencondary RX	FLG	1.000	No	
RAD	Reactor	5665	Top Sencondary RX	VLV	1.000	No	
RAD	Reactor	5665.1	Top Sencondary RX	CON	1.000	No	
RAD	Reactor	5665.2	Top Sencondary RX	CON	1.000	No	
RAD	Reactor	5666	Top Sencondary RX	FLG	1.000	No	
RAD	Reactor	5667	Top Sencondary RX	CON	1.000	No	
RAD	Reactor	5667.1	Top Sencondary RX	CON	1.000	No	
RAD	Reactor	5668	Top Sencondary RX	FLG	1.500	No	
RAD	Reactor	5669	Top Sencondary RX off rail	FLG	1.000	Yes	GRT 6FT OH
RAD	Reactor	5670	S. of Sencondary RX OH	FLG	1.000	Yes	GRT 6FT OH
RAD	Reactor	5671	S. of Sencondary RX OH	FLG	1.000	Yes	GRT 6FT OH
RAD	P/R	5672	S. of Sencondary RX OH	FLG	1.000	Yes	GRT 6FT OH
RAD	P/R	5673	S. of Sencondary RX OH	FLG	1.000	No	
RAD	P/R	5674	S. of Sencondary RX OH	FLG	1.000	Yes	GRT 6FT OH

Master Equipment List 1999  
Hercules RAD FACILITY

Area	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Difficult to Monitor	Difficult Why
RAD	P/R	5875	S. of Sencondary RX OH	FLG	1,000	Yes	GRT 6FT OH
RAD	P/R	5876	S. of Sencondary RX OH JLG	FLG	6,000	Yes	GRT 6FT OH
RAD	P/R	5877	S. of Sencondary RX OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5878	S. of Sencondary RX OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5879	S. of Sencondary RX OH JLG	FLG	2,000	Yes	GRT 6FT OH
RAD	P/R	5880	S. of Sencondary RX OH JLG	FLG	1,000	Yes	GRT 6FT OH
RAD	P/R	5881	S. of Sencondary RX OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5882	S. of Sencondary RX OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5883	S. of Sencondary RX OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5884	S. of Sencondary RX OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5885	S. of Sencondary RX OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5886	S. of Sencondary RX OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5888X	S. of Sencondary RX OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5887	S. of Sencondary RX OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5888	S. of Sencondary RX OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5889	S. of Sencondary RX OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5890	S. of Sencondary RX OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5890X	S. of Sencondary RX OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5891	S. of Sencondary RX OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5892	S. of Sencondary RX OH JLG	FLG	1,500	Yes	GRT 6FT OH
RAD	P/R	5893	S.E. of Sencondary RX OH JLG	FLG	4,000	Yes	GRT 6FT OH
RAD	P/R	5894	S. of RA-18 M-738 tank OH JLG	FLG	4,000	Yes	GRT 6FT OH
RAD	P/R	5895	S. of RA-S M-714 tank OH JLG	FLG	4,000	Yes	GRT 6FT OH
RAD	P/R	5896	S. of RA-S M-714 tank OH JLG	FLG	4,000	Yes	GRT 6FT OH
RAD	P/R	5897	S. of RA-S M-714 tank OH JLG	FLG	4,000	Yes	GRT 6FT OH
RAD	P/R	5898	S. of RA-S M-714 tank OH JLG	FLG	4,000	Yes	GRT 6FT OH
RAD	P/R	5899	W. of RXR UnLoad Vent header OH JLG	FLG	4,000	Yes	GRT 6FT OH
RAD	P/R	5700	W. of RXR UnLoad Vent header OH JLG	FLG	4,000	Yes	GRT 6FT OH
RAD	P/R	5501	W. of RXR UnLoad Vent header OH JLG	FLG	4,000	Yes	GRT 6FT OH
RAD	P/R	5502		FLG	1,500	Yes	GRT 6FT OH



# Hercules

Fourth Quarter Monitoring  
And Difficult To Monitor

Rad Unit

**Leak Summary Report**

Monitor Run ID: 1199

All Regulations

Area: ALL Sub Area: ALL

Area	Subarea	Number Tested	Number Left To Test	Number not Leaking	Number of Repair Delays	Number Repaired	Number Still Leaking
RAD	E/O Tank	97	0	97	0	0	0
	Load RXR	1	0	1	0	0	0
	P/R	249	0	249	0	0	0
	RXR Load	183	0	183	0	0	0
	Reactor	267	0	267	0	0	0
	Scrubber	13	0	13	0	0	0
<b>Subtotal for:</b>	<b>RAD</b>	<b>810</b>	<b>0</b>	<b>810</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>TOTALS</b>		<b>810</b>	<b>0</b>	<b>810</b>	<b>0</b>	<b>0</b>	<b>0</b>

All Regulations  
**Percent Leaker Report**

Monitor Run ID: 1199

Area: ALL Sub Area: ALL

Equip Type	Chemical State	Total Monitored	Total Left to Monitor	Percent Monitored	Number of Leaks	Percent Leaking	Delay of Repair	Leak Def. (ppm)
	Vapor	1	0	100.00%	0	0.00%	0	1000
CHV	Light Liquid	8	0	100.00%	0	0.00%	0	1000
CHV	Vapor	3	0	100.00%	0	0.00%	0	1000
CON	Light Liquid	218	0	100.00%	0	0.00%	0	1000
CON	Vapor	40	0	100.00%	0	0.00%	0	1000
FLG	Light Liquid	281	0	100.00%	0	0.00%	0	1000
FLG	Vapor	157	0	100.00%	0	0.00%	0	1000
PMP	Light Liquid	3	0	100.00%	0	0.00%	0	1000
PRV	Light Liquid	13	0	100.00%	0	0.00%	0	1000
PRV	Vapor	3	0	100.00%	0	0.00%	0	1000
VLV	Light Liquid	65	0	100.00%	0	0.00%	0	1000
VLV	Vapor	18	0	100.00%	0	0.00%	0	1000
<b>TOTALS</b>		<b>810</b>	<b>0</b>	<b>100.00%</b>	<b>0</b>	<b>0.00%</b>	<b>0</b>	



**FUGITIVE COMPLIANCE CORPORATION  
CALIBRATION CERTIFICATE  
(EPA METHOD 21)**

Company: FUGITIVE COMPLIANCE CORPORATION

Date: 10-1-99

Instrument Model: TVA-1000

Due Date: 01-1-2000

Serial Number: 11576812

Calibration Gas Data: Zero Air @ ppm.

Methane in Air 10,010 ppm.

Isobutylene in Air N/A ppm.

	DATE	TIME	ZERO		(FID) METHANE		(PID) ISO	
			READING	DRIFT	READING	DRIFT	READING	DRIFT
1.	10-1-99	10:00	0	0	10,008	1	—	—
2.	10-1-99	10:03	0	0	10,009	1	—	—
3.	10-1-99	10:09	0	0	10,009	1	—	—

Mean Value:

Drift: 0 ppm,  
(zero)

Drift: 10,008 ppm  
(methane)

Drift: N/A ppm  
(iso)

Calibration Precision =  $\frac{\text{Mean Cal Drift}}{\text{Cal Gas Concentration}} \times 100 =$

$\frac{10,008}{10,010} \times 100 = \frac{100}{100} \%$   
(methane)

$\frac{—}{—} \times 100 = \frac{—}{—} \%$   
(iso)

Response Time Determination:  
(90% of stable reading)

FID

PID

Mean Response Time:

1. 4 sec.

— sec.

FID 4 seconds

2. 4 sec.

— sec.

PID — seconds

3. 4 sec.

— sec.

  
CERTIFIED BY



**FUGITIVE COMPLIANCE CORPORATION  
CALIBRATION CERTIFICATE  
(EPA METHOD 21)**

Company: FUGITIVE COMPLIANCE CORPORATION

Date: 10-1-99

Instrument Model: TVA-1000

Due Date: 01-1-2000

Serial Number: 11576812

Calibration Gas Data: Zero Air @ ppm.

Methane in Air 2000 ppm.

Isobutylene in Air N/A ppm.

	DATE	TIME	ZERO		(FID) METHANE		(PID) ISO	
			READING	DRIFT	READING	DRIFT	READING	DRIFT
1.	10-1-99	9:45	∅	∅	1999	1	—	—
2.	10-1-99	9:49	∅	∅	2000	∅	—	—
3.	10-1-99	9:53	∅	∅	2000	∅	—	—

Mean Value:

Drift: ∅ ppm,  
(zero)

Drift: 1999 ppm  
(methane)

Drift: — ppm  
(iso)

Calibration Precision =  $\frac{\text{Mean Cal Drift}}{\text{Cal Gas Concentration}} \times 100 =$

$\frac{1999}{2000} \times 100 = \underline{100} \%$   
(methane)

$\frac{—}{—} \times 100 = \underline{—} \%$   
(iso)

Response Time Determination:  
(90% of stable reading)

Mean Response Time:

FID 4 seconds

PID — seconds

FID

1. 4 sec.

2. 4 sec.

3. 4 sec.

PID

— sec.

— sec.

— sec.

  
CERTIFIED BY

**FUGITIVE COMPLIANCE CORPORATION  
CALIBRATION CERTIFICATE  
(EPA METHOD 21)**

Company: FUGITIVE COMPLIANCE CORPORATION

Date: 10-1-99

Instrument Model: TVA-1000

Due Date: 01-1-2000

Serial Number: 11576812

Calibration Gas Data: Zero Air 0 ppm.

Methane in Air 1000 ppm.

Isobutylene in Air n/a ppm.

	DATE	TIME	ZERO		(FID) METHANE		(PID) ISO	
			READING	DRIFT	READING	DRIFT	READING	DRIFT
1.	10-1-99	9:30	0	0	1001	1	—	—
2.	10-1-99	9:33	0	0	1001	1	—	—
3.	10-1-99	9:35	0	0	999	1	—	—

Mean Value:

Drift: 0 ppm,  
(zero)

Drift: 1000 ppm  
(methane)

Drift: n/a ppm  
(iso)

Calibration Precision =  $\frac{\text{Mean Cal Drift}}{\text{Cal Gas Concentration}} \times 100 =$

$\frac{1000}{1000} \times 100 = \frac{100}{100} \%$   
(methane)

$\frac{n/a}{—} \times 100 = \frac{—}{—} \%$   
(iso)

Response Time Determination:  
(90% of stable reading)

FID

PID

Mean Response Time:

1. 4 sec.

— sec.

FID 4 seconds

2. 4 sec.

— sec.

PID — seconds

3. 4 sec.

— sec.

  
CERTIFIED BY

**FUGITIVE COMPLIANCE CORPORATION  
CALIBRATION CERTIFICATE  
(EPA METHOD 21)**

Company: FUGITIVE COMPLIANCE CORPORATION

Date: 10-1-99

Instrument Model: TVA-1000

Due Date: 01-1-2000

Serial Number: 11576812

Calibration Gas Data: Zero Air 0 ppm.

Methane in Air 506 ppm.

Isobutylene in Air — ppm.

	DATE	TIME	ZERO		(FID) METHANE		(PID) ISO	
			READING	DRIFT	READING	DRIFT	READING	DRIFT
1.	10-1-99	9:15	0	.0	508	2	—	—
2.	10-1-99	9:20	0	0	506	0	—	—
3.	10-1-99	9:23	0	0	506	0	—	—

Mean Value:

Drift: 0 ppm,  
(zero)

Drift: 506 ppm  
(methane)

Drift: N/A ppm  
(iso)

Calibration Precision =  $\frac{\text{Mean Cal Drift}}{\text{Cal Gas Concentration}} \times 100 =$

$\frac{506}{506} \times 100 = \frac{100}{100} \%$   
(methane)

$\frac{N/A}{N/A} \times 100 = \frac{N/A}{N/A} \%$   
(iso)

Response Time Determination:  
(90% of stable reading)

**FID**

**PID**

Mean Response Time:

1. 4 sec.

— sec.

FID 4 seconds

2. 4 sec.

— sec.

PID — seconds

3. 4 sec.

— sec.

*Dwight A. Cole*  
CERTIFIED BY



**AIR LIQUIDE**

11426 Fairmont Pkwy  
LaPorte, TX 77571  
Phone(281) 474-8400 Fax(281) 474-8419  
USA (800) 248-1427

Customer : FUGITIVE COMPLIANCE  
Date Made : 12/30/97  
Mix # : LPX7120  
P.O. Number: 460758  
AGZ Doc. # : 1889239-1A  
Item Number:  
Cyl. Size : 44 Valve: CGA 590  
Blend Type : GAS CERTIFIED  
Volume : 211 SCF Pres.: 2000 psia

**CERTIFICATION OF CYLINDER #  
K-087414**

Equipment Used

Mole	Components	Scale	Instr.	Standard
Balance	ULTRA ZERO AIR	1941		
10,010 PPM	METHANE	4867		

**Valid Until: 29 December, 2002**

Requested Notes	Accuracy of Standard	
	Certified* and Certified Plus	Weight Tracable
	Non-React.	React.
	1 % - 50 % ± 1% (*±2%), ± 2%	20 ppm - 50 % ± 1%
	100 ppm - <1 % ± 2%	± 3%
	10 ppm - <100 ppm ± 3%	± 5%
	1 ppm - <10 ppm ± 10%	± 10%

Improper storage or use may affect the accuracy of this standard.



This mixture was prepared and certified by weight using one or more scales certified against weights traceable to N.I.S.T. #822/254143-94.

Prepared by

\*\*\*\*\*  
\*CERTIFICATE OF ANALYSIS\*  
\*\*\*\*\*

DATE : August 5, 1999  
P.O.#: 10579

MANUFACTURED FOR: 19.0012  
Attn.Dwight Celestin  
Fugitive Compliance Corp.  
2300 Hywy 365 - Suite 330  
Nederland , TX 77029

CYLINDER SIZE : 103DS  
CYLINDER CONTENTS: 3.6 CU. FT., 103 L @ 70 F & 1000 PSIG  
CYLINDER LOT # : 900361  
MANUFACTURE DATE : 8/05/1999  
EXPIRATION DATE : 8/04/2000  
CERTIFICATION : Minor Component Certified to be +/-2%

COMPOSITION	CONCENTRATION
METHANE	2000 PPM (vol)
AIR	BALANCE

PREPARATION METHOD : GRAVIMETRIC BALANCES CALIBRATED TO N.I.S.T. WEIGHTS.  
N.I.S.T. TEST NUMBER 822/254480

DAVID SUN (800) 548 2268  
QUALITY ASSURANCE MANAGER PORTAGAS 6717-B POLK STREET, HOUSTON, TX 77011



**AIR LIQUIDE**

11426 Fairmont Pkwy  
LaPorte, TX 77571

Phone (281) 474-8400 Fax (281) 474-8419  
USA (800) 248-1427

Customer : Fugitive Comp.

Date Made : 4/29/97

Mix # : LAPX23186

P.O. Number : 112376320

AGZ Doc. # : 1713585-1A

Item Number :

Valve Type : CGA 590

Blend Type : GAS CERTIFIED

Cyl. Size : 44, 211 SCF

**CERTIFICATION OF CYLINDER #  
KX3001**

Equipment Used

Mole	Components	Scale	Instr.	Standard
Balance	ULTRA ZERO AIR	0007		
1000 PPM	METHANE	0080		

**Valid Until: 28 April, 2002**

Requested Notes	Accuracy of Standard		
	Certified* and Certified Plus		Weight Tracable
		Non-React.	React.
	1 % - 50 %	± 1% (*±2%)	± 2%
	100 ppm - <1 %	± 2%	± 3%
	10 ppm - <100 ppm	± 3%	± 5%
	1 ppm - <10 ppm	± 10%	± 10%
Improper storage or use may affect the accuracy of this standard.			



This mixture was prepared and certified by weight using one or more scales certified against weights traceable to N.I.S.T. #822/254480.

Prepared by

*[Handwritten Signature]*



11426 Fairmont Pkwy

LaPorte, TX 77571

Phone (281) 474-8400 Fax (281) 474-8419

USA (800) 248-1427

CERTIFICATION OF CYLINDER #

CC52311

Customer : Fugitive Compliance

Date Made : 6/29/99

Mix # : LPX28930

P.O. Number : 3453706

AGZ Doc. # : 3455456-1A

Item Number :

Cyl. Size : 30AL

Valve: CGA 590

Blend Type : GAS CERTIFIED

Volume : 144 SCF

Pres.: 2000 psia

Equipment Used

Mole	Components	Scale	Instr.	Standard
Balance	AIR	1399		
506 PPM	METHANE	3992	4008	NTRM7

Valid Until: 27 June, 2004

Requested Notes	Accuracy of Standard		
	Certified* and Certified Plus		Weight Tracable
FUGITIVE COMPLIANCE PO # 33334	1 % - 50 %	± 1% (*±2%)	± 2%
	100 ppm - <1 %	± 2%	± 3%
	10 ppm - <100 ppm	± 3%	± 5%
	1 ppm - <10 ppm	± 10%	± 10%
			20 ppm - 50 % ± 1
			2 ppm - <20 ppm ± 2
Improper storage or use may affect the accuracy of this standard.			



This mixture was certified by analysis using one or more calibration standards prepared with scales certified against weights traceable to N.I.S.T. #822/254143-94.

Prepared by



11426 Fairmont Pkwy.  
La Porte Texas 77571  
Phone (281) 474-8400  
Fax (281) 474-8419  
USA (800) 248-1427

Customer : FUGITIVE COMPLIANCE  
Date Made : 22 June, 1999  
P.O. Number : 3466808  
Doc. # : 3469096  
Lot # : 011299B  
Item Number :  
Valve Type : CGA 590  
Cyl. Size : 44

MAJOR COMPONENT

Air, Zero

PURITY


N. A.

IMPURITIES

Oxygen  
T. H. C.  
Water

Mole %

19.5-23.5%  
< 2.0 PPM  
< 3.0 PPM

  
Prepared by

Remarks CERTIFICATION OF CYLINDER #S:  
5843







Instrument Rea. .000  
HERCULES RAD FACILITY

01/10/2000

17:47:30

rea	Sub Area	Tag ID	Description	Equip Type	Equip. Size	Monitor Date	Adjusted Reading (ppm)
LAD	RXR Load	5133	Rail car E/O unloading Pump	PMP	1.500	12/30/1999	3
LAD	E/O Tank	5398	E. Side E/O tank RA-50 M-741	PMP	0.000	12/30/1999	3
LAD	Reactor	5650	Secondary RX south side	PMP	0.750	12/30/1999	3

**Leak Summary Report**

Monitor Run ID: 1299

All Regulations

Area: ALL Sub Area: ALL

Area	Subarea	Number Tested	Number Left To Test	Number not Leaking	Number of Repair Delays	Number Repaired	Number Still Leaking
RAD	E/O Tank	1	0	1	0	0	0
	RXR Load	1	0	1	0	0	0
	Reactor	1	0	1	0	0	0
<b>Subtotal for:</b>	RAD	<u>3</u>	<u>0</u>	<u>3</u>	<u>0</u>	<u>0</u>	<u>0</u>
<b>TOTALS</b>		<u>3</u>	<u>0</u>	<u>3</u>	<u>0</u>	<u>0</u>	<u>0</u>

All Regulations  
**Percent Leaker Report**  
 Monitor Run ID: 1299

Area: ALL Sub Area: ALL

Equip Type	Chemical State	Total Monitored	Total Left to Monitor	Percent Monitored	Number of Leaks	Percent Leaking	Delay of Repair	Leak Def. (ppm)
PMP	Light Liquid	3	0	100.00%	0	0.00%	0	1000
<b>TOTALS</b>		<u>3</u>	<u>0</u>	<u>100.00%</u>	<u>0</u>	<u>0.00%</u>	<u>0</u>	

**HERCULES, INCORPORATED  
 HATTIESBURG, MISSISSIPPI - TITLE V PERMIT #0800-00001  
 ANNUAL TITLE V COMPLIANCE CERTIFICATION**

TERM OR CONDITION OF TITLE V PERMIT	EMISSION POINT(S)	COMPLIANCE STATUS	CONTINUOUS OR INTERMITTENT	METHOD FOR DETERMINING COMPLIANCE	SUMMARY OF REQUIREMENT & NOTES
General Conditions - Conditions 1.1 through 1.25	Facility-Wide	IN	Continuous	Process knowledge and engineering judgement	These are general conditions such as paying the annual Title V fees, allowing DEQ on-site, permit duration, etc.
Facility-Wide Emissions Limitations (FWEL) - Condition 3.A.1	Facility-Wide	IN	Continuous	Visual observation	Smoke opacity, startup opacity, and soot blowing opacity limitations
FWEL - Condition 3.A.2	Facility-Wide	IN	Continuous	Visual observation	Opacity $\leq$ 40% from any air contaminant
Emission Point Specific Limitations & Standards (EPSL&S) - Condition 3.B.1	AA-000, AA-001, AN-000	IN	Continuous	Affected equipment is monitored for leaks and repaired properly.	Limit total emissions of HAPs from all process vents, storage tanks, and wastewater systems to 10 lb/MMlb of resins produced or control emissions from equipment leaks
EPSL&S - Condition 3.B.2	AA-002, AB-001, AC-004, AG-005, and AL-002	IN	Continuous	Process knowledge and engineering judgement via calculations performed at time of application submittal	APC-S-1, Sect. 3.6.a - process weight equation
EPSL&S - Condition 3.B.3	AC-001, AF-001, AG-001, AG-002, AJ-001, AL-001, and AN-001	IN	Continuous	Process knowledge and engineering judgement via calculations performed at time of application submittal	Fuel Burning sources < 10mmBTU/hr not to exceed 0.6 lb/mmBTU

TERM OR CONDITION OF TITLE V PERMIT	EMISSION POINT(S)	COMPLIANCE STATUS	CONTINUOUS OR INTERMITTENT	METHOD FOR DETERMINING COMPLIANCE	SUMMARY OF REQUIREMENT & NOTES
EPSL&S - Condition 3.B.4	AC-001, AF-001, AG-001, AG-002, AJ-001, AK-001, AL-001, AM-001, AM-002, and AN-001	IN	Continuous	Process knowledge, sulfur content of fuel, and engineering judgement via calculations performed at time of application submittal	SO <sub>2</sub> not to exceed 4.8 lbs/mmBTU
EPSL&S - Condition 3.B.5	AK-001 and AM-001	IN	Continuous	Process knowledge, and engineering judgement via calculations performed at time of application submittal	PM emissions not to exceed E = 0.8808 * I <sup>-0.667</sup>
EPSL&S - Condition 3.B.6	AF-001, AG-001, AJ-001, AK-001, AL-001, and AN-001	IN	Continuous	Recordkeeping of fuel use	Burn only natural gas or propane.
EPSL&S - Condition 3.B.7	AA-003, AA-004, AC-005, AE-002, AE-004, and AE-004	IN	Continuous	Recordkeeping of tank size and product stored	Comply with 40 CFR 60.110(b) of Subpart Kb
Insignificant and Trivial Activity Emission Limitations & Standards (JTAEL&S) - Condition 3.C.1	Facility-Wide	IN	Continuous	Process knowledge and engineering judgement via calculations performed at time of application submittal	Fuel Burning sources < 10mmBTU/hr not to exceed 0.6 lb/mmBTU



TERM OR CONDITION OF TITLE V PERMIT	EMISSION POINT(S)	COMPLIANCE STATUS	CONTINUOUS OR INTERMITTENT	METHOD FOR DETERMINING COMPLIANCE	SUMMARY OF REQUIREMENT & NOTES
ITAE&S - Condition 3.C.2	Facility-Wide	IN	Continuous	Process knowledge, sulfur content of fuel, and engineering judgement via calculations performed at time of application submittal	SO <sub>2</sub> not to exceed 4.8 lbs/mmBTU
ITAE&S - Condition 3.C.3	Facility-Wide	IN	Continuous	Process knowledge and engineering judgement via calculations performed at time of application submittal	APC-S-1, Sect. 3.6.a - process weight equation
Operation and Maintenance Requirements (O&M) 3.D.1	AA-000, AA-001, and AN-000	IN	Continuous	Best management practices and process knowledge regarding pollution control	Maintain emission points in manner consistent with good air pollution control practices.
O&M 3.D.2	AA-000 and AA-001	IN	Continuous	Maintain plan and follow provisions	Maintain a startup, shutdown, and malfunction plan and a corrective action program
O&M 3.D.3	AA-000, AA-001, and AN-001	IN	Continuous	NA	Identify all applicable routine and otherwise predictable emissions related CMS malfunctions.
Compliance Schedule (CS) - Condition 4.1	Facility-wide	IN	Continuous	Process knowledge, engineering judgement, and records retention	Permittee must be in compliance with all applicable requirements upon issuance of the Title V permit.
CS - Condition 4.2	All Title V permit conditions	IN	Continuous	Submittal of this report and certification	Submit annual certification of compliance status.
CS - Condition 4.3	AA-000, AA-001, and AN-000	IN	Continuous	Hercules has complied with these MACT requirements by the compliance date specified.	Comply with 40 CFR Part 63, Subparts A and W no later than March 8, 1998

TERM OR CONDITION OF TITLE V PERMIT	EMISSION POINT(S)	COMPLIANCE STATUS	CONTINUOUS OR INTERMITTENT	METHOD FOR DETERMINING COMPLIANCE	SUMMARY OF REQUIREMENT & NOTES
Monitoring, Recordkeeping & Reporting Requirements (MR&RR) - Condition 5.A.1	Facility-Wide	IN	Continuous	Process knowledge, engineering judgement and recordkeeping	Install, maintain and operate equipment and/or institute procedures as necessary to perform recordkeeping and monitoring as specified in Section 5.
MR&RR - Condition 5.A.2	Facility-Wide	IN	Continuous	Process knowledge and records retention	List of required monitoring information to be maintained with required records, where applicable.
MR&RR - Condition 5.A.3	Facility-Wide	IN	Continuous	Process knowledge and records retention	Maintain required records for 5 years from the date of the record.
MR&RR - Condition 5.A.4	Facility-Wide	IN	Continuous	Prompt reporting	Submittal of required semi-annual reports by July 31 <sup>st</sup> and January 31 <sup>st</sup> .
MR&RR - Condition 5.A.5	Facility-Wide	IN	Continuous	Report any deviations. However, no deviations occurred during this reporting period.	Prompt reporting of deviations from permit requirements.
MR&RR - Condition 5.A.6	Facility-Wide	IN	Continuous	Use of EPA approved Test Methods when required to test.	Permittee shall use the EPA Reference Test Methods when performing required testing.
MR&RR - Condition 5.B.1	AA-000, AA-001, and AN-000	IN	Continuous	Testing using approved EPA test methods. Calculating emissions for storage tanks, wastewater systems, and production based emission rate.	Initial Compliance and Performance Testing
MR&RR - Condition 5.B.2	AA-000, AA-001, and AN-000	IN	Continuous	Leak detection monitoring of affected components and repair promptly	Equipment leak requirements



Hercules, Incorporated - Hattiesburg, Mississippi  
 Annual Title V Certification  
 January 1999

TERM OR CONDITION OF TITLE V PERMIT	EMISSION POINT(S)	COMPLIANCE STATUS	CONTINUOUS OR INTERMITTENT	METHOD FOR DETERMINING COMPLIANCE	SUMMARY OF REQUIREMENT & NOTES
MR&RR - Condition 5.B.3	AA-000, AA-001, and AN-000	IN	Continuous	Leak detection monitoring of affected components and repair promptly	Perform monitoring per methods specified.
MR&RR - Condition 5.B.4	AA-000, AA-001, and AN-000	IN	Continuous	Recordkeeping of average values of equipment operating parameters to be monitored and equipment leak inspections.	Perform recordkeeping as specified.
MR&RR - Condition 5.B.5	AA-000, AA-001, and AN-000	N/A	N/A	N/A due to method of compliance demonstration chosen (i.e. 3.B.1(b) applies)	If demonstrated that certain process vents are below the de minimis cutoff for CMS, records of the HAP emission rate being less than 1 lb/yr must be kept.
MR&RR - Condition 5.B.6	AC-001, AF-001, AG-001, AG-002, AJ-001, AK-001, AL-001, AN-001	IN	Continuous	Recordkeeping and reporting of fuel operating records.	Monthly operating records report: type and quantity of fuel combusted, and semi-annual analysis of fuel quality and heating value.
MR&RR - Condition 5.B.7	AA-001 and AA-002	IN	Continuous	Recordkeeping and reporting of fuel operating records.	Monthly operating records report: type, quantity, quality (sulfur content), and heating value of fuel(s) combusted.
MR&RR - Condition 5.B.8	AA-002	IN	Continuous	Recordkeeping and reporting of Kymene adipic acid process.	Daily operating records report: number of boxes (in lbs) of solid raw material processed and hours of operation.
MR&RR - Condition 5.B.9	AB-001	N/A during reporting period	N/A during reporting period	N/A	Weekly operating records report: water flowrate through the scrubber by December 31, 1998.

Hercules, Incorporated - Hattiesburg, Mississippi  
 Annual Title V Certification  
 January 1999

TERM OR CONDITION OF TITLE V PERMIT	EMISSION POINT(S)	COMPLIANCE STATUS	CONTINUOUS OR INTERMITTENT	METHOD FOR DETERMINING COMPLIANCE	SUMMARY OF REQUIREMENT & NOTES
MR&RR - Condition 5.B.10	AG-005	N/A during reporting period	N/A during reporting period	N/A	Weekly operating records report: pressure drop across the baghouse by December 31, 1998.
MR&RR - Condition 5.B.11	AL-002	IN	Continuous	Recordkeeping and reporting of number of bags of silica processed and hours of operation.	Daily operating records report: number of bags of silica processed (in lbs) and hours of operation.
MR&RR - Condition 5.B.12	AM-001 and AM-002	IN	Continuous	EPA Reference Methods 1-5 and Method 6	Stack testing for PM and SO2 within 60 days of burning No. 6 fuel oil for 5 consecutive days. Submit test protocol at least 30 days prior to test date.
MR&RR - Condition 5.B.13	AC-004	IN	Continuous	Recordkeeping and reporting of raw material input and hours of operation.	Daily operating records of raw material input (in lbs) and hours of operation.
MR&RR - Condition 5.B.14	AA-001, AA-002, AB-001, AC-001, AC-003, AD-001, AD-002, AD-003, AF-004, AG-003, AG-005, AK-000, AL-002, AN-001	IN	Continuous	Recordkeeping of maintenance inspections.	Perform weekly maintenance checks to ensure proper operation and maintain sufficient replacement parts.
MR&RR - Condition 5.B.15	AA-003, AA-004, AC-005, AE-002, and AE-003	IN	Continuous	Recordkeeping of dimensions and capacity of storage vessels.	Keep records of dimensions and capacity of storage vessels.
MR&RR - Condition 5.C.1	AA-000, AA-001, and AN-000	IN	Continuous	Prompt reporting.	Meet reporting requirements of 40 CFR 63.10 (Subpart W)
MR&RR - Condition 5.C.2	AA-000, AA-001, AN-000, AM-001, and AM-002	IN	Continuous	Prompt reporting of stack test data. No stack test required during reporting period.	Submit written report of stack test results to MDEQ within 45 days of stack test.

Hercules, Incorporated - Hattiesburg, Mississippi  
 Annual Title V Certification  
 January 1999

TERM OR CONDITION OF TITLE V PERMIT	EMISSION POINT(S)	COMPLIANCE STATUS	CONTINUOUS OR INTERMITTENT	METHOD FOR DETERMINING COMPLIANCE	SUMMARY OF REQUIREMENT & NOTES
MR&RR - Condition 5.C.3	AA-001, AA-002, AC-001, AF-001, AG-001, AG-002, AJ-001, AK-001, AL-001, AN-001	IN	Continuous	Prompt reporting.	Submit written report summarizing the type, quality, and quantity of fuel burned in all fuel burning equipment.
Alternative Operating Scenarios Section 6	Not Applicable	Not Applicable	Not Applicable	Not Applicable	Not Applicable. No alternative operating scenarios are permitted.
Title VI Requirements - Section 7 - Conditions 7.1 through 7.5.	Facility-wide use of ozone depleting substances	IN	Continuous	Process Knowledge and record retention, as well as ensuring that employees or contractors employed for these services are properly certified and use approved equipment.	This section applies to repair and maintenance on motor vehicle air conditioning units, plant refrigeration, and plant appliances that contain ozone depleting substances (i.e. freon).



**Hercules Incorporated**  
613 West 7th Street  
P.O. Box 1937  
Hattiesburg, MS 39403-1937  
(601) 545-3450  
Fax: (601) 584-3226

January 28, 1999

Earl Mahaffey  
Environmental Compliance and Enforcement Division  
Office of Pollution Control  
101 West Capitol Street  
Jackson, Mississippi 39201


Re: Hercules, Incorporated - Permit # 0800-00001  
Semi-Annual Reporting

Dear Mr. Mahaffey:

As required by Title V Conditions 5.B.6, 5.B.7, 5.B.8, 5.B.11, and 5.B.13, attached is the required monitoring data for the period ending December 31, 1998. As Responsible Official for Hercules, Incorporated, I certify that based on information and belief formed after reasonable inquiry, the statements and information in the attached document are true, accurate, and complete.

Please contact Mr. Charles Jordan at (601) 584-3360 should you have any questions or need any further information.

Sincerely,



Walter D. Langhans  
Plant Manager

Attachment

cc: Mr. Ken Faulkner, P.E. (w/ attachment)

MONITORING, RECORDKEEPING & REPORTING REQUIREMENT 5.A.4

YEAR	EMISSION POINT	DESCRIPTION	GAS USAGE - MCF											
			JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	OCT	NOV	DEC
1998	AC001	Poly-pale nat. gas Dowtherm boiler											0	2,400
	AF001	RAD nat. gas Dowtherm boiler											0	0
	AG001	HRA nat. gas Dowtherm boiler											808	926
	AG002	HRA nat. gas Dowtherm boiler											0	0
	AJ001	Rosin dist. nat. gas Dowtherm boiler											4500	2250
	AK001	Hydrogen nat. gas Dowtherm boiler											0	0
	AL001	Silica nat. gas Dowtherm boiler											0	0
	AM001	No. 5 package boiler											847	10603
	AM002	No. 6 package boiler											32267	25908
	AN001	Reg. furnace nat. gas boiler											1700	1200

T5ngas

Koch Gateway Pipeline Company  
DETAIL METER STATEMENT  
FOR THE MONTH OF 11.98

11/01/98 20:27:11  
PAGE 4

METER ID: 002020-01  
LOCATION: HATTISBURG CITY GATE #1  
TYPE METER: EFM (office)

SYSTEM: 007 Missisippi  
SUBSYSTEM: 014 Jackson to Leaksville 16" & 8"  
PURPOSE: Koch Custody Delivery

CONTRACT TIME: 09.00  
ANALYST: Matthews, Tota  
PHONE #: 5041695903

EFFECTIVE DATE	REF NUM	STATIC RANGE	DIFF RANGE	TUBE SIZE	PLATE SIZE	TAP TYPE	TAP LOCA	CHART DAYS	MACHINE CONSTANT	CALC TYPE
11/01/98	1	500	100	8.072	3.250	F	U	1	1.0000	11

DAY ON	DAY OFF	REF NUM	FLOW EXTENT	FLOW HOURS	TEMP	PRES PSIA	DIFF	SPEC GRAV	MCF VOLUME @ 14.730	BTU(D)	Dth
1	2	1							3527	1015.5000	3582
2	3	1							4512	1015.5000	4582
3	4	1							5109	1015.5000	5188
4	5	1							5175	1015.5000	5255
5	6	1							8287	1015.5000	8415
6	7	1							7607	1015.5000	7725
7	8	1							5908	1015.5000	6000
8	9	1							3867	1015.5000	3927
9	10	1							2901	1015.5000	2946
10	11	1							4419	1015.5000	4487
11	12	1							6065	1015.5000	6159
12	13	1							5646	1015.5000	5734
13	14	1							5103	1015.5000	5182
14	15	1							4277	1015.5000	4343
15	16	1							4383	1015.5000	4451
16	17	1							4624	1015.5000	4656
17	18	1							5231	1015.5000	5312
18	19	1							4431	1015.5000	4500
19	20	1							4303	1015.5000	4370
20	21	1							5195	1015.5000	5276
21	22	1							5975	1015.5000	6068
22	23	1							4248	1015.5000	4314
23	24	1							4229	1015.5000	4295
24	25	1							4647	1015.5000	4719
25	26	1							4780	1015.5000	4854
26	27	1							4414	1015.5000	4482
27	28	1							4720	1015.5000	4793
28	29	1							5045	1015.5000	5124
29	30	1							4825	1015.5000	4900
30	1	1							4112	1015.5000	4176

Total

147566

148202

149855

**WAS QUALITY INFORMATION**

EFFECTIVE DATE	SAMPLE TYPE	WATER CONTENT	N2	CO2	H2S	O1	O2	O3	IC4	NC4	IC5	NC5	C6+
* 11/01/98	C	6.1	1.3020	2.6620	0.0000	93.5250	1.2730	0.4600	0.1480	0.1930	0.0890	0.0850	0.2730

Nov. Gas

Heat value = 1051 BTU/MCF















## Emission Point - AC004 Poly-Pale Process Melter

Date	7-3 Hrs	7-3 Drs	3-11 Hrs	3-11 Drs	Total Drs	Tons/hr	Comments
12/1/98							No Production
12/2/98							↓
12/3/98							
12/4/98							
12/5/98							
12/6/98							
12/7/98							↓
12/8/98	8	50	8	60	110	1.7	-
12/9/98	8	40	8	60	100	1.6	
12/10/98	—	—	8	42	42	1.3	
12/11/98	8	40	8	44	84	1.3	
12/12/98	8	60	8	60	120	1.9	
12/13/98	8	80	8	40	120	1.9	
12/14/98	8	60	—	—	60	1.9	
12/15/98	8	61	8	44	105	1.6	
12/16/98	8	20	—	—	20	0.6	
12/17/98	8	40	8	50	90	1.4	
12/18/98	8	60	—	—	60	1.9	
12/19/98	—	—	—	—	—	—	
12/20/98	8	70	8	50	120	1.9	
12/21/98	—	—	—	—	—		
12/22/98	—	—	—	—	—		
12/23/98	8	60	8	40	100	1.6	
12/24/98	8	60	—	—	60	1.9	
12/25/98	8	60	—	—	60	1.9	
12/26/98	8	60	—	—	60	1.9	
12/27/98	—	—	—	—	—		
12/28/98	8	80	8	60	140	2.2	
12/29/98					—		No Production
12/30/98					—		
12/31/98					—		↓

**FUGITIVE EMISSIONS SCREENING REPORT  
FOR LEAK DETECTION AND REPAIR (LDAR) PROGRAM**

**prepared for**

**Hercules, Inc.  
Specialty Chemicals  
Hattiesburg, Mississippi**

**prepared by**

***Eco-Systems, Inc.*  
Environmental Engineers and Scientists  
Jackson, MS · Little Rock, AR · Houston, TX**

**January, 1999**

## **1.0 INTRODUCTION**

---

Hercules, Inc.(Hercules) owns and operates a specialty chemicals facility in Hattiesburg, Mississippi. The facility is located on West Seventh Street in Hattiesburg, Forrest County, Mississippi on approximately 200 acres of land. More specifically, the Site is located in Township 4 North, Range 13 West, within sections 4 and 5 just north of Hattiesburg, Mississippi. The facility has been in operation since 1923 and is surrounded by both industrial and residential properties.

The facility's operations consist of extraction, fractionation, refining, distillation, and processing of rosin to produce various products. Over 250 products are produced from the above-referenced operations and include: modified resins, polyamides, ketene dimer, crude tall oil wax emulsions, and synthetic rubber. Structures at the facility include offices, laboratories, powerhouses, wastewater treatment plant, settling ponds, landfills, and central loading and packaging areas.

The facility is classified as a major source as defined in section 112(a) of the Clean Air Act based on emissions of Hazardous Air Pollutants (HAPs), and is, therefore, subject to regulation under 40 CFR 63 Subpart W (National Emission Standards for Hazardous Air Pollutants for Epoxy Resins Production and Non-Nylon Polyamides Production). Specifically, Hercules stores and uses Epichlorohydrin (a HAP) in the Kymene process. Therefore, in accordance with 40 CFR 63 Subpart W, all process equipment that is in organic HAP service must be monitored for leaks and repaired as defined in Subpart W and Subpart H of 40 CFR 63.524 through 63.528 and 63.160 through 63.182. Process equipment is considered to be in organic HAP service if that equipment either contains or contacts a fluid (liquid or gas) that is at least 5 percent by weight of the designated organic HAP (i.e., Epichlorohydrin).

Hercules is utilizing the services of *Eco-Systems, Inc. (Eco-Systems)* to assist in implementing the Leak Detection and Repair (LDAR) program for the Epichlorohydrin process. *Eco-Systems*, utilizing tags previously placed on affected components, screened each applicable piece of equipment on January 14, 1999 (see Table 1). This report contains information on the scope of work, methodology, results (Section 2.0), and conclusions (Section 3.0).

## **2.0 SCOPE OF WORK, METHODOLOGY, AND RESULTS**

---

### **2.1 Leak Criteria**

Prior to initiating screening activities, *Eco-Systems* identified the “leak criteria” for each type of equipment potentially screened. At Hercules’ request, each source was screened for leaks based on Phase II criteria outlined in 40 CFR 63. In accordance with 40 CFR 63.162, sources in the Kymene process that met the following criteria were not screened:

- Equipment not in organic HAP service;
- Equipment in vacuum service; and
- Equipment that is in organic HAP service less than 300 hours per calendar year;

### **2.2 Equipment Used and Testing Methodology**

After identifying each source to be screened, Method 21 was followed to screen equipment for leaks in accordance with the regulations. A Thermo-Environmental 680 flame ionization detector (FID) was used to screen a total of 370 sources. Attachment I presents information and specifications for the FID which meets the criteria for Method 21 specified in 40 CFR 60 Appendix A and has the following specifications:

- Response time of approximately 2 seconds for 90% of final reading;
- Response factor of 2.1 for Epichlorohydrin; and
- Calibration accuracy of  $\pm 10\%$ , for a range of 1-10,000 ppm.

Prior to beginning screening activities, the FID was assembled, started and calibrated with a 10 ppmv and a 10,000 ppmv methane in air mixture. Screening of individual components were conducted in accordance with 40 CFR 60 Appendix A, Method 21, Section 4.3 Individual Source Surveys. Background readings were noted for each area and subtracted from the FID reading for each applicable source screened.

### **2.3 Monitoring Results**

Screening results along with other pertinent information are presented in Table 1. One source (a connector) was identified as leaking:

- Tag # 0022.00 - Located in the Epichlorohydrin loading area near Pump 0001.00.

The leaking source was identified with a weatherproof and readily visible tag indicating that the component was leaking and required repair. Hercules personnel were notified of the leaking component so that repair activities could be initiated.

***Hercules, Inc.***  
***Hattiesburg, Mississippi***



During screening activities, the presence of visual leaks (i.e., liquid visibly dripping from a connection or seal) was noted for each component. No visual leaks were identified for the components screened.

To satisfy the requirements of 40 CFR 63.162(c) and as part of this scope of work, *Eco-Systems* has identified all sources subject to 40 CFR 63 and has distinguished those sources from sources that are not subject to 40 CFR 63.



**Hercules, Inc.**  
**Hattiesburg, Mississippi**



### **3.0 CONCLUSION**

---

Based on the screening results, one (1) leaking unit (a connector) was identified: component # 0022.00. During the next scheduled monitoring event (mid-February, 1999) and upon repair of the leaking component, *Eco-Systems* will perform follow-up monitoring in accordance with the regulations to confirm successful repair of the leaking unit.

**TABLE 1**  
LDAR Screening Results

**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0001.00	Pump	Epichlorohydrin	Truck Loading	1/14/99	9.4
0001.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0001.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0002.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0003.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0004.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0005.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	32.0
0006.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0006.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0007.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0008.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0009.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0010.01	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0010.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0010.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0011.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0012.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0013.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0014.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.04	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.05	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.06	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.07	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.08	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.09	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.10	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.11	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.12	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.13	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.14	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.15	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.16	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0016.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0017.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0018.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0019.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	20.5
0020.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0

**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0021.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.04	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0022.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	> 500.0
0023.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0024.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0025.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0025.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0025.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0025.03	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.04	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.05	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.06	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.07	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.08	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.09	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.10	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.11	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.12	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0026.00	Pump	Epichlorohydrin	Truck Loading	1/14/99	0.0
0027.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0028.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0028.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0028.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0029.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0030.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0031.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0032.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.04	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.05	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.06	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.07	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0034.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0035.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	10.7
0035.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0035.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0035.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0

**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0036.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0037.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0038.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0039.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0040.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0040.01	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0040.02	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0040.03	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0041.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0042.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0042.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0042.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0043.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0043.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0043.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0044.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.03	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.04	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.05	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.06	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0046.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0046.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0046.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.03	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.04	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.05	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.06	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.07	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.08	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0048.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0049.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0050.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0051.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0052.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0053.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0054.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0

**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0055.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0056.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0057.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0058.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0059.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0059.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0059.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0060.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0061.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0062.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0063.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0063.01	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.02	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.03	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.04	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.05	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.06	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.07	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.08	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.09	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.10	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0064.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.03	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.04	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.06	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0065.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0066.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0067.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0067.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0067.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0068.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0069.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0070.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0071.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0071.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0071.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0072.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0073.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0073.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0073.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0



**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0074.00	Valve	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0074.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0074.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0075.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0076.00	Valve	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0077.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0078.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.02	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.02	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.04	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.05	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.06	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.07	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.08	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0078.09	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0079.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0079.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0079.02	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0080.00	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0080.01	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0080.02	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0080.03	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0080.04	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0080.05	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0081.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0082.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0082.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0083.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0084.00	Valve	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0085.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0086.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0087.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0088.00	Valve	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0089.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0090.00	Valve	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0091.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0091.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0092.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0093.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0093.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0093.02	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0

**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0094.00	Connector	Epichlorohydrin	1st Lvl-Wicgh Tks	1/14/99	0.0
0095.00	Connector	Epichlorohydrin	1st Lvl-Wicgh Tks	1/14/99	0.0
0096.00	Connector	Epichlorohydrin	1st Lvl-Wicgh Tks	1/14/99	0.0
0097.00	Valve	Epichlorohydrin	1st Lvl-Wicgh Tks	1/14/99	0.0
0098.00	Connector	Epichlorohydrin	1st Lvl-Wicgh Tks	1/14/99	0.0
0099.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0100.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0101.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0102.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0103.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0104.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0105.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0106.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0107.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0108.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0109.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0110.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0111.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0112.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0113.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0114.00	Connector	Epichlorohydrin	Grd Level-R401	1/14/99	0.0
0115.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0116.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0117.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0118.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0119.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0120.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0120.01	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0121.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0122.00	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.01	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.02	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.03	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.04	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.05	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.06	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.00	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.01	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.02	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.03	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.00	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.01	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0



**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0124.02	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.03	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.04	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.05	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.06	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.07	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0125.00	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0126.00	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0127.00	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0156.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0157.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0157.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0158.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0159.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0160.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0160.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0160.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0160.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0161.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0161.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0161.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0162.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0163.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0165.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0165.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0165.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0166.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0166.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0166.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0167.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0167.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0167.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0168.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0168.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0168.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0

**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0169.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.04	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0172.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0172.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0172.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0173.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0173.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0173.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0174.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0174.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0174.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0175.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0175.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0175.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0176.00	Agitator	Epichlorohydrin	Top of R-401	1/14/99	0.0
0177.00	Pump	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.02	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.03	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.04	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.05	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0178.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0178.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0178.02	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0179.00	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0179.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.00	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.02	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.03	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0181.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0181.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0182.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0183.00	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0

**Table 1**  
**Epichlorohydrin Screening Results - January, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0183.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0184.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0184.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0185.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0185.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0186.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0187.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0188.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0189.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0189.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0189.02	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0189.03	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0189.04	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.02	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.03	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.04	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0191.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0191.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.02	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.03	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0193.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0193.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0194.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0194.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0195.00	Valve	Epichlorohydrin	Tank Farm - A408	1/14/99	0.0
0196.00	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0
0196.01	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0
0196.02	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0
0196.03	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0

**Table 1a**  
**Epichlorohydrin Screening Results - Agitators**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0176.00	Agitator	Epichlorohydrin	Top of R-401	1/14/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0001.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0001.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0002.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0003.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0005.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	32.0
0006.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0006.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0007.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0008.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0009.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0010.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0010.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0011.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0012.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0014.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.04	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.05	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.06	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.07	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.08	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.09	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.10	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.11	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.12	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.13	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.15	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.16	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0016.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0018.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0019.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	20.5
0021.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0021.04	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0022.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	> 500.0
0024.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0025.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0025.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0

**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0025.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0025.03	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.04	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.05	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.06	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.07	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.08	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.09	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.10	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.11	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0025.12	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0027.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0028.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0028.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0029.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0031.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0032.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.04	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.05	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.06	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0033.07	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0034.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0035.01	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0035.02	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0035.03	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0036.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0038.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0039.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0040.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0040.01	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0040.02	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0040.03	Connector	Epichlorohydrin	Line from Loading	1/14/99	0.0
0041.00	Connector	Epichlorohydrin	Truck Loading	1/14/99	0.0
0042.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0042.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0042.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0043.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0043.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0



**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0043.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0044.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.03	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.04	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.05	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0045.06	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0046.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0046.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0046.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.03	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.04	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.05	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.06	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.07	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0047.08	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0048.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0050.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0051.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0053.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0054.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0055.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0057.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0058.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0059.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0059.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0060.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0061.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0062.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0063.00	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0063.01	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.02	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.03	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.04	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.05	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.06	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.07	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0

**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0063.08	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.09	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0063.10	Connector	Epichlorohydrin	Line from K-110	1/14/99	0.0
0064.01	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.02	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.03	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.04	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.06	Connector	Epichlorohydrin	EPI Storage	1/14/99	0.0
0065.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0066.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0067.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0067.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0067.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0068.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0069.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0070.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0071.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0071.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0071.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0072.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0073.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0073.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0073.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0074.01	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0074.02	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0075.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0077.00	Connector	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0078.00	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.01	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.02	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.02	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.04	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.05	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.06	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.07	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.08	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0078.09	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0079.00	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0079.01	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0079.02	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0080.00	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0080.01	Connector	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0



**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0080.02	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0080.03	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0080.04	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0080.05	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0081.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0082.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0082.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0083.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0085.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0086.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0087.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0089.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0091.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0091.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0092.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0093.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0093.01	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0093.02	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0094.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0095.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0096.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0098.00	Connector	Epichlorohydrin	1st Lvl-Wiegh Tks	1/14/99	0.0
0099.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0100.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0102.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0104.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0106.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0107.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0109.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0110.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0112.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0113.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0114.00	Connector	Epichlorohydrin	Grd Level-R401	1/14/99	0.0
0115.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0117.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0118.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0120.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0120.01	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0121.00	Connector	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0122.01	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.02	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.03	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0

**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0122.04	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.05	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0122.06	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.01	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.02	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.03	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.00	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.01	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.02	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.03	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.04	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.06	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.07	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0126.00	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0127.00	Connector	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0156.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0157.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0157.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0158.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0159.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0160.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0160.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0160.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0161.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0161.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0162.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0163.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0165.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0165.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0165.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0166.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0166.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0166.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0167.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0167.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0168.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0168.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0

**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0169.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.04	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.03	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0172.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0172.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0173.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0173.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0174.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0174.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0175.00	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0175.01	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0175.02	Connector	Epichlorohydrin	Top of R-401	1/14/99	0.0
0177.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.02	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.03	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.04	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0177.05	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0178.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0178.02	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0179.00	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0179.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.00	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.02	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0180.03	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0181.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0183.00	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0183.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0184.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0185.01	Connector	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0189.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0189.02	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0189.03	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0189.04	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.02	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.03	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0

**Table 1b**  
**Epichlorohydrin Screening Results - Connectors**  
 Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0190.04	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0191.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.02	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.03	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0193.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0194.01	Connector	Epichlorohydrin	Near P-401	1/14/99	0.0
0196.00	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0
0196.01	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0
0196.02	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0
0196.03	Connector	Epichlorohydrin	Top of K-110	1/14/99	0.0
<b>Percent Leakers</b>					<b>0.33%</b>

**Table 1c**  
**Epichlorohydrin Screening Results - Valves**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0004.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0010.01	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0013.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0015.14	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0017.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0020.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0023.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0028.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0030.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0035.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	10.7
0037.00	Valve	Epichlorohydrin	Truck Loading	1/14/99	0.0
0049.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0052.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0056.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0059.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0064.00	Valve	Epichlorohydrin	EPI Storage	1/14/99	0.0
0074.00	Valve	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0076.00	Valve	Epichlorohydrin	2nd Lvl-Weigh Tks	1/14/99	0.0
0084.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0088.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0090.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0097.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	1/14/99	0.0
0101.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0103.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0105.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0108.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0111.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0116.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0119.00	Valve	Epichlorohydrin	Grd Level-R-401	1/14/99	0.0
0122.00	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0123.00	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0124.05	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0125.00	Valve	Epichlorohydrin	Loading St. - N Side	1/14/99	0.0
0160.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0161.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0164.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0167.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0168.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0169.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0170.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0171.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0

**Table 1c**  
**Epichlorohydrin Screening Results - Valves**  
 Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0172.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0173.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0174.00	Valve	Epichlorohydrin	Top of R-401	1/14/99	0.0
0178.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0181.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0182.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0184.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0185.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0186.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0187.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0188.00	Valve	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
0189.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0190.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0191.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0192.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0193.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0194.00	Valve	Epichlorohydrin	Near P-401	1/14/99	0.0
0195.00	Valve	Epichlorohydrin	Tank Farm - A408	1/14/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**Table 1d**  
**Epichlorohydrin Screening Results - Pumps**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0001.00	Pump	Epichlorohydrin	Truck Loading	1/14/99	9.4
0026.00	Pump	Epichlorohydrin	Truck Loading	1/14/99	0.0
0177.00	Pump	Epichlorohydrin	Bottom of R-401	1/14/99	0.0
<b>Percent Leakers</b>					<b>0%</b>




## **ATTACHMENT I**

### **Foxboro 108 Flame Ionization Detector Information and Specifications**



# MODEL 680


## PORTABLE HYDROCARBON VAPOR METER



### Advanced Technology For Applications In:

- EPA Method 21 Compliance Testing
- Fugitive Emissions Monitoring
- Detection of Soil and Water Contaminants
- Leaking Underground Storage Tank Monitoring
- Industrial Hygiene Monitoring
- New Features for 1995:
  - New and Improved Laser Scanner
  - Bar Code Editing
  - Optional 512K Memory Expansion
  - Additional Database Interfaces
  - On Demand Detector Purge

## KEY DESIGN FEATURES



\* New and Improved for 1995

## ADVANCED TECHNOLOGY

The Model 680 Hydrocarbon Vapor Meter (HVM) microprocessor based design offers capabilities previously unavailable with portable flame ionization instrumentation, including, system diagnostics (check-out) upon power-up, bidirectional RS-232 communications, maximum concentration hold, Time Weighted Averaging (TWA) report capability and auto-ranging over the entire 0-20,000 ppm concentration range.

However, the technological advances within this state-of-the-art design does not end here. Thermo Environmental Instruments engineers implemented an interchangeable battery assembly resulting in extended field

operation and pressure transducer technology for monitoring hydrogen flow status and operating time indication.

The user programmable software capabilities entail response factor settability, self-calibration adjustment, storage of up to 10 calibrations in memory, and automatic data logging of up to 4000 sample readings by time, date, concentration value, location code.

Additionally, the Model 680 HVM is an ergonomic success with its pistol grip display gun and light-weight sidepack layout. This will result in increased field comfort for all types of operators.

# A Truly Portable, Truly Integrated, Intrinsically Safe FUGITIVE EMISSIONS MONITORING SYSTEM

The regulations to be promulgated by the Environmental Protection Agency in support of the Clean Air Act Amendments of 1990 impose stringent demands on process component leak measurement and management.

Existing Fugitive Emissions Monitoring technologies are labor intensive, suffer from erroneous interpretation of data, utilize manual reporting techniques, or require one to be an octopus to operate the system components effectively.

The Model 680 HVM utilizes an integrated system approach which incorporates the flame-ionization detector assembly, data logger, and bar code scanning device into a single sidepack/hand-held gun package. This integrated system addresses the shortcomings of past technologies while providing fugitive emissions monitoring personnel with enhanced capabilities including:


- Integral manual or automatic logging of up to 4000 individual data points by location code, time, date and sample concentration.
- Lock-in of maximum concentration reading. This is useful in isolating or pin-pointing the source of a gaseous chemical leak.
- Increased operator safety via an intrinsically safe design which includes the laser based bar code reading device. The Model 680 HVM is Factory Mutual (FM) certified for use in Class I, Division 1 Groups A, B, C, D hazardous locations.

Leak Detection and Repair (LDAR) programs require extensive documentation and follow-up. The Model 680 HVM addresses LDAR requirements via its ROUTE VIEW function which is illustrated in the flow diagram below. As a self-contained fugitive emissions monitoring system, the Model 680 HVM improves LDAR management efficiency by offering:

- Reread capability for situations in which an exceedance (violation) measurement is encountered and subsequent repair attempted.
- Report identification of any missed component tags.
- Ability to measure and record a background measurement which can subsequently be automatically subtracted from the fugitive emission measurement.
- Ability to generate process component leak reports.


Additionally, via bidirectional RS-232 communications, the Model 680 HVM interfaces directly with several commercially available fugitive emission data base computer software systems. This combination results in the ultimate utilization of the Model 680 HVM microprocessor capabilities by allowing LDAR personnel to download a pre-programmed survey route from a personal computer to the 680. Subsequently, the Model 680 will guide the operator through the designated leak survey route. Please contact us for database software compatibility.

## ROUTE VIEW FUNCTION



## Customized Liquid Crystal Display

- Digital & Graphical Sample Concentration Level
- Maximum Concentration Signal Hold
- Alarm Exceedance Indication
- Low Battery Warning
- Low Hydrogen Warning
- Flame Status



## Specifications

### Measurement:

Technique:	Flame Ionization Detection (FID) of most organic vapors. Note that sample also serves as source of combustion air.
Ranges:	Liquid Crystal Display (LCD) - Auto ranging over entire 0-20,000ppm concentration range. Displayed concentration reading resolution as follows: 0-100ppm (resolution to 0.1ppm) 0-20,000ppm (resolution to 1.0ppm)
Minimum Detectable:	0.5ppm methane in air matrix
Sensitivity:	0.1ppm methane
System Time Constant:	4.0 seconds at 800ml/min sample flow (10.0% to 90.0% of final reading)
Sampling Rate:	800ml/min
Sample Conditioning:	Changeable Teflon filter which also functions as water trap

### Power Requirements:

Battery:	Internally rechargeable (external charger provided with unit.)
Service Life:	Ten hours per internal battery charge, operates from charger indefinitely. Battery is interchangeable. Therefore, battery based operation can be extended indefinitely.
Charger Requirements:	115/220 VAC, 50Hz

### Controls, Panel:

Readout:	Highly visible (0.4"H x 0.2"W) seven (7) segment concentration readout; 2 line by 17 character message display; 1 line by 17 character key function display; calibrated bar graph; symbolic status messages including flame out/fit, low battery charge, low H <sub>2</sub> pressure and concentration level exceedance. Current time and date also available for display.
Keypad:	Three keys control instrument software functions. Keys offer tactile feedback with current function displayed at all times.

### Gases:

Combustion Air:	Provided by sample at a flow rate of 800 ml/min.
Hydrogen:	Provided by refillable internal cylinder. 1800 psig capacity offers 14 hours operation. H <sub>2</sub> flow is 13 ml/min.

### Physical Dimensions:

Case Size:	HWD 12.5 x 11.5 x 2.6 inches
Weight:	Side Pack - 10.5 lbs; Gun - 12 oz.

### Communication:

- 9 Pin RS-232 Port
- 0 - 1V Analog Signal

### Approvals:

Factory Mutual (FM) Class I, Division 1, Groups A, B, C, D  
CENELEC EEx ib d IIC T4

### Patents:

Covered by U.S. Patent 5,356,594

For Price and Delivery Information, Contact:

**TE** *Thermo Environmental  
Instruments Inc.*

Thermo Electron Ltd., 910 Birchwood Blvd., Warrington, Cheshire, WA3 7QN, ENGLAND / Telephone: 0925 / 813600

Thermo Instrument Systems, GMBH, Martenerstrasse 539, 4600 Dortmund 70, WEST GERMANY / Telephone :231 / 6170 78

ThS Analytical B.V., Heerbaan 220, 4817 Breda, HOLLAND / Telephone: 76 / 713717

Thermo Instrument Systems, Spinnerslaan 2A, Lokeren, BELGIUM / Telephone: 93/485841

8 West Forge Parkway  
Franklin, MA 02038

(508) 520-0430

FAX: (508) 520-1460

# **Eco-Systems, Inc.**

Consultants, Engineers and Scientists



March 8, 1999

Mr. Charles Jordan  
Environmental Supervisor  
Hercules, Inc.  
P.O. Box 1937  
Hattiesburg, Mississippi 39403-1937

**Re: Environmental Engineering/Consulting Services  
Leak Detection and Repair  
Kymene Process**

Dear Mr. Jordan:

*Eco-Systems* appreciates the opportunity to again provide services to Hercules, Inc. We performed monthly Leak Detection Monitoring services on the affected pumps and agitator of the Kymene process on February 25, 1999. A total of three (3) pumps and one (1) agitator were identified during the initial event in January, 1999. No unit was identified as leaking. A leaking pump is defined in this case as one which has a vapor emission of greater than 5,000 parts per million (ppm). All applicable pumps were tested using a Thermo Environmental Model 680B organic vapor meter. Results of these tests are shown on Table 1 and Table 2 (attached). This report may be placed in the previously provided binder in the First Quarter, 1999 section. Please do not hesitate to contact us at (601) 936-4440 should you have any questions.

Sincerely,  
*Eco-Systems, Inc.*

Wade Steinriede  
Staff Scientist

Jeffrey L. Allen, P.E.  
Senior Engineer

Enclosures

**Table 1**  
**Epichlorohydrin Screening Results - Pumps**  
**February, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0001.00	Pump	Epichlorohydrin	Truck Loading	2/25/99	0.0
0026.00	Pump	Epichlorohydrin	Truck Loading	2/25/99	0.0
0177.00	Pump	Epichlorohydrin	Bottom of R-401	2/25/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**Table 2**  
**Epichlorohydrin Screening Results - Agitators**  
**February, 1999**  
Hercules, Inc.



Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0176.00	Agitator	Epichlorohydrin	Top of R-401	2/25/99	0.0
<b>Percent Leakers</b>					<b>0%</b>



**Eco-Systems, Inc.**  
Consultants, Engineers and Scientists



April 19, 1999

Mr. Charles Jordan  
Environmental Supervisor  
Hercules, Inc.  
P.O. Box 1937  
Hattiesburg, Mississippi 39403-1937

**Re: Environmental Engineering/Consulting Services  
Leak Detection and Repair  
Kymene Process**

Dear Mr. Jordan:

*Eco-Systems* appreciates the opportunity to again provide services to Hercules, Inc. We performed monthly Leak Detection Monitoring services on the affected pumps and agitator of the Kymene process on March 25, 1999. A total of three (3) pumps and one (1) agitator were identified during the initial event in January, 1999. No unit was identified as leaking. A leaking pump is defined in this case as one which has a vapor emission of greater than 5,000 parts per million (ppm). All applicable components were tested using a Thermo Environmental Model 680B organic vapor meter. Results of these tests are shown on Table 1 and Table 2 (attached). This report may be placed in the previously provided binder in the First Quarter, 1999 section. The next monitoring event is tentatively scheduled for mid-April, 1999.

*Eco-Systems* appreciates providing environmental assistance to Hercules. Please do not hesitate to contact us at (601) 936-4440 should you have any questions.

Sincerely,  
*Eco-Systems, Inc.*

Wade Steinriede  
Staff Scientist

Evan M. Tullos  
Project Scientist

Enclosures





**Table 1**  
**Epichlorohydrin Screening Results - Pumps**  
**March, 1999**  
Hercules, Inc.

<b>Tag ID</b>	<b>Component Type</b>	<b>Chemical Stream</b>	<b>Location</b>	<b>Screen Date</b>	<b>Screen Reading (ppm)</b>
0001.00	Pump	Epichlorohydrin	Truck Loading	3/25/99	0.0
0026.00	Pump	Epichlorohydrin	Truck Loading	3/25/99	0.0
0177.00	Pump	Epichlorohydrin	Bottom of R-401	3/25/99	0.0
<b>Percent Leakers</b>					<b>0%</b>



**Table 2**  
**Epichlorohydrin Screening Results - Agitators**  
**March, 1999**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0176.00	Agitator	Epichlorohydrin	Top of R-401	3/25/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**INSTRUMENT CALIBRATION**

Methane Mix	Initial Reading	Final Reading
0 (air)	1.4	0.06
95 ppmv	98.2	94.7
980 ppmv	932	978

**Calibration Check**

Methane Mix	Reading	Percent
95 ppmv	95.2	100%

# **Eco-Systems, Inc.**

Consultants, Engineers and Scientists



May 6, 1999

Mr. Charles Jordan  
Environmental Supervisor  
Hercules, Inc.  
P.O. Box 1937  
Hattiesburg, Mississippi 39403-1937

**Re: *Environmental Engineering/Consulting Services***  
***Leak Detection and Repair***  
***Kymene Process***

Dear Mr. Jordan:

*Eco-Systems* appreciates the opportunity to again provide services to Hercules, Inc. We performed monthly Leak Detection Monitoring services on the affected pumps and agitator of the Kymene process on April 14, 1999. A total of three (3) pumps and one (1) agitator were identified during the initial event in January, 1999. No unit was identified as leaking. A leaking pump is defined in this case as one which has a vapor emission of greater than 5,000 parts per million (ppm). All applicable components were tested using a Thermo Environmental Model 680B organic vapor meter. Results of these tests are shown on Table 1 and Table 2 (attached). This report may be placed in the previously provided binder in the Second Quarter, 1999 section. The next monitoring event is tentatively scheduled for mid-May, 1999.

*Eco-Systems* appreciates providing environmental assistance to Hercules. Please do not hesitate to contact us at (601) 936-4440 should you have any questions.

Sincerely,  
*Eco-Systems, Inc.*

Wade Steinriede  
Staff Scientist

Evan M. Tullos  
Project Scientist

Enclosures



**Table 1**  
**Epichlorohydrin Screening Results - Pumps**  
**April, 1999**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0001.00	Pump	Epichlorohydrin	Truck Loading	4/14/99	0.0
0026.00	Pump	Epichlorohydrin	Truck Loading	4/14/99	0.0
0177.00	Pump	Epichlorohydrin	Bottom of R-401	4/14/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**INSTRUMENT CALIBRATION**

Methane Mix	Initial Reading	Final Reading
0 (air)	3.5	-1.5
95 ppmv	100	95.2
980 ppmv	958	972

**Calibration Check**

Methane Mix	Reading	Percent
95 ppmv	95.9	101%



**Table 2**  
**Epichlorohydrin Screening Results - Agitators**  
**April, 1999**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0176.00	Agitator	Epichlorohydrin	Top of R-401	4/14/99	0.0
<b>Percent Leakers</b>					<b>0%</b>



**Table 1**  
**Epichlorohydrin Screening Results - Pumps**  
**May, 1999**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0001.00	Pump	Epichlorohydrin	Truck Loading	5/25/99	0.0
0026.00	Pump	Epichlorohydrin	Truck Loading	5/25/99	0.0
0177.00	Pump	Epichlorohydrin	Bottom of R-401	5/25/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**INSTRUMENT CALIBRATION**

Methane Mix	Initial Reading	Final Reading
0 (air)	2.7	0
95 ppmv	108	96
980 ppmv	1150	980

**Calibration Check**

Methane Mix	Reading	Percent
95 ppmv	95	100%



**Table 2**  
**Epichlorohydrin Screening Results - Agitators**  
**May, 1999**  
Hercules, Inc.

<b>Tag ID</b>	<b>Component Type</b>	<b>Chemical Stream</b>	<b>Location</b>	<b>Screen Date</b>	<b>Screen Reading (ppm)</b>
0176.00	Agitator	Epichlorohydrin	Top of R-401	5/25/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

# Eco-Systems, Inc.

Consultants, Engineers and Scientists



July 1, 1999

Mr. Charles Jordan  
Environmental Supervisor  
Hercules, Inc.  
P.O. Box 1937  
Hattiesburg, Mississippi 39403-1937

COPY

**Re: Environmental Engineering/Consulting Services  
Quarterly Leak Detection Monitoring for Valves,  
and Monthly for Pumps, Kymene Process**

Dear Mr. Jordan:

*Eco-Systems* appreciates the opportunity to again provide services to Hercules, Inc. We performed quarterly leak detection services on the affected valves in the Kymene process and monthly monitoring on the pumps in the Kymene process on June 28, 1999. A total of 60 valves, three (3) pumps, and one (1) agitator were identified during the initial event in January, 1999. A leaking valve in this case is one which has an organic vapor emission of greater than 500 parts per million (ppm) and/or a visible leak. A leaking pump or agitator is one which has an organic vapor emission of greater than 5,000 ppm or 10,000 ppm, respectively. All applicable components were tested by *Eco-Systems* using a Thermo Environmental Model 680 organic vapor meter and no leaking units were discovered. Results of these tests are shown on the attached tables.

*Eco-Systems* will contact Hercules concerning timing of the next monitoring event tentatively scheduled for mid-July, 1999. *Eco-Systems* appreciates the opportunity to provide environmental assistance to Hercules. Please do not hesitate to contact us at (601) 936-4440 should you have any questions.

Sincerely,  
*Eco Systems, Inc.*

Wade Steinriede  
Staff Scientist

Evan Tullos  
Project Scientist

Attachment



**Table 1a**  
**Epichlorohydrin Screening Results for June, 1999 - Valves**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0004.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0010.01	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0013.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0015.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0015.14	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0017.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0020.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0023.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0028.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0030.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0035.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0037.00	Valve	Epichlorohydrin	Truck Loading	6/28/99	0.0
0049.00	Valve	Epichlorohydrin	EPI Storage	6/28/99	0.0
0052.00	Valve	Epichlorohydrin	EPI Storage	6/28/99	0.0
0056.00	Valve	Epichlorohydrin	EPI Storage	6/28/99	0.0
0059.00	Valve	Epichlorohydrin	EPI Storage	6/28/99	0.0
0064.00	Valve	Epichlorohydrin	EPI Storage	6/28/99	0.0
0074.00	Valve	Epichlorohydrin	2nd Lvl-Weigh Tks	6/28/99	0.0
0076.00	Valve	Epichlorohydrin	2nd Lvl-Weigh Tks	6/28/99	0.0
0084.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	6/28/99	0.0
0088.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	6/28/99	0.0
0090.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	6/28/99	0.0
0097.00	Valve	Epichlorohydrin	1st Lvl-Weigh Tks	6/28/99	0.0
0101.00	Valve	Epichlorohydrin	Grd Level-R-401	6/28/99	0.0
0103.00	Valve	Epichlorohydrin	Grd Level-R-401	6/28/99	0.0
0105.00	Valve	Epichlorohydrin	Grd Level-R-401	6/28/99	0.0
0108.00	Valve	Epichlorohydrin	Grd Level-R-401	6/28/99	0.0
0111.00	Valve	Epichlorohydrin	Grd Level-R-401	6/28/99	0.0
0116.00	Valve	Epichlorohydrin	Grd Level-R-401	6/28/99	0.0
0119.00	Valve	Epichlorohydrin	Grd Level-R-401	6/28/99	0.0
0122.00	Valve	Epichlorohydrin	Loading St. - N Side	6/28/99	0.0
0123.00	Valve	Epichlorohydrin	Loading St. - N Side	6/28/99	0.0
0124.05	Valve	Epichlorohydrin	Loading St. - N Side	6/28/99	0.0
0125.00	Valve	Epichlorohydrin	Loading St. - N Side	6/28/99	0.0
0160.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0161.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0164.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0167.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0168.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0169.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0170.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0171.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0

**Table 1a**  
**Epichlorohydrin Screening Results for June, 1999 - Valves**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0172.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0173.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0174.00	Valve	Epichlorohydrin	Top of R-401	6/28/99	0.0
0178.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0181.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0182.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0184.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0185.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0186.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0187.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0188.00	Valve	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
0189.00	Valve	Epichlorohydrin	Near P-401	6/28/99	0.0
0190.00	Valve	Epichlorohydrin	Near P-401	6/28/99	0.0
0191.00	Valve	Epichlorohydrin	Near P-401	6/28/99	0.0
0192.00	Valve	Epichlorohydrin	Near P-401	6/28/99	0.0
0193.00	Valve	Epichlorohydrin	Near P-401	6/28/99	0.0
0194.00	Valve	Epichlorohydrin	Near P-401	6/28/99	0.0
0195.00	Valve	Epichlorohydrin	Tank Farm - A408	6/28/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**Table 1b**  
**Epichlorohydrin Screening Results for June, 1999 - Agitators**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0176.00	Agitator	Epichlorohydrin	Top of R-401	6/28/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**Table 1c**  
**Epichlorohydrin Screening Results for June, 1999 - Pumps**  
Hercules, Inc.

Tag ID	Component Type	Chemical Stream	Location	Screen Date	Screen Reading (ppm)
0001.00	Pump	Epichlorohydrin	Truck Loading	6/28/99	0.0
0026.00	Pump	Epichlorohydrin	Truck Loading	6/28/99	0.0
0177.00	Pump	Epichlorohydrin	Bottom of R-401	6/28/99	0.0
<b>Percent Leakers</b>					<b>0%</b>

**INSTRUMENT CALIBRATION**

Methane Mix	Initial Reading	Final Reading
0 (air)	3.2	0
95 ppmv	101	95.4
980 ppmv	1122	1002

**Calibration Check**

Methane Mix	Reading	Percent
95 ppmv	97.2	102.3%



Koch Gateway Pipeline Company  
 DETAIL METER STATEMENT  
 FOR THE MONTH OF 06/99

07/08/99 19:17:54  
 PAGE 4

METER ID: 002520-01  
 LOCATION: HATTIESBURG CITY GATE #1  
 TYPE METER: EFM Orifice

SYSTEM: 007:Mississippi  
 SUBSYSTEM: 014:Jackson to Leaksville 16" & 8"  
 PURPOSE: Koch Custody Delivery

CONTRACT TIME: 09:00  
 ANALYST: Matthews, Lloia  
 PHONE #: 5044695903

METER INFORMATION										
EFFECTIVE DATE	REF NUM	STATIC RANGE	DIFF RANGE	TUBE SIZE	PLATE SIZE	TAP TYPE	TAP LOCA	CHART DAYS	MACHINE CONSTANT	CALC TYPE
06/01/99	1	500	100	8.072	3.250	P	U	1	1.0000	14

VOLUME INFORMATION											
DAY ON	DAY OFF	REF NUM	FLOW EXTENT	FLOW HOURS	TEMP	PRES PSIA	DIFF	SPEC GRAV	MCF VOLUME @ 14.730	BTU(A)	Dth
1	2	1	18	24.0	61.9	112.5	2.9	0.6017	1323	1016.3000	1345
2	3	2	17	24.0	63.1	112.8	2.6	0.6017	1260	1016.3000	1281
3	4	3	17	24.0	63.7	112.8	2.7	0.6017	1275	1016.3000	1296
4	5	4	16	24.0	64.8	112.9	2.3	0.6017	1164	1016.3000	1183
5	6	5	16	24.0	65.2	112.9	2.0	0.6017	1101	1016.3000	1119
6	7	6	16	24.0	63.6	112.7	2.4	0.6017	1216	1016.3000	1236
7	8	7	18	24.0	62.8	112.7	3.0	0.6017	1347	1016.3000	1369
8	9	8	18	24.0	62.5	112.4	3.0	0.6017	1349	1016.3000	1371
9	10	9	18	24.0	63.9	112.4	3.1	0.6017	1366	1016.3000	1388
10	11	10	19	24.0	63.3	112.4	3.3	0.6017	1408	1016.3000	1431
11	12	11	18	24.0	62.1	112.4	3.1	0.6017	1374	1016.3000	1396
12	13	12	17	24.0	63.1	112.5	2.7	0.6017	1282	1016.3000	1303
13	14	13	17	24.0	63.4	112.4	2.8	0.6017	1295	1016.3000	1316
14	15	14	19	24.0	63.6	112.4	3.3	0.6017	1413	1016.3000	1436
15	16	15	19	24.0	62.4	112.3	3.4	0.6017	1430	1016.3000	1453
16	17	16	19	24.0	62.2	112.2	3.5	0.6017	1451	1016.3000	1475
17	18	17	20	24.0	61.5	112.3	3.8	0.6017	1522	1016.3000	1547
18	19	18	20	24.0	60.6	112.3	3.5	0.6017	1472	1016.3000	1496
19	20	19	18	24.0	61.7	112.3	2.9	0.6017	1332	1016.3000	1354
20	21	20	18	24.0	62.3	112.4	2.9	0.6017	1313	1016.3000	1334
21	22	21	19	24.0	65.1	112.4	3.2	0.6017	1403	1016.3000	1426
22	23	22	20	24.0	64.2	112.2	3.6	0.6017	1469	1016.3000	1493
23	24	23	19	24.0	65.5	112.3	3.1	0.6017	1384	1016.3000	1407
24	25	24	18	24.0	66.5	112.3	3.0	0.6017	1338	1016.3000	1360
25	26	25	18	24.0	65.0	112.2	3.1	0.6017	1370	1016.3000	1392
26	27	26	17	24.0	65.8	112.2	2.8	0.6017	1302	1016.3000	1323
27	28	27	16	24.0	68.6	112.4	2.3	0.6017	1169	1016.3000	1188
28	29	28	17	24.0	69.3	112.2	2.7	0.6017	1255	1016.3000	1275
29	30	29	17	24.0	67.7	112.2	3.0	0.6017	1266	1016.3000	1287
30	1	30	15	24.0	69.3	112.4	2.2	0.6017	1132	1016.3000	1150
Total									39781		40430

GAS QUALITY INFORMATION													
EFFECTIVE DATE	SAMPLE TYPE	WATER CONTENT	N2	CO2	H2S	C1	C2	C3	IC4	NC4	105	NC5	C6+
06/01/99	C	9.6	1.1550	2.0400	0.0000	94.7810	1.0770	0.3020	0.0940	0.1240	0.0630	0.0700	0.2940

### EMISSION POINT AC-004 (MELTER)

Report Period:  
Jan.- June, 1999

Note: No activity on those dates not shown.

DATE	# HOURS	# DRUMS	TOTAL LBS.	TONS/HR.
12/29/98	16	87	45155	1.349
1/5/99	8	42	20833	1.302
1/6/99	16	130	64435	2.015
1/7/99	16	120	59524	1.860
1/8/99	16	116	57540	1.798
1/9/99	16	100	49604	1.550
1/11/99	16	112	55556	1.736
1/12/99	16	58	28770	0.899
1/13/99	16	93	46131	1.442
1/14/99	16	80	39683	1.240
1/19/99	8	40	19841	1.240
1/20/99	8	30	14881	0.930
1/22/99	8	50	24802	1.550
3/16/99	16	102	50596	1.581
3/17/99	16	125	62004	1.938
3/18/99	16	120	59524	1.860
3/19/99	16	120	59524	1.860
3/20/99	16	120	59524	1.860

**EMISSION POINT AC-004 (MELTER)****Report Period:  
Jan.- June, 1999****Note: No activity on those dates not shown.**

<b>DATE</b>	<b># HOURS</b>	<b># DRUMS</b>	<b>TOTAL LBS.</b>	<b>TONS/HR.</b>
3/21/99	16	100	49604	1.550
3/23/99	16	122	60516	1.891
3/24/99	8	40	19841	1.240
3/25/99	16	120	59524	1.860
3/27/99	16	100	49604	1.550
3/28/99	8	30	14881	0.930
3/29/99	16	66	32738	1.023
3/31/99	16	50	24802	0.775
4/1/99	16	94	46627	1.457
4/2/99	16	100	49604	1.550
4/3/99	16	102	50596	1.581
4/5/99	8	32	15873	0.992
4/6/99	8	60	29762	1.860
4/7/99	16	120	59524	1.860
4/8/99	16	120	59524	1.860
4/9/99	16	120	59524	1.860
4/10/99	16	89	44147	1.380



**EMISSION POINT AC-004 (MELTER)****Report Period:  
Jan.- June, 1999****Note: No activity on those dates not shown.**

<b>DATE</b>	<b># HOURS</b>	<b># DRUMS</b>	<b>TOTAL LBS.</b>	<b>TONS/HR.</b>
4/11/99	16	104	51588	1.612
4/12/99	16	96	47619	1.488
4/17/99	16	90	44643	1.395
4/26/99	16	124	61508	1.922
4/28/99	8	40	19841	1.240
5/3/99	8	60	29762	1.860
5/4/99	16	80	39683	1.240
5/5/99	16	98	48611	1.519
5/6/99	16	110	54564	1.705
5/7/99	16	120	59524	1.860
5/8/99	16	120	59524	1.860
5/9/99	16	120	59524	1.860
5/10/99	16	120	59524	1.860
5/11/99	16	120	59524	1.860
5/12/99	16	124	61508	1.922
5/13/99	16	100	49604	1.550
5/14/99	16	70	34722	1.085



Emission Point - AA002

Adipic Acid Handling System Equipment with a Dust Shaker

Date (M-D-Y)	Adipic Acid Addition Time minutes	Adipic Acid Total Charge boxes	Adipic Acid Total Charge pounds	Adipic Acid Total Charge ton/hr	Comments
12/31/98	180	16	23900	4.0	
12/31/98	90	8	11966	4.0	
1/2/99	90	8	11960	4.0	
1/4/99	180	16	23920	4.0	
1/5/99	90	8	11960	4.0	
1/6/99	90	8	11960	4.0	
1/7/99	180	16	23920	4.0	
1/8/99	90	8	11960	4.0	
1/9/99	90	8	11960	4.0	
1/10/99	90	8	11960	4.0	
1/12/99	90	8	11960	4.0	
1/13/99	90	8	11960	4.0	
1/15/99	180	16	23920	4.0	
1/17/99	90	8	11960	4.0	
1/18/99	90	8	11960	4.0	
1/19/99	90	8	11960	4.0	
1/21/99	90	8	11960	4.0	
1/23/99	180	16	23920	4.0	
1/24/99	180	16	23920	4.0	
1/25/99	90	8	11960	4.0	
1/26/99	90	8	11960	4.0	
1/28/99	90	8	11960	4.0	

### Emission Point - AA002

### Adipic Acid Handling System Equipment with a Dust Shaker

Date (M-D-Y)	Adipic Acid Addition Time minutes	Adipic Acid Total Charge boxes	Adipic Acid Total Charge pounds	Adipic Acid Total Charge ton/hr	Comments
1/29/99	90	16	11960	4.0	
1/31/99	180	16	23920	4.0	
2/1/99	90	16	11960	4.0	
2/2/99	90	16	11960	4.0	
2/3/99	90	16	11960	4.0	
2/4/99	90	16	11960	4.0	
2/5/99	90	16	11960	4.0	
2/7/99	180	16	23920	4.0	
2/9/99	90	16	11960	4.0	
2/10/99	90	16	11960	4.0	
2/11/99	90	16	11960	4.0	
2/12/99	90	16	11960	4.0	
2/13/99	90	16	11960	4.0	
2/14/99	180	16	23920	4.0	
2/16/99	90	16	11960	4.0	
2/17/99	90	16	11960	4.0	
2/18/99	90	16	11960	4.0	
2/19/99	90	16	11960	4.0	
2/20/99	90	16	11960	4.0	
2/22/99	90	16	11960	4.0	
2/23/99	90	16	11960	4.0	
2/24/99	90	16	11960	4.0	
2/25/99	90	16	11960	4.0	
2/26/99	90	16	11960	4.0	
2/27/99	90	16	11960	4.0	
2/28/99	180	16	23920	4.0	



### Emission Point - AA002

### Adipic Acid Handling System Equipment with a Dust Shaker

Date (M-D-Y)	Adipic Acid Addition Time minutes	Adipic Acid Total Charge boxes	Adipic Acid Total Charge pounds	Adipic Acid Total Charge ton/hr	Comments
3/1/99	90	8	11960	4.0	
3/2/99	90	8	11960	4.0	
3/3/99	90	8	11960	4.0	
3/4/99	90	8	11960	4.0	
3/6/99	90	8	11960	4.0	
3/7/99	180	16	23920	4.0	
3/8/99	90	8	11920	4.0	
3/9/99	90	8	11960	4.0	
3/11/99	90	8	11960	4.0	
3/12/99	90	8	11960	4.0	
3/15/99	180	16	23920	4.0	
3/16/99	90	8	11960	4.0	
3/17/99	90	8	11960	4.0	
3/18/99	180	16	23920	4.0	
3/19/99	90	8	11960	4.0	
3/20/99	90	8	11960	4.0	
3/25/99	90	8	11960	4.0	
3/26/99	180	16	23920	4.0	
3/28/99	90	8	11960	4.0	

Emission Point - AA002

Adipic Acid Handling System Equipment with a Dust Shaker

Date	Adipic Acid Addition Time	Adipic Acid Total Charge	Adipic Acid Total Charge	Adipic Acid Total Charge	Comments
(M-D-Y)	minutes	boxes	pounds	ton/hr	
3/29/99	90	8	11960	4.0	
3/30/99	90	8	11960	4.0	
3/31/99	90	8	11960	4.0	
4/1/99	90	8	11960	4.0	
4/2/99	90	8	11960	4.0	
4/4/99	180	16	23920	4.0	
4/6/99	180	16	23920	4.0	
4/7/99	90	8	11960	4.0	
4/8/99	180	16	23920	4.0	
4/9/99	180	16	23920	4.0	
4/11/99	180	16	23920	4.0	
4/13/99	90	8	11960	4.0	
4/14/99	90	8	11960	4.0	
4/15/99	90	8	11960	4.0	
4/19/99	90	8	11960	4.0	
4/20/99	90	8	11960	4.0	
4/23/99	90	8	11960	4.0	
4/24/99	90	8	11960	4.0	
4/25/99	180	16	23920	4.0	

Emission Point - AA002

Adipic Acid Handling System Equipment with a Dust Shaker

Date	Adipic Acid Addition Time	Adipic Acid Total Charge	Adipic Acid Total Charge	Adipic Acid Total Charge	Comments
(M-D-Y)	minutes	boxes	pounds	ton/hr	
4/29/99	180	16	23920	4.0	
5/1/99	180	16	23920	4.0	
5/2/99	90	8	11960	4.0	
5/7/99	90	8	11960	4.0	
5/9/99	180	16	23920	4.0	
5/11/99	90	8	11960	4.0	
5/12/99	90	8	11960	4.0	
5/13/99	180	16	23920	4.0	
5/14/99	90	8	11960	4.0	
5/16/99	90	8	11960	4.0	
5/17/99	90	8	11960	4.0	
5/20/99	90	8	11960	4.0	
5/21/99	90	8	11960	4.0	
5/23/99	90	8	11960	4.0	
5/25/99	90	8	11960	4.0	
5/27/99	90	8	11960	4.0	
5/28/99	90	8	11960	4.0	



Emission Point - AA002

Adipic Acid Handling System Equipment with a Dust Shaker

*Every Batch*

Date (M-D-Y)	Adipic Acid Addition Time minutes	Adipic Acid Total Charge boxes	Adipic Acid Total Charge pounds	Adipic Acid Total Charge ton/hr	Comments
5/28/99	90	8	11960	4.0	
5/29/99	180	16	23920	4.0	
5/30/99	180	16	23920	4.0	
5/31/99	90	8	11960	4.0	
6/4/99	90	8	11960	4.0	
6/7/99	180	16	23920	4.0	
6/8/99	90	8	11960	4.0	
6/9/99	90	8	11960	4.0	
6/10/99	180	16	23920	4.0	
6/12/99	90	8	11960	4.0	
6/13/99	90	8	11960	4.0	
6/17/99	90	8	11960	4.0	
6/20/99	90	8	11960	4.0	
6/21/99	90	8	11960	4.0	
6/21/99	90	8	11960	4.0	
6/23/99	90	8	11960	4.0	
6/26/99	90	8	11960	4.0	
6-27-99	90	8	11960	4.0	
6-28-99	90	8	11960	4.0	
6-30-99	90	8	11960	4.0	
7-1-99	90	8	11960	4.0	
7-5-99	90	8	11960	4.0	
7-6-99	90	8	11960	4.0	
7-7/99	90	8	11960	4.0	
7/14/99	90	8	11960	4.0	
7/15/99	90	8	11960	4.0	
7/16/99	90	8	11960	4.0	
7/18/99	90	8	11960	4.0	
7/20/99	90	8	11960	4.0	



**Emission Point - AL002**  
**Defoamer Process Silica Furnance Dust Collector**

Date (M-D-Y)	Silica Addition Time minutes	Silica Total Charge bages	Silica Total Charge pounds	Silica Total Charge ton/hr	Comments
12/31/98					NO operation of silica drying process in December 1998
1/31/99					NO operation of silica dryer process in January 1999
2/28/99					No operation of silica dryer process in the month of February 1999
3/31/99					no operation of silica dryer process in the month of March 1999
4/24/99					no operation of silica dryer process in the month of April 1999
5/24/99					No operation of the silica dryer process in the month of May 1999
6/27/99					No operation of the silica dryer process in the month of June 1999. See operator log sheet <sup>date</sup> subsequent to 6/99. <i>[Signature]</i>

**PERIODIC LEAK  
MONITORING REPORT  
January, 1999 To June, 1999**

**KYMENE PROCESS**

for

**HERCULES, INCORPORATED  
CHEMICAL SPECIALTIES  
Hattiesburg, Mississippi**

Forrest County

*prepared by:*

**ECO-SYSTEMS, INC.  
ENVIRONMENTAL ENGINEERS AND SCIENTISTS  
Jackson, Mississippi**

**June, 1999**

**PERIODIC LEAK MONITORING REPORT - KYMENE PROCESS**  
**For Compliance Period - January, 1999 through June, 1999**


Hercules, Incorporated  
Hattiesburg, Mississippi

1. ***Number of affected valves for which leaks were detected; percent leakers; total number of valves:***
  - No affected valves were discovered leaking during compliance period (greater than 500 ppm and/or a visible leak);
  - 0.00% of total affected valves were leaking;
  - 60 total affected valves are in the Kymene process.
2. ***Number of valves which were not repaired during this period:***
  - No affected valves were discovered leaking.
3. ***Number of pumps for which leaks were detected; percent leakers; total number of pumps:***
  - No affected pumps were discovered leaking during the compliance period (greater than 5,000 ppm or a visible leak);
  - 0.00% of affected pumps were leaking;
  - 3 total affected pumps are in the Kymene process.
4. ***Number of pumps which were not repaired during this period:***
  - No affected pumps were discovered leaking during this compliance period.
5. ***Number of agitators for which leaks were detected; percent leakers; total number of agitators:***
  - No affected agitators were discovered leaking during compliance period (greater than 10,000 ppm or a visible leak);
  - 0.00% of affected agitators were leaking;
  - 1 total affected agitator is in the Kymene process.
6. ***Number of agitators which were not repaired during this period:***
  - No affected agitators required repair.

7. ***Number of connectors (flanges, screwed fittings and others) for which leaks were detected; percent leakers; total number of connectors:***
  - 1 affected connector (flange) was discovered leaking during compliance period (greater than 500 ppm);
  - 0.33% of total affected connectors were leaking;
  - 302 total affected connectors are in the Kymene process.
  
8. ***Number of connectors which were not repaired during this period:***
  - Leaking connector was successfully repaired.
  
9. ***Provide explanation of any repairs that were unable to be made:***
  - Repairs of all affected leaking components were successful.
  
10. ***Provide results of all monitoring conducted during compliance period:***
  - All results for the specified reporting period may be found in Attachment A to this report.

**ATTACHMENT A**

**Results Of Leak Monitoring  
Kymene Process  
January, 1999 - June, 1999**



**CONSTRUCTION PERMIT APPLICATION  
HERCULES, INC.  
HATTIESBURG, MISSISSIPPI**

**(REDACTED)  
FOR PUBLIC REVIEW**

**FACILITY NUMBER 0800-00001**

**JANUARY, 1998**

PREPARED BY

***ECO-SYSTEMS, INC.***  
Consultants Engineers and Scientists

*Jackson, Mississippi  
Little Rock, Arkansas*

*Houston, Texas  
Dallas, Texas*

## **TABLE OF CONTENTS**

---

### **REPORT**

1. Introduction
2. Purpose
3. Proposed Storage Tank
4. Regulatory Review

### **APPLICATION**

### **FIGURES**

- Figure 1: Site Location  
Figure 2: Production Area Layout & Proposed  
Storage Tank Location

### **TANKS PROGRAM OUTPUT**

**REPORT**



## **1 INTRODUCTION**

Hercules Inc. (Hercules) owns and operates a Specialty Chemicals manufacturing facility in Hattiesburg, Mississippi (the facility). The facility is located in Forrest County, at 613 West 7<sup>th</sup> Street, Hattiesburg, Mississippi. The facility consists of various chemical production/process areas. This facility currently operates under the Mississippi Department of Environmental Quality Air Permit No. 0800-00001.

One of the various production processes operated at the Hercules facility is the Hard Resins Processing Area (HRA - Emission Point 080). Several products are produced in this production area. The pollutants emitted from the existing HRA area include PM, VOCs, and HAPs. HAPs emitted include Acrolein, Formaldehyde, Maleic Anhydride, Phthalic Anhydride, and Ethyl Glycol.

Hercules intends to produce a new confidential product in the HRA. Production of the new product is similar to the current proprietary production process and is confidential business information. The existing equipment in the HRA is sufficient to support the production operation for the new product. However, Hercules intends to replace an existing storage tank (S-94) with an identical new stainless steel storage tank (S-94) for storing Maleic Anhydride.

Figure 1 Shows the site location as depicted on a 7.5 minute United States Geological Survey (USGS) quad map. Figure 2 is the layout for the proposed new product production process and indicates the location of the proposed new Maleic Anhydride storage tank.

## **2 Purpose**

As mentioned above Hercules proposes to replace an existing storage tank with a new stainless steel storage tank for Maleic Anhydride. This application is prepared in order to apply for a 'State of Mississippi Construction Permit' for the proposed construction at the Hercules facility.

## **3 Proposed Storage Tank**

The proposed Maleic Anhydride storage tank will be a vertical tank with a fixed roof. The tank will have 8,565 gallon capacity. The tank will be located as shown in Figure 2. The only emissions expected from the tank are VOCs and Maleic Anhydride (HAP). The emissions from the proposed tank are estimated by using the API's Tanks3 program. Please see the attached tanks program output for more details.

## 4 REGULATORY REVIEW

### *New Source Performance Standards (NSPS)*

New Source Performance Standards (NSPS) have been promulgated to govern the emissions of certain sources of air pollutant emissions modified, constructed, or reconstructed after the applicability dates of the regulations. These standards are documented in 40 CFR 60. The proposed storage tank at the Hercules facility is not subject to NSPS requirements since its capacity is below 10,560 gallons.

### *National Emission Standards for Hazardous Air Pollutants (NESHAP)*

National Emission Standards for Hazardous Air Pollutants (NESHAP) have been promulgated to govern the emissions of certain hazardous air pollutants. These standards are documented in 40 CFR 61 and 63. The proposed storage tank at the Hercules facility is not subject to any NESHAP requirements.

### *Non-attainment Area Review (NAR)*

The proposed modification is not subject to NAR because the facility is located in an attainment area.

### *Prevention of Significant Deterioration (PSD) Review*

Prevention of Significant Deterioration (PSD) applies to major stationary sources and major modifications with respect to each pollutant regulated under the federal PSD program. This facility meets the definition of a major stationary source because it has the potential to emit 250 tons per year or more of a pollutant (VOCs) subject to the PSD regulations. However, the requested increase in emissions from the proposed modification is less than the significant emission rate thresholds for triggering PSD review. No de-bottlenecking of the facility will occur from the installation of this new tank.

### *Title V Applicability*

The Hercules facility in Hattiesburg is a major source and therefore subject to the Title V requirements. This facility has submitted a complete Title V application to the MDEQ in a timely manner.

**APPLICATION**

**STATE OF MISSISSIPPI  
DEPT. OF ENVIRONMENTAL QUALITY  
OFFICE OF POLLUTION CONTROL  
P. O. BOX 10385  
JACKSON, MS 39289-0385  
(601) 961-5171**

**APPLICATION FOR  
AIR POLLUTION CONTROL PERMIT  
TO CONSTRUCT AND/OR OPERATE  
AIR EMISSIONS EQUIPMENT**

**TYPE OF PERMIT**

- New Source**
- Modification**
- Renewal of Operating Permit**
- Existing Source Operating Permit**

**Name:** Hercules, Inc.  
**Location: City** Hattiesburg **County** Forrest  
**Facility No. (if known)** 0800-00001

**APPLICATION FOR PERMIT TO CONSTRUCT  
AND/OR OPERATE AIR EMISSIONS EQUIPMENT  
GENERAL FORM**

1. Name, Address & Contact for the Owner/Applicant

A. Company Name: Hercules, Inc.

B. Mailing Address:

1. Street Address or P.O. Box: P. O. Box 1937  
2. City: Hattiesburg 3. State: Mississippi  
4. Zip Code: 39401 5. Telephone No.: ( 601 ) 545-3450

C. Contact:

1. Name: Charles Jordan  
2. Title: Environmental Coordinator

2. Name, Address, Location and Contact for the Facility:

A. Name: Hercules, Inc.

B. Mailing Address:

1. Street Address or P.O. Box: P. O. Box 1937  
2. City: Hattiesburg 3. State: Mississippi  
4. Zip Code: 39401 5. Telephone No.: ( 601 ) 545-3450

C. Site Location:

1. Street: 613 West 7<sup>th</sup> Street  
2. City: Hattiesburg 3. State: Mississippi  
4. County: Forrest 5. Zip Code: 39401  
6. Telephone No.: ( 601 ) 545-3450

Note: If the facility is located outside of the City limits, please attach a sketch or description to this application showing the approximate location of the site.

D. Contact:

1. Name: Charles Jordan  
2. Title: Environmental Coordinator

3. SIC Code(s) 2861, 2821, 2869, 2899

4. Number of Employees: 142

5. Principal Process(es): Specialty Chemicals Manufacturing

6. Principle Product(s) and maximum amount produced per day Specialty Chemicals.  
Maximum Production: 3,103,720 lbs/day.

7. Principal Raw Materials and maximum amount consumed per day Rosin and Paper Chemicals.  
Maximum amount consumed: 3,103,720 lbs/day.

8. Facility Operating Schedule:

- A. Specify maximum hours per day the operation will occur: 24
- B. Specify maximum days per week the operation will occur: 7
- C. Specify maximum weeks per year the operation will occur: 52
- D. Specify the months the operation will occur: January to December

9. Only if the application is for Operating Permit renewal, has the facility been modified in any way (including production rate, fuel, and or raw material changes) during the period covered by the Operating Permit?  
 YES NO, If yes, give years in which modification occurred and explain. Not Applicable

10. If after August 7, 1977, provide the date construction commenced. NA

11. If after August 7, 1977, provide the date operation began. NA

12. Please list the dates of any modifications or emissions increases since August 7, 1977. NA

- April 1985 – Metal Resinates production permitted and began operation.
- October 1985 – Added #6 natural gas steam boiler.
- May 1987 – Neuphor production process permitted and began operation.
- November 1987 – Synthetic Resins modification permitted.
- January 1991 – Kymene production expansion permitted.
- April 1991 – Dresinol production permitted and began operation.
- December 1993 – Permitted to increase Metal Resinates production capacity.

13. EACH APPLICATION MUST BE SIGNED BY THE APPLICANT.


If the applicant is a corporation, it must be signed by a corporate officer as defined in Regulation APC-S-2. If the applicant is a partnership, it must be signed by a partner with authority to bind the partnership. In the case of a governmental agency, the application must be signed by the facility manager or senior staff officer responsible for the installations or facility's environmental compliance.

*I certify that I am familiar with the information contained in the application and that to the best of my knowledge and beliefs such information is true, complete, and accurate, and that, as an appropriate representative of the applicant, my signature shall constitute an agreement that the applicant assumes the responsibility for any alteration, additions, or changes in operation that may be necessary to achieve and maintain compliance with all applicable Rules and Regulations.*

Walter Langhans  
 Printed Name of Person signing

Plant Manager  
 Title

1/10/98  
 Date Application Signed

  
 Signature of Applicant

PLEASE COMPLETE THE FOLLOWING PAGES WHERE APPLICABLE

## GENERAL INFORMATION & INSTRUCTIONS

1) The application is designed to obtain information to allow evaluation of a number of different types of air emission facilities. If the space provided in the application is not adequate or does not fit your air emissions equipment, you may use a separate sheet(s) to provide the necessary information.

2) Permits will be valid only for those operations, pollutants, and pollutant emission rates identified in the application. As a minimum, the application must identify the following:

A. All operations or equipment having air emissions. For each, specify the maximum schedule, the maximum operating rate and the expected operating rate, if different from the maximum.

B. Emission rates (in units of the applicable emission standard as well as lbs/hr and tons/year) for each air pollutant subject to regulation under the Federal Act that can be reasonably expected to be emitted from each independent emission point. The following emission rates shall be provided in the EMISSIONS SUMMARY SECTION:

1. Potential Uncontrolled Emissions - this emission rate is defined in Regulation APC-S-2, amended December 9, 1993.

2. Proposed Emission Rate - the maximum emission rate at which the applicant proposes to operate the emission point.

**EMISSION RATE CALCULATIONS MUST BE PROVIDED.**

C. The exhaust or stack parameters for each emission source (height, velocity, diameter, and temperature) shall be provided in the EMISSIONS SUMMARY SECTION.

**APPLICATION FOR AIR POLLUTION CONTROL PERMIT  
ADDITIONAL INFORMATION REQUIRED FOR MODIFICATIONS,  
EXISTING SOURCE OPERATING PERMITS,  
AND/OR APPROVAL TO CONSTRUCT**

The following additional information must be submitted in duplicate. Failure to submit any of the additional information or to conform to the instructions may result in initial rejection of the application.

- 1) Design Calculations and Specifications - all data and calculations used in selecting or designing process and control equipment.
- 2) Site Drawings - the drawing(s) or sketch(es) must be to scale and show at least the following:
  - A. The property involved with dimensions, clearly defining restricted entry boundaries and, if different, the total property boundaries.
  - B. Location and identification of all existing and/or proposed buildings, structures, and/or equipment, including points of discharge of air contaminants to the atmosphere, drawn to scale and in proper orientation.
  - C. The dimensions (length, width) of all buildings, structures, and/or equipment, including emission points.
  - D. The elevation of all buildings, structures, and/or equipment, including emission points, showing heights, grade baseline, and grade baseline height above mean sea level.
  - E. Primary compass direction indicator.
  - F. Location of streets and all adjacent properties. Show location of all buildings outside the property that are within 150 feet of the equipment involved in the application. Identify all such buildings (as a residence, apartment, warehouse, etc.), specifying number of stories or approximate height, and indicate the prevailing wind direction.



3) Construction Drawings (See Note Below) - an assembly drawing, dimensioned and to scale, in as many sections as are needed to show clearly the design and operation of the equipment and the means by which air contaminants are controlled. The following must be shown:

- A. Size and shape of equipment. Show exterior and interior dimensions and features.
- B. Locations, sizes, and shape details of all features which may affect the production, collection, conveying or control of air contaminants of any kind; location, size and shape details concerning all materials handling equipment.

NOTE: Structural design calculations and details are not required.

4) Description of Process and Control Equipment - a written description of each process to be carried out in the facility and the function of the equipment used in the process. The descriptions must be complete and particular attention must be given to explaining all stages in the process where the discharge of any materials might contribute in any way to air pollution. Control procedures must be described in sufficient detail to show the extent of control of air contaminants anticipated in the design, specifying the expected efficiencies of the capture systems and the control devices. All obtainable data must be supplied concerning the nature, volumes, particle size, weights, chemical composition and concentrations of all types of air contaminants.

5) Block Flow Diagram - a drawing showing the steps of the process and the flow of materials through the process and any control devices.

Additional information may be required as is necessary to evaluate the design adequacy of the facility or to comply with the requirements of the Prevention of Significant Deterioration (PSD) regulations.

ALL ENGINEERING PLANS AND SPECIFICATIONS MUST BEAR THE SIGNATURE, REGISTRATION NUMBER, AND SEAL OF A PROFESSIONAL ENGINEER REGISTERED IN THE STATE OF MISSISSIPPI.



## EMISSIONS SUMMARY SECTION PART II

Reference Number	Pollutant	PROPOSED EMISSION RATE			POTENTIAL UNCONTROLLED EMISSIONS	
		See Footnote (1)	(lbs/hr)	(TPY)	(lbs/hr)	(TPY)
S-94	VOC	na	None proposed		5.36 lb/yr	

- (1) Provide emission rate in units of applicable emission standard, e.g., lb/MMBTU, gr/dscf at 12% CO<sub>2</sub>, etc. This may not apply to every emission point or every pollutant from an emission point.
- (2) Please provide the total emissions from the facility by pollutant.

## EMISSIONS SUMMARY SECTION PART III

CAS NO.	HAP	Proposed Emission Rate		Potential Uncontrolled Emission Rate	
		lbs/hr	TPY	lbs/hr	TPY
75070	Acetaldehyde	NA	NA	NA	NA
60355	Acetamide	NA	NA	NA	NA
75058	Acetonitrile	NA	NA	NA	NA
98862	Acetophenone	NA	NA	NA	NA
53963	Acetylamino fluorene(2)	NA	NA	NA	NA
107028	Acrolein	NA	NA	NA	NA
79061	Acrylamide	NA	NA	NA	NA
79107	Acrylic Acid	NA	NA	NA	NA
107131	Acrylonitrile	NA	NA	NA	NA
107051	Allyl Chloride	NA	NA	NA	NA
92671	Aminodipheyl(4)	NA	NA	NA	NA
62533	Aniline	NA	NA	NA	NA
90040	Anisidine(o)	NA	NA	NA	NA
7440360	Antimony Compounds	NA	NA	NA	NA
7440382	Arsenic Compounds (inorganic including arsine)	NA	NA	NA	NA
1332214	Asbestos	NA	NA	NA	NA
71432	Benzene	NA	NA	NA	NA
92875	Benzidine	NA	NA	NA	NA
98077	Benzotrichloride	NA	NA	NA	NA
100447	Benzyl Chloride	NA	NA	NA	NA
7440417	Beryllium Compounds	NA	NA	NA	NA
192524	Biphenyl	NA	NA	NA	NA
117817	Bis(2-ethylhexyl)phthalate (DEHP) (Dioctyl Phthalate)	NA	NA	NA	NA
542881	Bis(chloromethyl)ether	NA	NA	NA	NA
75252	Bromoform	NA	NA	NA	NA

CAS NO.	HAP	Proposed Emission Rate		Potential Uncontrolled Emission Rate	
		lbs/hr	TPY	lbs/hr	TPY
106990	Butadiene(1,3)	NA	NA	NA	NA
7440439	Cadmium Compounds	NA	NA	NA	NA
156627	Calcium Cyanamide	NA	NA	NA	NA
105602	Caprolactam	NA	NA	NA	NA
133062	Captan	NA	NA	NA	NA
63252	Carbaryl	NA	NA	NA	NA
75150	Carbon Disulfide	NA	NA	NA	NA
56235	Carbon Tetrachloride	NA	NA	NA	NA
463581	Carbonyl Sulfide	NA	NA	NA	NA
120809	Catechol	NA	NA	NA	NA
133904	Chloramben	NA	NA	NA	NA
57749	Chlordane	NA	NA	NA	NA
7782505	Chlorine	NA	NA	NA	NA
79118	Chloroacetic Acid	NA	NA	NA	NA
532274	Chloroacetophenone(2)	NA	NA	NA	NA
108907	Chlorobenzene	NA	NA	NA	NA
510156	Chlorobenzinate	NA	NA	NA	NA
67663	Chloroform	NA	NA	NA	NA
107302	Chloromethyl methyl ether	NA	NA	NA	NA
126998	Chloroprene (Neoprene; 2-Chloro-1,3-Butadiene)	NA	NA	NA	NA
7440473	Chromium Compounds (IV)	NA	NA	NA	NA
10210681	Cobalt Carbonyl (as Co)	NA	NA	NA	NA
7440484	Cobalt Compounds (metal, dust, and fumes as Co)	NA	NA	NA	NA
16842038	Cobalt Hydrocarbonyl (as Co)	NA	NA	NA	NA
65996818A	Coke Oven Emissions	NA	NA	NA	NA
1319773	Cresols/Cresylic acid	NA	NA	NA	NA
108394	Cresol(m)	NA	NA	NA	NA

CAS NO.	HAP	Proposed Emission Rate		Potential Uncontrolled Emission Rate	
		lbs/hr	TPY	lbs/hr	TPY
95487	Cresol(o)	NA	NA	NA	NA
106445	Cresol(p)	NA	NA	NA	NA
98828	Cumene (Isopropylbenzene)	NA	NA	NA	NA
---	Cyanide Compounds (NOTE # 1)	NA	NA	NA	NA
3547044	DDE	NA	NA	NA	NA
334883	Diazomethane	NA	NA	NA	NA
132649	Dibenzofurans	NA	NA	NA	NA
96128	Dibromo-3-chloropropane(1,2)	NA	NA	NA	NA
84742	Dibutylphthalate	NA	NA	NA	NA
106467	Dichlorobenzene(1,4)(p)	NA	NA	NA	NA
91941	Dichlorobenzidene(3,3)	NA	NA	NA	NA
111444	Dichloroethyl ether (Bis(2-chloroethyl)ether)	NA	NA	NA	NA
542756	Dichloropropene(1,3)	NA	NA	NA	NA
62737	Dichlorvos	NA	NA	NA	NA
111422	Diethanolamine	NA	NA	NA	NA
121697	Diethyl aniline (N,N) (dimethylaniline (N,N))	NA	NA	NA	NA
64675	Diethyl Sulfate	NA	NA	NA	NA
119904	Dimethoxybenzidine(3,3')	NA	NA	NA	NA
60117	4 - Dimethyl aminoazobenzene	NA	NA	NA	NA
119937	Dimethyl benzidine (3,3')	NA	NA	NA	NA
79447	Dimethyl carbamoyl chloride	NA	NA	NA	NA
68122	Dimethyl formamide	NA	NA	NA	NA
57147	Dimethyl hydrazine(1,1)	NA	NA	NA	NA
131113	Dimethyl phthalate	NA	NA	NA	NA
77781	Dimethyl sulfate	NA	NA	NA	NA
534521	Dinitro-o-cresol(4,6), and salts	NA	NA	NA	NA
51285	Dinitrophenol(2,4)	NA	NA	NA	NA

CAS NO.	HAP	Proposed Emission Rate		Potential Uncontrolled Emission Rate	
		lbs/hr	TPY	lbs/hr	TPY
121142	Dinitrotoluene(2,4)	NA	NA	NA	NA
123911	Dioxane(1,4) (1,4-diethyleneoxide)	NA	NA	NA	NA
122667	Diphenylhydrazine(1,2)	NA	NA	NA	NA
94757	d(2,4), salts and esters	NA	NA	NA	NA
106898	Epichlorohydrin (Chloro-2,3-epoxypropane(1))	NA	NA	NA	NA
106887	Epoxybutane(1,2) (1,2-Butylene oxide)	NA	NA	NA	NA
140885	Ethyl acrylate	NA	NA	NA	NA
100414	Ethyl benzene	NA	NA	NA	NA
51796	Ethyl carbamate (Urethane)	NA	NA	NA	NA
75003	Ethyl chloride (Chloroethane)	NA	NA	NA	NA
106934	Ethylene dibromide (1,2-Dibromoethane)	NA	NA	NA	NA
107062	Ethylene dichloride (1,2-Dichloroethane)	NA	NA	NA	NA
107211	Ethylene glycol	NA	NA	NA	NA
151564	Ethylene imine (Azridine)	NA	NA	NA	NA
75218	Ethylene oxide	NA	NA	NA	NA
96457	Ethylene thiourea	NA	NA	NA	NA
75343	Ethylidene dichloride (1,1-Dichloroethane)	NA	NA	NA	NA
50000	Formaldehyde	NA	NA	NA	NA
---	Glycol ethers (NOTE #2)	NA	NA	NA	NA
76448	Heptachlor	NA	NA	NA	NA
118741	Hexachlorobenzene	NA	NA	NA	NA
87683	Hexachlorocyclopentadiene	NA	NA	NA	NA
67721	Hexachloroethane	NA	NA	NA	NA
822060	Hexamethylene-1,6-diisocyanate	NA	NA	NA	NA
680319	Hexamethylphosphoramide	NA	NA	NA	NA
110543	Hexane	NA	NA	NA	NA

CAS NO.	HAP	Proposed Emission Rate		Potential Uncontrolled Emission Rate	
		lbs/hr	TPY	lbs/hr	TPY
302012	Hydrazine	NA	NA	NA	NA
7647010	Hydrochloric acid	NA	NA	NA	NA
7664393	Hydrogen Fluoride (Hydrofluoric acid)	NA	NA	NA	NA
123319	Hydroquinone	NA	NA	NA	NA
78591	Isophorone	NA	NA	NA	NA
7439921	Lead Compounds	NA	NA	NA	NA
58899	Lindane (all isomers)	NA	NA	NA	NA
108316	Maleic anhydride	NA	NA	5.36 LB/YR	
7439965	Manganese Compounds	NA	NA	NA	NA
7439976	Mercury Compounds	NA	NA	NA	NA
67561	Methanol	NA	NA	NA	NA
72435	Methoxychlor	NA	NA	NA	NA
74839	Methyl bromide (Bromomethane)	NA	NA	NA	NA
74873	Methyl chloride (Chloromethane)	NA	NA	NA	NA
71556	Methyl chloroform (1,1,1-Trichloroethane)	NA	NA	NA	NA
78933	Methyl ethyl ketone (2-Butanone) (MEK)	NA	NA	NA	NA
60344	Methyl hydrazine	NA	NA	NA	NA
74884	Methyl iodide (Iodomethane)	NA	NA	NA	NA
108101	Methyl isobutyl ketone (Hexone)	NA	NA	NA	NA
624839	Methyl isocyanate	NA	NA	NA	NA
80626	Methyl methacrylate	NA	NA	NA	NA
1634044	Methyl tert butyl ether	NA	NA	NA	NA
101144	Methylene bis(2-chloroaniline)(4,4) (MOCA)	NA	NA	NA	NA
75092	Methylene chloride (Dichloromethane)	NA	NA	NA	NA
101688	Methylene diphenyl diisocyanate (MDI)	NA	NA	NA	NA
101779	Methylenedianiline(4,4')	NA	NA	NA	NA



CAS NO.	HAP	Proposed Emission Rate		Potential Uncontrolled Emission Rate	
		lbs/hr	TPY	lbs/hr	TPY
---	Mineral fibers (NOTE #3)	NA	NA	NA	NA
91203	Naphthalene	NA	NA	NA	NA
7440020	Nickel Compounds	NA	NA	NA	NA
7440020	Nickel, refinery dust	NA	NA	NA	NA
12035722	Nickel, subsulfide	NA	NA	NA	NA
98953	Nitrobenzene	NA	NA	NA	NA
92933	Nitrodiphenyl(4)	NA	NA	NA	NA
100027	Nitrophenol(4)	NA	NA	NA	NA
79469	Nitropropane(2)	NA	NA	NA	NA
62759	Nitrosodimethylamine(N) (Dimethylnitrosoamine)	NA	NA	NA	NA
59892	Nitrosomorpholine(N)	NA	NA	NA	NA
684935	Nitroso-N-methylurea(N)	NA	NA	NA	NA
56382	Parathion	NA	NA	NA	NA
82688	Pentachloronitrobenzene (Quintobenzene)	NA	NA	NA	NA
87865	Pentachlorophenol	NA	NA	NA	NA
108952	Phenol	NA	NA	NA	NA
106503	Phenylenediamine(p)	NA	NA	NA	NA
75445	Phosgene	NA	NA	NA	NA
7803512	Phosphine	NA	NA	NA	NA
7723140	Phosphorus	NA	NA	NA	NA
85449	Phthalic anhydride	NA	NA	NA	NA
1336363	Polychlorinated biphenyls (Arochlors)	NA	NA	NA	NA
---	Polycyclic Organic Matter (NOTE #5)	NA	NA	NA	NA
1120714	Propane sultone(1,3)	NA	NA	NA	NA
57578	Propiolactone(beta)	NA	NA	NA	NA
123386	Propionaldehyde	NA	NA	NA	NA
114261	Propoxur (Baygon)	NA	NA	NA	NA

CAS NO.	HAP	Proposed Emission Rate		Potential Uncontrolled Emission Rate	
		lbs/hr	TPY	lbs/hr	TPY
78875	Propylene dichloride (1,2 dichloropropane)	NA	NA	NA	NA
75558	Propylene imine(1,2) (2-methyl aziridine)	NA	NA	NA	NA
75569	Propylene oxide	NA	NA	NA	NA
91225	Quinoline	NA	NA	NA	NA
106514	Quinone (1,4-Cyclohexadienedione)	NA	NA	NA	NA
---	Radionuclides (including radon) (NOTE #4)	NA	NA	NA	NA
7782492	Selenium Compounds	NA	NA	NA	NA
100425	Styrene	NA	NA	NA	NA
96093	Styrene oxide	NA	NA	NA	NA
1746016	Tetrachlorodibenzo-p-dioxin(2,3,7,8) (TCDD) (Dioxin)	NA	NA	NA	NA
79345	Tetrachloroethane(1,1,2,2)	NA	NA	NA	NA
127184	Tetrachloroethylene (Perchloroethylene)	NA	NA	NA	NA
7550450	Titanium Tetrachloride	NA	NA	NA	NA
108883	Toluene	NA	NA	NA	NA
95807	Toluene diamine(2,4) (2,4-diaminotoluene)	NA	NA	NA	NA
584849	Toluene diisocyanate(2,4)	NA	NA	NA	NA
95534	Toluidine(o)	NA	NA	NA	NA
8001352	Toxaphene (Chlorinated camphene)	NA	NA	NA	NA
120821	Trichlorobenzene(1,2,4)	NA	NA	NA	NA
79005	Trichloroethane(1,1,2)	NA	NA	NA	NA
79016	Trichloroethylene	NA	NA	NA	NA
95954	Trichlorophenol(2,4,5)	NA	NA	NA	NA
88062	Trichlorophenol(2,4,6)	NA	NA	NA	NA
121448	Triethylamine	NA	NA	NA	NA
1582098	Trifluralin	NA	NA	NA	NA

CAS NO.	HAP	Proposed Emission Rate		Potential Uncontrolled Emission Rate	
		lbs/hr	TPY	lbs/hr	TPY
540841	Trimethylpentane(2,2,4)	NA	NA	NA	NA
75014	Vinyl Chloride	NA	NA	NA	NA
108054	Vinyl Acetate	NA	NA	NA	NA
593602	Vinyl Bromide	NA	NA	NA	NA
75354	Vinylidene chloride (1,1-Dichloroethylene)	NA	NA	NA	NA
1330207	Xylenes (mixed)	NA	NA	NA	NA
108383	Xylene(m)	NA	NA	NA	NA
95476	Xylene(o)	NA	NA	NA	NA
106423	Xylene(p)	NA	NA	NA	NA

NOTE # 1: X'CN where X = H' or any other group where a formal dissociation may occur, for example: KCN or Ca(CN)<sub>2</sub>.

NOTE # 2: Includes mono- and di- ethers of ethylene glycol, diethylene glycol and triethylene glycol R-(OCH<sub>2</sub>CH<sub>2</sub>)<sub>n</sub>-OR' where:

$$n = 1,2,3$$

R = alkyl or aryl groups

R' = R, H, or group which, when removed, yield glycol ethers with the structure: R-(OCH<sub>2</sub>CH<sub>2</sub>)<sub>n</sub>-OH. Polymers are excluded from the glycol category.

NOTE # 3: Includes glass microfibers, glass wool fibers, rock wool fibers, and slag wool fibers, each characterized as "respirable" (fiber diameter less than 3.5 micrometers) and possessing an aspect ratio (fiber length divided by fiber diameter) greater than 3.

NOTE # 4: A type of atom which spontaneously undergoes radioactive decay.

NOTE # 5: Includes organic compounds with more than one benzene ring, and which have a boiling point greater than or equal to 100 Celsius.

**APPLICATION SUMMARY SECTION**

I. Indicate below which sections have been completed as part of this application. Where applicable, also indicate the number of each section completed.

Administrative Information	<u>    X    </u>
Emission Summary Section	
Part I	<u>    X    </u>
Part II	<u>    X    </u>
Part III	<u>    X    </u>
Fuel Burning Equipment	<u>          </u>
Manufacturing Process Operations	<u>          </u>
Refuse Disposal	
Tank Section	<u>    X    </u>
Incineration Section	
Asphalt Plant Section	
Concrete Plant Section	
Air Pollution Control Devices	
Baghouse	
Cyclone	
Adsorption	
Afterburner	
Scrubber	
Electrostatic Precipitator	
Other Air Pollution Control Equipment/Devices	

II. Please list any other attachments.

**Report, Figures, and Tanks Program Output.**

**TANK SUMMARY (page 1 of 2)**

**SECTION H**

1. Emission Point No./Name: Em. Point 080: S-94 (Hercules Reference # M0899) / Maleic Anhydride Storage Tank

2. Was this unit constructed or modified after August 7, 1977? X yes no  
 If yes please give date and explain. To be Constructed in January 1998.

3. Product Stored: Maleic Anhydride  
 If more than one product is stored, provide the information in 4 A-E for each product.

4. Tank Data:

- A. True Vapor Pressure at storage temperature: 0.01 psia/°F
- B. Reid Vapor Pressure at storage temperature: N/A psia/°F
- C. Density of product at storage temperature: 8.0 lb/gal
- D. Molecular Weight of product vapor at storage temperature: 98.06 lb/lbmol
- E. Throughput for most recent calendar year: 119,615 gal/yr
- F. Tank Capacity: 8,565 gal
- G. Tank Diameter: 9 feet
- H. Tank Height / Length: 18 feet
- I. Average Vapor Space Height: 9 feet
- J. Tank Orientation: Vertical or Horizontal
- K. Type of Roof: Dome or Cone
- L. Is the Tank Equipped with a Vapor Recovery System? Yes X No  
 If Yes, describe on separate sheet of paper and attach. Indicate efficiency.
- M. Check the Type of Tank:  
 Fixed Roof                       External Floating Roof  
 Pressure                                       Internal Floating Roof  
 Variable Vapor Space  
 Other, describe: \_\_\_\_\_
- N. Check the Closest City:  
 Jackson, Ms.                       Birmingham, Al.  
 Memphis, Tn.                               Montgomery, Al.  
 New Orleans, La.                       Baton Rouge, La.
- O. Check the Tank Paint Color:  
 Aluminum Specular                       Gray Light  
 Aluminum Diffuse                       Gray Medium  
 Red     White  
 Other, describe: \_\_\_\_\_
- P. Tank Paint Condition: Good or Poor
- Q. Check Type of Tank Loading
  - 1. Trucks and Rail Cars Not applicable  
 Submerged Loading of clean cargo tank  
 Submerged Loading : Dedicated Normal Service  
 Submerged Loading : Dedicated Vapor Balance Service  
 Splash Loading of clean cargo tank  
 Splash Loading : Dedicated Normal Service  
 Splash Loading : Dedicated Vapor Balance Service
  - 2. Marine Vessels Not applicable  
 Submerged Loading: Ships  
 Submerged Loading: Barges

R. For External Floating Roof Tanks Not Applicable

1. Check the Type of Tank Seal:
  - Mechanical Shoe
  - Primary Seal Only
  - With Shoe-Mounted Secondary Seal
  - With Rim-Mounted Secondary Seal
  - Liquid Mounted Resilient Seal
  - Primary Seal Only
  - With Shoe-Mounted Secondary Seal
  - With Rim-Mounted Secondary Seal
  - Vapor Mounted Resilient Seal
  - Primary Seal Only
  - With Shoe-Mounted Secondary Seal
  - With Rim-Mounted Secondary Seal
2. Type of External Floating Roof:
  - Pontoon
  - Double-Deck

S. For Internal Floating Roof Tanks Not Applicable

1. Check the Type of Tank Seal:
  - Liquid Mounted Resilient Seal
  - Primary Seal Only
  - With Rim-Mounted Secondary Seal
  - Vapor Mounted Resilient Seal
  - Primary Seal Only
  - With Rim-Mounted Secondary Seal
2. Number of Roof Columns: \_\_\_\_\_
3. Length of Deck Seam \_\_\_\_\_ feet:
4. Area of Deck: \_\_\_\_\_ feet<sup>2</sup>
5. Effective Column Diameter: \_\_\_\_\_ feet
6. Check the Type of Tank:
  - Bolted with Column Supported Roof
  - Welded with Column Supported Roof
  - Bolted with Self-Supported Roof
  - Welded with Self-Supported Roof

5. Emissions Summary

1. Breathing Loss:	<u>0.015</u> lb/hr	<u>0.066</u> TPY
2. Working Loss:	<u>0.029</u> lb/hr	<u>0.126</u> TPY
3. Total Emissions:	<u>0.044</u> lb/hr	<u>0.192</u> TPY

6. UTM Coordinates:


A. Zone 16      B. North 3,469,200      C. East 280,700

**TABLE 1  
CODE NUMBERS FOR CONTROL DEVICES**

Vapor Control Equipment	48	Barometric Condenser with hot wells
<b>00</b>	<b>GROUP - CONTROL BY COMBUSTION</b>	<b>50 GROUP - ELECTRICAL PRECIPITATORS</b>
01	Catalytic Combustion	50 Single Stage
02	Furnace Combustion	51 Double Stage
03	Boiler Firebox	52 Precipitation
04	Steam Injection Flare	
05	Venturi Flare	<b>60 GROUP</b>
06	Direct Flame Combustion (Afterburner)	60 Counteractant
<b>10</b>	<b>GROUP - ADSORBERS</b>	<b>70 GROUP - SPECIAL</b>
10	Activated Carbon - Nonregenerative	
11	Activated Carbon - Regenerative	71 Jet Exhausters (Air Dilution)
12	Silica Gel - Nonregenerative	72 Mist Eliminators
13	Silica Gel - Regenerative	
14	Lithium Chloride	<b>80 GROUP - Other</b>
15	Activated Alumina	
16	Activated Bauxite	80 Specify
<b>20</b>	<b>GROUP - ABSORBERS</b>	
20	Sieve Plate Tower	
21	Bubble - Cap Tower	
22	Packed Tower	
Particulate Matter - Liquid Mist Control Equipment		
<b>30</b>	<b>GROUP - DRY SEPARATORS &amp; FILTERS</b>	
30	Simple Cyclones	
31	High Efficiency Cyclones	
32	Settling Chamber	
33	Simple Filters	
34	Baghouse (Shaking)	
35	Baghouse (Reverse Jet)	
36	Dry Collector (Dynamic)	
<b>40</b>	<b>GROUP - WET COLLECTORS</b>	
40	Spray Chamber - No Baffles	
41	Spray Chamber - With Baffles	
42	Wet Cyclones - Rotoclone	
43	Wet Dynamic Precipitator	
44	Venturi Scrubber	
45	Spray Tower (Not Absorption - Scrubbers)	
46	Packed Tower (Not Absorption - Scrubbers)	
47	Condensers (Tube and Shell); air	

**FIGURES**





QUADRANGLE LOCATION

SOURCE:  
 U.S.G.S. 7.5 MINUTE QUADRANGLE MAP,  
 HATTIESBURG, MISSISSIPPI 1964



**HERCULES**

CHEMICAL SPECIALTIES

**Eco-Systems, Inc.**

Environmental Engineers and Scientists




DATE: 12-29-95

DATE:

SITE LOCATION

01/12/1998 15:36 U:\DRWG\HERC\SET1\9502S108



**HERCULES**  
CHEMICAL SPECIALTIES

**Eco-Systems, Inc.**  
Environmental Engineers and Scientists

SCALE: 1" = 50'	DRAWN BY: K. SELF	DATE: 11-27-95
	CHKD. BY:	DATE:

PROJECT NO. HER9502	CAD FILE 9502S108.DWG
------------------------	--------------------------

ASA PRODUCTION AREA LAYOUT AND STORAGE TANK LOCATION	FIGURE 2
---	-------------



**TANKS PROGRAM OUTPUT**

TANKS PROGRAM 3.0  
EMISSIONS REPORT - SUMMARY FORMAT  
TANK IDENTIFICATION AND PHYSICAL CHARACTERISTICS

Identification No.: S-94  
City: Hattiesburg  
State: MS  
Company: Hercules, Inc.  
Type of Tank: Vertical Fixed Roof  
Description: Maleic An. Stg. Tank

Tank Dimensions  
Shell Height (ft): 18.0  
Diameter (ft): 9.0  
Liquid Height (ft): 18.0  
Avg. Liquid Height (ft): 9.0  
Volume (gallons): 8565  
Turnovers: 14.0  
Net Throughput (gal/yr): 119615

Tank Characteristics  
Shell Color/Shade: Aluminum/Specular  
Shell Condition: Good  
Roof Color/Shade: Aluminum/Specular  
Roof Condition: Good

Roof Characteristics  
Type: Dome  
Height (ft): 0.00  
Radius (ft) (Dome Roof): 5.00  
Slope (ft/ft) (Cone Roof): 0.0000

Weather Vent Settings  
Vacuum Setting (psig): 0.00  
Pressure Setting (psig): 0.00

Meteorological Data Used in Emission Calculations: Jackson, Mississippi (Avg Atmospheric Pressure = 14.7 psia)



TANKS PROGRAM 3.0  
EMISSIONS REPORT - SUMMARY FORMAT  
INDIVIDUAL TANK EMISSION TOTALS

Annual Emissions Report

Liquid Contents	Losses (lbs.):		Total
	Standing	Working	
Leic Anhydride	2.57	2.79	5.36
Total:	2.57	2.79	5.36



Mississippi Department of Environmental Quality  
Office of Pollution Control

I-sys 2000 Master Site Detail Report

Site Name: Hercules Inc

<p><b>PHYSICAL ADDRESS</b></p> <p>LINE 1: 613 West 7th Street</p> <p>LINE 2:</p> <p>LINE 3:</p> <p>MUNICIPALITY: Hattiesburg</p> <p>STATE CODE: MS</p> <p>ZIP CODE: 39401-</p> <p><b>MAILING ADDRESS</b></p> <p>LINE 1: 613 West 7th Street</p> <p>LINE 2:</p> <p>LINE 3:</p> <p>MUNICIPALITY: Hattiesburg</p> <p>STATE CODE: MS</p> <p>ZIP CODE: 39401-</p>	<p><b>OTHER INFORMATION</b></p> <p>MASTER ID: 002022</p> <p>COUNTY: Forrest</p> <p>REGION SRO</p> <p>SIC 1: 2822</p> <p>AIR TYPE: TITLE V</p> <p>HW TYPE: LARGE QUANTITY</p> <p>SOLID TYPE:</p> <p>WATER TYPE: INDUSTRIAL</p> <p>BRANCH: Chemical</p> <p>ECED CONTACT: Yassin, Mohammad</p> <p>BASIN:</p>
<p><b>AIR PROGRAMS</b> <input checked="" type="checkbox"/> SIP <input type="checkbox"/> PSD <input type="checkbox"/> NSPS <input type="checkbox"/> NESHAPS <input checked="" type="checkbox"/> MACT</p>	



**Mississippi Department of Environmental Quality  
Office of Pollution Control**

<b>Permits</b>				
PROGRAM	PERMIT TYPE	PERMIT #	MDEQ PERMIT CONTACT	ACTIVE
HAZ. WASTE	EPA ID	MSD008182081		NO
AIR	TITLE V	080000001	Ketchum, Brian	YES
AIR	SOP	080000001	Ketchum, Brian	NO
WATER	NPDES - MAJOR	MS0001830	Cook, Charles	NO
WATER	NPDES - MAJOR	MS0001830	Cook, Charles	NO
WATER	NPDES - MAJOR	MS0001830	Beasley, Jerry	YES
WATER	PRE-TREATMENT	MSP091286	Tomkins, Tracy	YES
GENERAL	SARA TITLE III	MSR110153	Lavallee, Louis	YES
AIR	TITLE V	0800-00001	Glenn, Montie	NO

<b>Compliance Actions</b>				
MEDIA	ACTIVITY TYPE	SCHEDULED	COMPLETED	INSPECTED B
WATER	CEI - NA	3/17/99	3/17/99	Yassin, Mohammad
WATER	CMI - PRETREATMENT	11/1/99		Sharp, Loyd
WATER	CMI - NPDES	4/1/00		Sharp, Loyd
WATER	CMI - NPDES	11/1/99		Sharp, Loyd
WATER	CEI - NA	9/30/00		Yassin, Mohammad
HAZ WASTE	Compliance Evaluation Inspection	9/30/00		Yassin, Mohammad
AIR	State Compliance Inspection	9/30/00		Yassin, Mohammad
HAZ WASTE	Compliance Evaluation Inspection	6/30/99	6/30/99	Yassin, Mohammad
AIR	State Compliance Inspection	6/29/99	6/29/99	Yassin, Mohammad
WATER	CEI - NA	6/30/99	6/30/99	Yassin, Mohammad



***ETHYLENE OXIDE EMISSIONS TEST***

***HERCULES, INC***

***RAD ETHYLENE OXIDE SCRUBBER***

***EMISSION POINT AF-004***

***FACILITY NO. 0800-00001***

***Hattiesburg, Mississippi***

***April 5, 2002***

Hercules, Inc.

613 West 7<sup>th</sup> Street

Hattiesburg, MS 39401-2812

***Performed by:***

**ENVIRONMENTAL MONITORING LABORATORIES, INC.**

624 Ridgewood Road  
P.O. Box 655  
Ridgeland, Mississippi 39158

Phone: (601)856-3092

Fax: (601)853-2151

REPORT OF  
AIR EMISSIONS TESTS  
FOR  
HERCULES, INC.

RAD ETHYLENE OXIDE SCRUBBER

Hattiesburg, Mississippi  
April 5, 2002

**FACILITY NO. 0800-00001**

Hercules, Inc.  
613 West 7<sup>th</sup> Street  
Hattiesburg, Mississippi 39401-2812

contact: Charlie Jordan  
phone: 601/584-3264

*Performed By:*  
*Environmental Monitoring Laboratories*  
*Ridgeland, Mississippi*  
*<601/856-3092>*

# ENVIRONMENTAL MONITORING LABORATORIES, INC.

P.O. Box 655 ☉ 624 Ridgewood Road  
Ridgeland, Mississippi 39158

phone: 601/856-3092  
fax : 601/853-2151

May 9, 2002

Subject: Hercules, Inc. Hattiesburg, Mississippi  
FACILITY NO. 0800-00001 EP AF-004

On April 5, 2002, Environmental Monitoring Laboratories performed air emissions testing for Hercules, Inc. in Hattiesburg, Mississippi. Testing was performed to measure ethylene oxide concentrations from and loading to the RAD Ethylene Oxide Scrubber in accordance with requirements of the Mississippi Department of Environmental Quality.

The RAD process is subject to provisions of 40 CFR 63, subpart PPP Polyether Polyols Production. The applicable equipment in organic HAP service is equipment that contains or contacts a fluid, which is  $\geq 5\%$  by weight of total organic HAPs and operates 300 hours or more during the calendar year. Compliance with provisions of the subpart can be demonstrated by using equipment shown to reduce ethylene oxide emissions by 98% or to a concentration of less than 20 ppm.

Results of testing are summarized in the table below.

ETHYLENE OXIDE EMISSIONS		REMOVAL EFFICIENCY, %
EO SCRUBBER INLET	EO SCRUBBER OUTLET	
49.666 %	4.00 ppm	99.99 %

Mr. Charlie Jordan of Hercules coordinated the testing project. Danny Russell of EML was responsible for sample and data collection and for report preparation. Summa Canisters used for sampling and sample analysis was provided by Enthalpy Analytical. Otherwise, sample custody was limited to Mr. Russell.

Following is a report of the test.

---

**REPORT OF AIR EMISSIONS TESTS FOR  
HERCULES, INC.  
RAD ETHYLENE OXIDE SCRUBBER  
HATTIESBURG, MISSISSIPPI  
APRIL 5, 2002**

---


**CONTENTS**

1.0	TEST RESULTS	page	1
2.0	SOURCE DESCRIPTION		2
3.0	TEST PROCEDURES		3
4.0	APPENDICES:		4
	A. Field Data		
	B. Wastewater Analysis (Bonner)		
	C. Enthalpy Report (EO analysis)		

**REPORT CERTIFICATION**

I certify that I have examined the information submitted herein,  
and based upon inquires of those responsible for obtaining the  
data or upon my direct acquisition of data, I believe the  
submitted information is true, accurate and complete.

Signed \_\_\_\_\_



Daniel G. Russell

## 1.0 Test Results:

The following table is a summary of the measured parameters for air emissions testing done on April 5, 2002, for the RAD Ethylene Oxide Scrubber at Hercules in Hattiesburg, Mississippi.

Run No. ....		1	2	3	AVG.
Date .....		04/05/02	04/05/02	04/05/02	-----
Time Start .....		1131	1238	1356	----
Time End .....		1231	1338	1456	----
EO SCRUBBER INLET LOADING	ppm	44,265	71,256	33,476	49,666
EO SCRUBBER OUTLET EMISSIONS	ppm	6.01	4.02	1.97	4.00
EO SCRUBBER REMOVAL EFFICIENCY	%	99.99	99.99	99.99	99.99


Details of the analyses indicating these results may be reviewed in Appendix B.

Enthalpy Analytical performed the analysis and reported the values shown in the table.

Enthalpy's report is copied in total in Appendix B.

**2.0 SOURCE DESCRIPTION:** Ethylene Oxide Derivatives, including polyrads and surfactants are corrosion inhibitors that are used for hydrochloric acid and for petroleum refining equipment. Their detergent properties aid in loosening and dispersing scale. The manufacturing scheme for EOD is 1) reacting ethylene oxide with various feed resins, and 2) various blending operations. Exhaust from the batch process consists primarily of ethylene oxide and nitrogen. This exhaust is directed to a weak sulfuric acid scrubber where ethylene oxide is converted to ethylene glycol and controlled by scrubber blowdown. The EO Scrubber exhausts to the atmosphere by way of a two inch diameter pipe about 30 feet above grade.

Outlet samples were collected from a 3/8 inch diameter tube and valve installed about 15 feet above the scrubber and directed to ground level valved outlet. Inlet samples were collected from a similar installation immediately prior to the sulfuric acid scrubber. Both lines were adequately purged prior to commencing sample collection.



### 3.0 TEST PROCEDURES:

Inlet and outlet samples were collected in two liter Summa canisters provided by Enthalpy Analytical. Flow to the evacuated canisters was controlled to a constant rate over the 60 minute sample time by use of a critical orifice controller also provide by Enthalpy. Ambient temperature, barometric pressure, and canister beginning and ending pressures were recorded for each of the three runs. Inlet and outlet samples were collected simultaneously. This procedure resembles Method 18 in function. The Summa canisters were chosen over Tedlar bags for their inherent sturdiness and resistance to sample loss due to leakage from handling. Those canisters were shipped to Enthalpy Analytical for analysis by GCMS.

Oxygen content was continuously measured at the outlet during sampling to monitor for ambient air leakage dilution.

As an additional quality control measure, selected samples were re-analyzed after two weeks to determine if the samples may have degraded from the time the samples were collected to the time they were initially analyzed. Reanalysis of the samples illustrated satisfactory stability

Reported values:

	Run 2 Inlet	Run 1 Outlet
Ethylene Oxide (4/29/02)	67.417 ppm	5.52 ppm
Ethylene Oxide (4/16/02)	71,256 ppm	6.01 ppm

## 7.0 APPENDICES

- A. Field Data
- B. Wastewater Analysis (Bonner)
- C. Enthalpy Report (EO analysis)



APPENDIX A

FIELD DATA

RAD Process E.O. Scrubber

Hurcules, Hattisburg MS

04/05/02

in/out	Canister #	time		Vacuum "Hg	
		Start	End.	Start	Stop.
R1 out	1003	1131	1231	29.35	0.55
R1 in	1037	1131	1231	29.60	3.95
R2 out	<del>1043</del> 1016	1238	1338	25.90	0.30
R2 in	1044	1238	1338	29.65	3.75
R3 in out	1035	1356	1456	29.80	1.50
R3 IN	1108	1356	1456	29.15	<del>3.00</del> 3.40

time	pbar
1120	30.18
1240	30.15
1501	30.09

TIME	O2	CO2
04/05/02 11:09	20.89	0.10
04/05/02 11:09	20.96	-0.02
04/05/02 11:10	20.98	-0.05
04/05/02 11:10	20.96	-0.05
04/05/02 11:10	20.90	0.00
04/05/02 11:10	20.94	-0.01
04/05/02 11:11	20.93	-0.02
04/05/02 11:11	20.73	-0.02
04/05/02 11:11	20.85	-0.03
04/05/02 11:11	20.90	-0.03
04/05/02 11:12	20.91	-0.05
04/05/02 11:12	20.91	-0.04
04/05/02 11:12	20.88	-0.03
04/05/02 11:12	20.81	-0.02
04/05/02 11:13	20.85	-0.07
04/05/02 11:13	20.87	-0.07
04/05/02 11:13	20.86	-0.05
04/05/02 11:13	20.86	-0.05
04/05/02 11:14	20.85	-0.04
04/05/02 11:14	20.85	-0.06
04/05/02 11:14	20.85	-0.06
04/05/02 11:14	20.85	-0.06
04/05/02 11:15	20.85	-0.07
04/05/02 11:15	20.85	-0.06
04/05/02 11:15	20.85	-0.07
04/05/02 11:15	20.84	-0.08
04/05/02 11:16	20.83	-0.08
04/05/02 11:16	20.83	-0.09
04/05/02 11:16	20.82	-0.08
04/05/02 11:16	20.82	-0.04
04/05/02 11:17	20.82	-0.06
04/05/02 11:17	20.81	-0.05
04/05/02 11:17	20.81	-0.04
04/05/02 11:17	20.80	-0.04
04/05/02 11:18	20.80	-0.04
04/05/02 11:18	20.80	-0.02
04/05/02 11:18	20.80	-0.03
04/05/02 11:18	20.79	-0.02
04/05/02 11:19	20.79	-0.01
04/05/02 11:19	20.79	-0.02
04/05/02 11:19	20.78	-0.03
04/05/02 11:19	20.78	-0.03
04/05/02 11:20	20.78	-0.03
04/05/02 11:20	20.77	-0.03
04/05/02 11:20	20.76	-0.04
04/05/02 11:20	20.77	-0.03
04/05/02 11:21	20.77	-0.04
04/05/02 11:21	20.77	-0.04
04/05/02 11:21	20.77	-0.03
04/05/02 11:21	20.76	-0.05
04/05/02 11:22	20.76	-0.07
04/05/02 11:22	20.76	-0.06
04/05/02 11:22	20.76	-0.06
04/05/02 11:22	20.76	-0.06
04/05/02 11:23	20.74	-0.05
04/05/02 11:23	20.75	-0.04
04/05/02 11:23	20.75	-0.03
04/05/02 11:23	20.75	-0.03
04/05/02 11:24	20.75	-0.03
04/05/02 11:24	20.74	-0.02
04/05/02 11:24	20.75	-0.02
04/05/02 11:24	20.75	-0.02
04/05/02 11:25	20.07	-0.02
04/05/02 11:25	7.43	-0.05
04/05/02 11:25	1.16	-0.07
04/05/02 11:25	0.33	-0.08
04/05/02 11:26	0.22	-0.07
04/05/02 11:26	0.20	-0.08
04/05/02 11:26	0.20	-0.08
04/05/02 11:26	0.21	-0.07
04/05/02 11:27	0.21	-0.07
04/05/02 11:27	0.21	-0.08
04/05/02 11:27	3.61	-0.07
04/05/02 11:27	15.20	-0.05
04/05/02 11:28	19.88	-0.04
04/05/02 11:28	20.60	-0.04
04/05/02 11:28	20.69	-0.03
04/05/02 11:28	20.70	-0.03
04/05/02 11:29	20.70	-0.02
04/05/02 11:29	20.69	-0.02
04/05/02 11:29	20.70	-0.03
04/05/02 11:29	20.69	-0.04
04/05/02 11:30	20.69	-0.04
04/05/02 11:30	20.70	-0.04
04/05/02 11:30	20.70	-0.04
04/05/02 11:30	20.71	-0.05
04/05/02 11:31	20.71	-0.04
04/05/02 11:31	20.71	-0.03
04/05/02 11:31	20.71	-0.02
04/05/02 11:31	20.31	-0.02
04/05/02 11:32	8.96	-0.04
04/05/02 11:32	1.50	-0.06

START RUN 1	O2	CO
04/05/02 11:32	0.44	-0.05
04/05/02 11:32	0.30	-0.05
04/05/02 11:33	0.28	-0.05
04/05/02 11:33	0.27	-0.06
04/05/02 11:33	0.18	-0.07
04/05/02 11:33	0.18	-0.07
04/05/02 11:34	0.18	-0.08
04/05/02 11:34	0.18	-0.09
04/05/02 11:34	0.18	-0.11
04/05/02 11:34	0.18	-0.13
04/05/02 11:35	0.18	-0.13
04/05/02 11:35	0.18	-0.18
04/05/02 11:35	0.19	-0.19
04/05/02 11:35	0.19	-0.19
04/05/02 11:36	0.19	-0.20
04/05/02 11:36	0.19	-0.15
04/05/02 11:36	0.19	-0.14
04/05/02 11:36	0.19	-0.13
04/05/02 11:37	0.19	-0.13
04/05/02 11:37	0.20	-0.12
04/05/02 11:37	0.20	-0.12
04/05/02 11:37	0.20	-0.12
04/05/02 11:38	0.20	-0.14
04/05/02 11:38	0.20	-0.13
04/05/02 11:38	0.20	-0.12
04/05/02 11:38	0.20	-0.11
04/05/02 11:39	0.20	-0.11
04/05/02 11:39	0.20	-0.11
04/05/02 11:39	0.21	-0.11
04/05/02 11:39	0.20	-0.11
04/05/02 11:40	0.21	-0.11
04/05/02 11:40	0.21	-0.10
04/05/02 11:40	0.20	-0.12
04/05/02 11:40	0.21	-0.12
04/05/02 11:41	0.20	-0.12
04/05/02 11:41	0.21	-0.10
04/05/02 11:41	0.21	-0.09
04/05/02 11:41	0.21	-0.07
04/05/02 11:42	0.20	-0.05
04/05/02 11:42	0.21	-0.05
04/05/02 11:42	0.20	-0.04
04/05/02 11:42	0.20	-0.04
04/05/02 11:43	0.20	-0.04
04/05/02 11:43	0.20	-0.04
04/05/02 11:43	0.20	-0.05
04/05/02 11:43	0.20	-0.05
04/05/02 11:44	0.20	-0.05
04/05/02 11:44	0.20	-0.05
04/05/02 11:44	0.20	-0.07
04/05/02 11:44	0.20	-0.06
04/05/02 11:45	0.20	-0.05
04/05/02 11:45	0.19	-0.06
04/05/02 11:45	0.20	-0.04
04/05/02 11:45	0.19	-0.07
04/05/02 11:46	0.19	-0.07
04/05/02 11:46	0.20	-0.10
04/05/02 11:46	0.19	-0.12
04/05/02 11:46	0.18	-0.11
04/05/02 11:47	0.18	-0.12
04/05/02 11:47	0.17	-0.13
04/05/02 11:47	0.17	-0.14
04/05/02 11:47	0.17	-0.17
04/05/02 11:48	0.16	-0.17
04/05/02 11:48	0.16	-0.17
04/05/02 11:48	0.16	-0.20
04/05/02 11:48	0.15	-0.21
04/05/02 11:49	0.15	-0.21
04/05/02 11:49	0.15	-0.21
04/05/02 11:49	0.15	-0.20
04/05/02 11:49	0.15	-0.21
04/05/02 11:50	0.14	0.06
04/05/02 11:50	0.14	0.00
04/05/02 11:50	0.14	0.04
04/05/02 11:50	0.14	0.06
04/05/02 11:51	0.14	0.07
04/05/02 11:51	0.13	0.03
04/05/02 11:51	0.13	0.02
04/05/02 11:51	0.12	0.02
04/05/02 11:52	0.12	0.01
04/05/02 11:52	0.11	0.03
04/05/02 11:52	0.11	0.03
04/05/02 11:52	0.10	0.01
04/05/02 11:53	0.10	0.00
04/05/02 11:53	0.09	0.00
04/05/02 11:53	0.09	0.00
04/05/02 11:53	0.09	0.00
04/05/02 11:54	0.08	0.00
04/05/02 11:54	0.08	-0.01
04/05/02 11:54	0.08	-0.01
04/05/02 11:54	0.08	-0.01
04/05/02 11:55	0.08	0.00
04/05/02 11:55	0.07	0.00

04/05/02 11:55	0.07	0.02
04/05/02 11:55	0.06	0.03
04/05/02 11:56	0.06	0.04
04/05/02 11:56	0.06	0.01
04/05/02 11:56	0.06	0.03
04/05/02 11:56	0.05	0.04
04/05/02 11:57	0.05	0.04
04/05/02 11:57	0.04	0.06
04/05/02 11:57	0.04	0.07
04/05/02 11:57	0.03	0.07
04/05/02 11:58	0.03	0.07
04/05/02 11:58	0.03	0.09
04/05/02 11:58	0.02	0.07
04/05/02 11:58	0.02	0.07
04/05/02 11:59	0.02	0.07
04/05/02 11:59	0.01	0.08
04/05/02 11:59	0.01	0.08
04/05/02 11:59	0.01	0.08
04/05/02 12:00	0.01	0.08
04/05/02 12:00	0.01	0.08
04/05/02 12:00	0.01	0.08
04/05/02 12:00	0.01	0.08
04/05/02 12:01	0.01	0.08
04/05/02 12:01	0.00	0.08
04/05/02 12:01	0.00	0.08
04/05/02 12:01	0.00	0.08
04/05/02 12:02	-0.01	0.07
04/05/02 12:02	-0.01	0.06
04/05/02 12:02	-0.01	0.07
04/05/02 12:02	-0.01	0.06
04/05/02 12:03	-0.01	0.07
04/05/02 12:03	-0.02	0.06
04/05/02 12:03	-0.01	0.07
04/05/02 12:03	-0.01	0.06
04/05/02 12:04	-0.01	0.07
04/05/02 12:04	-0.01	0.07
04/05/02 12:04	-0.01	0.07
04/05/02 12:04	-0.01	0.07
04/05/02 12:05	-0.01	0.08
04/05/02 12:05	-0.01	0.11
04/05/02 12:05	-0.01	0.11
04/05/02 12:05	-0.01	0.12
04/05/02 12:06	-0.01	0.13
04/05/02 12:06	-0.01	0.13
04/05/02 12:06	0.00	0.13
04/05/02 12:06	-0.01	0.15
04/05/02 12:07	-0.01	0.15
04/05/02 12:07	-0.01	0.13
04/05/02 12:07	-0.01	0.14
04/05/02 12:07	-0.01	0.15
04/05/02 12:08	-0.01	0.15
04/05/02 12:08	-0.01	0.16
04/05/02 12:08	-0.01	0.16
04/05/02 12:08	-0.02	0.16
04/05/02 12:09	-0.02	0.17
04/05/02 12:09	-0.02	0.17
04/05/02 12:09	-0.02	0.17
04/05/02 12:09	-0.02	0.17
04/05/02 12:10	-0.02	0.17
04/05/02 12:10	-0.02	0.16
04/05/02 12:10	-0.03	0.16
04/05/02 12:10	-0.03	0.16
04/05/02 12:11	-0.03	0.16
04/05/02 12:11	-0.03	0.16
04/05/02 12:11	-0.04	0.17
04/05/02 12:11	-0.04	0.17
04/05/02 12:12	-0.04	0.16
04/05/02 12:12	-0.04	0.17
04/05/02 12:12	-0.04	0.17
04/05/02 12:12	-0.04	0.17
04/05/02 12:13	-0.04	0.17
04/05/02 12:13	-0.05	0.19
04/05/02 12:13	-0.05	0.18
04/05/02 12:13	-0.05	0.18
04/05/02 12:14	-0.06	0.18
04/05/02 12:14	-0.06	0.18
04/05/02 12:14	-0.06	0.18
04/05/02 12:14	-0.06	0.19
04/05/02 12:15	-0.06	0.18
04/05/02 12:15	-0.06	0.18
04/05/02 12:15	-0.06	0.18
04/05/02 12:15	-0.06	0.18
04/05/02 12:16	-0.06	0.19
04/05/02 12:16	-0.06	0.19
04/05/02 12:16	-0.06	0.19
04/05/02 12:16	-0.06	0.19
04/05/02 12:17	-0.06	0.19
04/05/02 12:17	-0.06	0.19
04/05/02 12:17	-0.05	0.19
04/05/02 12:17	-0.05	0.20
04/05/02 12:18	-0.05	0.20
04/05/02 12:18	-0.06	0.20
04/05/02 12:18	-0.06	0.19

04/05/02 12:18	-0.05	0.19
04/05/02 12:19	-0.06	0.19
04/05/02 12:19	-0.06	0.20
04/05/02 12:19	-0.06	0.19
04/05/02 12:19	-0.06	0.19
04/05/02 12:20	-0.06	0.20
04/05/02 12:20	-0.07	0.20
04/05/02 12:20	-0.07	0.19
04/05/02 12:20	-0.07	0.20
04/05/02 12:21	-0.07	0.19
04/05/02 12:21	-0.07	0.19
04/05/02 12:21	-0.07	0.16
04/05/02 12:21	-0.07	0.16
04/05/02 12:22	-0.07	0.16
04/05/02 12:22	-0.07	0.16
04/05/02 12:22	-0.06	0.14
04/05/02 12:22	-0.06	0.14
04/05/02 12:23	-0.06	0.14
04/05/02 12:23	-0.06	0.14
04/05/02 12:23	-0.06	0.14
04/05/02 12:23	-0.06	0.14
04/05/02 12:24	-0.06	0.15
04/05/02 12:24	-0.05	0.14
04/05/02 12:24	-0.05	0.14
04/05/02 12:24	-0.05	0.15
04/05/02 12:25	-0.05	0.14
04/05/02 12:25	-0.05	0.14
04/05/02 12:25	-0.04	0.14
04/05/02 12:25	-0.04	0.14
04/05/02 12:26	-0.04	0.14
04/05/02 12:26	-0.04	0.15
04/05/02 12:26	-0.04	0.14
04/05/02 12:26	-0.05	0.16
04/05/02 12:27	-0.05	0.17
04/05/02 12:27	-0.05	0.16
04/05/02 12:27	-0.05	0.17
04/05/02 12:27	-0.05	0.18
04/05/02 12:28	-0.05	0.18
04/05/02 12:28	-0.05	0.18
04/05/02 12:28	-0.05	0.18
04/05/02 12:29	-0.05	0.18
04/05/02 12:29	-0.06	0.18
04/05/02 12:29	-0.06	0.18
04/05/02 12:29	-0.06	0.18
04/05/02 12:30	-0.07	0.19
04/05/02 12:30	-0.07	0.19
04/05/02 12:30	-0.07	0.19
04/05/02 12:30	0.04	0.20
04/05/02 12:31	0.03	0.20
04/05/02 12:31	0.03	0.20
04/05/02 12:31	0.03	0.21
04/05/02 12:31	0.03	0.20
04/05/02 12:32	0.03	0.20
04/05/02 12:32	0.02	0.20
AVG. R 1	0.05	0.06

04/05/02 12:32	11.05	0.23
04/05/02 12:32	18.68	0.24
04/05/02 12:33	20.37	0.24
04/05/02 12:33	20.57	0.24
04/05/02 12:33	14.08	0.23
04/05/02 12:33	2.84	0.21
04/05/02 12:34	0.32	0.20
04/05/02 12:34	0.01	0.20
04/05/02 12:34	-0.04	0.20
04/05/02 12:34	0.00	0.20
04/05/02 12:35	9.38	0.21
04/05/02 12:35	17.75	0.23
04/05/02 12:35	20.11	0.24
04/05/02 12:35	20.52	0.23
04/05/02 12:36	20.58	0.23
04/05/02 12:36	20.59	0.24
04/05/02 12:36	20.55	0.22
04/05/02 12:36	20.59	0.22
04/05/02 12:37	20.61	0.23
04/05/02 12:37	20.61	0.22
04/05/02 12:37	20.62	0.20
04/05/02 12:37	20.62	0.19
04/05/02 12:38	20.62	0.18
04/05/02 12:38	14.15	0.16
04/05/02 12:38	3.00	0.14
04/05/02 12:38	0.38	0.13
04/05/02 12:39	0.04	0.13

START RUN 2	O2	CO
04/05/02 12:39	-0.01	0.12
04/05/02 12:39	-0.02	0.14
04/05/02 12:39	-0.02	0.13
04/05/02 12:40	-0.02	0.13
04/05/02 12:40	-0.02	0.14
04/05/02 12:40	-0.01	0.13
04/05/02 12:40	-0.01	0.14
04/05/02 12:41	-0.01	0.14
04/05/02 12:41	0.00	0.14







04/05/02 13:28	0.24	0.18
04/05/02 13:28	0.24	0.17
04/05/02 13:28	0.24	0.17
04/05/02 13:28	0.24	0.16
04/05/02 13:29	0.24	0.16
04/05/02 13:29	0.24	0.16
04/05/02 13:29	0.24	0.16
04/05/02 13:30	0.24	0.16
04/05/02 13:30	0.24	0.16
04/05/02 13:30	0.24	0.16
04/05/02 13:30	0.24	0.16
04/05/02 13:31	0.24	0.16
04/05/02 13:31	0.24	0.16
04/05/02 13:31	0.24	0.17
04/05/02 13:31	0.24	0.18
04/05/02 13:32	0.24	0.18
04/05/02 13:32	0.24	0.18
04/05/02 13:32	0.24	0.18
04/05/02 13:32	0.24	0.18
04/05/02 13:33	0.23	0.18
04/05/02 13:33	0.23	0.18
04/05/02 13:33	0.23	0.18
04/05/02 13:33	0.23	0.19
04/05/02 13:34	0.23	0.19
04/05/02 13:34	0.23	0.19
04/05/02 13:34	0.23	0.20
04/05/02 13:34	0.23	0.23
04/05/02 13:35	0.23	0.24
04/05/02 13:35	0.23	0.24
04/05/02 13:35	0.23	0.25
04/05/02 13:35	0.23	0.25
04/05/02 13:36	0.23	0.25
04/05/02 13:36	0.23	0.25
04/05/02 13:36	0.23	0.25
04/05/02 13:36	0.23	0.25
04/05/02 13:37	0.22	0.26
04/05/02 13:37	0.22	0.26
04/05/02 13:37	0.22	0.25
04/05/02 13:37	0.22	0.26
04/05/02 13:38	0.22	0.26
04/05/02 13:38	0.22	0.26
04/05/02 13:38	0.22	0.26
04/05/02 13:38	0.22	0.25
04/05/02 13:39	0.22	0.25
<b>AVG. R 2</b>	<b>0.16</b>	<b>0.16</b>

04/05/02 13:39	20.61	0.26
04/05/02 13:39	20.61	0.26
04/05/02 13:39	20.62	0.25
04/05/02 13:40	20.62	0.25
04/05/02 13:40	20.62	0.25
04/05/02 13:40	20.63	0.25
04/05/02 13:40	20.62	0.25
04/05/02 13:41	20.62	0.25
04/05/02 13:41	20.63	0.24
04/05/02 13:41	20.62	0.25
04/05/02 13:41	20.62	0.25
04/05/02 13:42	20.62	0.25
04/05/02 13:42	20.63	0.25
04/05/02 13:42	20.63	0.25
04/05/02 13:42	20.63	0.25
04/05/02 13:43	20.62	0.26
04/05/02 13:43	20.62	0.26
04/05/02 13:43	20.63	0.26
04/05/02 13:43	20.63	0.25
04/05/02 13:44	20.63	0.26
04/05/02 13:44	20.61	0.26
04/05/02 13:44	20.64	0.26
04/05/02 13:44	20.63	0.26
04/05/02 13:45	20.63	0.26
04/05/02 13:45	20.63	0.26
04/05/02 13:45	20.62	0.26
04/05/02 13:45	20.61	0.26
04/05/02 13:46	20.62	0.26
04/05/02 13:46	20.62	0.26
04/05/02 13:46	20.62	0.27
04/05/02 13:46	20.63	0.26
04/05/02 13:47	20.63	0.26
04/05/02 13:47	20.63	0.26
04/05/02 13:47	20.62	0.26
04/05/02 13:47	20.63	0.26
04/05/02 13:48	20.63	0.27
04/05/02 13:48	20.62	0.27
04/05/02 13:48	20.62	0.26
04/05/02 13:48	20.62	0.27
04/05/02 13:49	20.62	0.27
04/05/02 13:49	20.61	0.27
04/05/02 13:49	20.62	0.27
04/05/02 13:49	20.61	0.26
04/05/02 13:50	20.61	0.24
04/05/02 13:50	20.61	0.24
04/05/02 13:50	20.33	0.23
04/05/02 13:50	19.89	0.22

04/05/02 13:51	20.44	0.21
04/05/02 13:51	20.58	0.20
04/05/02 13:51	20.61	0.18
04/05/02 13:51	20.62	0.16
04/05/02 13:52	20.61	0.17
04/05/02 13:52	20.61	0.17
04/05/02 13:52	20.60	0.16
04/05/02 13:52	20.60	0.16
04/05/02 13:53	20.92	0.17
04/05/02 13:53	20.91	0.17
04/05/02 13:53	20.93	0.17
04/05/02 13:53	20.92	0.17
04/05/02 13:54	20.85	0.17
04/05/02 13:54	20.84	0.17
04/05/02 13:54	20.85	0.17
04/05/02 13:54	20.85	0.17
04/05/02 13:55	20.44	0.17
04/05/02 13:55	9.44	0.15
04/05/02 13:55	1.41	0.13
04/05/02 13:55	0.21	0.13
04/05/02 13:56	0.01	0.12
04/05/02 13:56	-0.03	0.12
04/05/02 13:56	0.03	0.12
04/05/02 13:56	5.66	0.13
04/05/02 13:57	4.56	0.13
04/05/02 13:57	0.77	0.13
04/05/02 13:57	0.08	0.12
04/05/02 13:57	-0.02	0.12

START RUN 3	O2	CO
04/05/02 13:58	-0.04	0.12
04/05/02 13:58	-0.04	0.12
04/05/02 13:58	-0.04	0.13
04/05/02 13:58	-0.04	0.12
04/05/02 13:59	-0.04	0.12
04/05/02 13:59	-0.04	0.13
04/05/02 13:59	-0.04	0.12
04/05/02 13:59	-0.03	0.12
04/05/02 14:00	-0.03	0.12
04/05/02 14:00	-0.03	0.13
04/05/02 14:00	-0.03	0.13
04/05/02 14:00	-0.03	0.12
04/05/02 14:01	-0.03	0.12
04/05/02 14:01	-0.03	0.12
04/05/02 14:01	-0.03	0.12
04/05/02 14:01	-0.03	0.12
04/05/02 14:02	-0.03	0.13
04/05/02 14:02	-0.03	0.13
04/05/02 14:02	-0.03	0.14
04/05/02 14:02	-0.03	0.13
04/05/02 14:03	-0.03	0.14
04/05/02 14:03	-0.03	0.14
04/05/02 14:03	-0.03	0.14
04/05/02 14:03	-0.03	0.14
04/05/02 14:04	-0.03	0.14
04/05/02 14:04	-0.03	0.14
04/05/02 14:04	-0.03	0.14
04/05/02 14:04	-0.03	0.14
04/05/02 14:05	-0.02	0.14
04/05/02 14:05	-0.03	0.14
04/05/02 14:05	-0.03	0.14
04/05/02 14:05	-0.03	0.14
04/05/02 14:06	-0.02	0.15
04/05/02 14:06	-0.02	0.18
04/05/02 14:06	-0.02	0.18
04/05/02 14:06	-0.02	0.18
04/05/02 14:07	-0.02	0.18
04/05/02 14:07	-0.02	0.19
04/05/02 14:07	-0.03	0.19
04/05/02 14:07	-0.03	0.19
04/05/02 14:08	-0.03	0.19
04/05/02 14:08	-0.02	0.19
04/05/02 14:08	-0.02	0.19
04/05/02 14:08	-0.02	0.19
04/05/02 14:09	-0.02	0.19
04/05/02 14:09	-0.03	0.19
04/05/02 14:09	-0.02	0.20
04/05/02 14:09	-0.03	0.19
04/05/02 14:10	-0.03	0.19
04/05/02 14:10	-0.03	0.19
04/05/02 14:10	-0.03	0.19
04/05/02 14:10	-0.03	0.19
04/05/02 14:11	-0.03	0.19
04/05/02 14:11	-0.03	0.20
04/05/02 14:11	-0.03	0.20
04/05/02 14:11	-0.03	0.19
04/05/02 14:12	-0.03	0.19
04/05/02 14:12	-0.04	0.19
04/05/02 14:12	-0.03	0.19
04/05/02 14:12	-0.04	0.19
04/05/02 14:13	-0.04	0.19
04/05/02 14:13	-0.04	0.19
04/05/02 14:13	-0.04	0.19
04/05/02 14:13	-0.04	0.19



04/05/02 14:37	-0.01	0.24
04/05/02 14:37	0.00	0.24
04/05/02 14:37	0.00	0.24
04/05/02 14:38	0.01	0.24
04/05/02 14:38	0.01	0.24
04/05/02 14:38	0.01	0.24
04/05/02 14:38	0.02	0.24
04/05/02 14:39	0.02	0.24
04/05/02 14:39	0.03	0.24
04/05/02 14:39	0.03	0.24
04/05/02 14:39	0.03	0.24
04/05/02 14:40	0.04	0.24
04/05/02 14:40	0.04	0.24
04/05/02 14:40	0.04	0.24
04/05/02 14:40	0.05	0.24
04/05/02 14:41	0.05	0.24
04/05/02 14:41	0.05	0.24
04/05/02 14:41	0.06	0.24
04/05/02 14:41	0.06	0.24
04/05/02 14:42	0.06	0.24
04/05/02 14:42	0.07	0.24
04/05/02 14:42	0.07	0.24
04/05/02 14:42	0.08	0.25
04/05/02 14:43	0.08	0.24
04/05/02 14:43	0.08	0.24
04/05/02 14:43	0.09	0.24
04/05/02 14:43	0.09	0.24
04/05/02 14:44	0.09	0.24
04/05/02 14:44	0.10	0.24
04/05/02 14:44	0.10	0.24
04/05/02 14:44	0.10	0.23
04/05/02 14:45	0.10	0.24
04/05/02 14:45	0.11	0.23
04/05/02 14:45	0.11	0.24
04/05/02 14:45	0.11	0.24
04/05/02 14:46	0.12	0.24
04/05/02 14:46	0.12	0.24
04/05/02 14:46	0.12	0.24
04/05/02 14:46	0.12	0.24
04/05/02 14:46	0.13	0.24
04/05/02 14:47	0.13	0.24
04/05/02 14:47	0.14	0.24
04/05/02 14:47	0.14	0.24
04/05/02 14:47	0.15	0.24
04/05/02 14:48	0.15	0.24
04/05/02 14:48	0.15	0.24
04/05/02 14:48	0.16	0.24
04/05/02 14:48	0.16	0.24
04/05/02 14:49	0.16	0.24
04/05/02 14:49	0.17	0.24
04/05/02 14:49	0.17	0.24
04/05/02 14:49	0.17	0.24
04/05/02 14:50	0.18	0.23
04/05/02 14:50	0.18	0.24
04/05/02 14:50	0.18	0.24
04/05/02 14:50	0.18	0.24
04/05/02 14:51	0.19	0.23
04/05/02 14:51	0.19	0.24
04/05/02 14:51	0.19	0.24
04/05/02 14:51	0.19	0.23
04/05/02 14:52	0.19	0.24
04/05/02 14:52	0.19	0.24
04/05/02 14:52	0.19	0.24
04/05/02 14:52	0.20	0.24
04/05/02 14:53	0.20	0.24
04/05/02 14:53	0.20	0.24
04/05/02 14:53	0.20	0.24
04/05/02 14:54	0.20	0.24
04/05/02 14:54	0.21	0.24
04/05/02 14:54	0.21	0.23
04/05/02 14:54	0.21	0.24
04/05/02 14:55	0.20	0.24
04/05/02 14:55	0.21	0.24
04/05/02 14:55	0.21	0.24
04/05/02 14:55	0.21	0.24
04/05/02 14:56	0.21	0.24
04/05/02 14:56	0.22	0.24
04/05/02 14:56	0.22	0.24
04/05/02 14:56	0.21	0.23
04/05/02 14:57	0.21	0.24
04/05/02 14:57	0.22	0.24
04/05/02 14:57	0.22	0.24
04/05/02 14:57	0.22	0.23
<b>AVG. R</b>	<b>0.02</b>	<b>0.20</b>

04/05/02 14:58	1.23	0.24
04/05/02 14:58	11.96	0.26
04/05/02 14:58	18.83	0.27
04/05/02 14:58	20.18	0.27
04/05/02 14:59	20.65	0.27
04/05/02 14:59	20.75	0.28
04/05/02 14:59	20.77	0.28
04/05/02 14:59	20.77	0.28
04/05/02 15:00	20.78	0.28

04/05/02 15:00	20.79	0.28
04/05/02 15:00	20.79	0.28
04/05/02 15:00	20.80	0.28
04/05/02 15:01	20.80	0.27
04/05/02 15:01	20.81	0.28
04/05/02 15:01	20.80	0.28
04/05/02 15:01	20.81	0.28
04/05/02 15:02	20.81	0.28
04/05/02 15:02	20.82	0.29
04/05/02 15:02	20.81	0.29
04/05/02 15:02	20.82	0.29
04/05/02 15:03	20.82	0.29
04/05/02 15:03	20.82	0.29
04/05/02 15:03	20.82	0.29
04/05/02 15:03	20.80	0.30
04/05/02 15:04	20.79	0.30
04/05/02 15:04	20.81	0.30
04/05/02 15:04	20.79	0.29
04/05/02 15:04	20.82	0.29
04/05/02 15:05	20.83	0.29
04/05/02 15:05	20.83	0.29
04/05/02 15:05	20.83	0.30
04/05/02 15:05	20.83	0.29
04/05/02 15:06	20.83	0.29
04/05/02 15:06	20.84	0.29
04/05/02 15:06	20.82	0.29
04/05/02 15:06	20.83	0.30
04/05/02 15:07	20.84	0.29
04/05/02 15:07	20.83	0.30
04/05/02 15:07	20.83	0.30
04/05/02 15:07	20.83	0.29
04/05/02 15:08	20.83	0.29
04/05/02 15:08	20.83	0.30
04/05/02 15:08	20.84	0.29
04/05/02 15:08	20.84	0.29
04/05/02 15:09	20.84	0.30
04/05/02 15:09	20.84	0.28
04/05/02 15:09	20.83	0.29
04/05/02 15:09	20.84	0.28
04/05/02 15:10	20.83	0.28
04/05/02 15:10	16.75	0.28
04/05/02 15:10	4.62	0.26
04/05/02 15:10	0.64	0.26
04/05/02 15:11	0.08	0.25
04/05/02 15:11	-0.01	0.25
04/05/02 15:11	-0.03	0.25
04/05/02 15:11	-0.04	0.24
04/05/02 15:12	-0.04	0.25
04/05/02 15:12	-0.04	0.25
04/05/02 15:12	-0.05	0.25
04/05/02 15:12	-0.04	0.25
04/05/02 15:13	4.40	0.26
04/05/02 15:13	15.45	0.29
04/05/02 15:13	19.80	0.30
04/05/02 15:13	20.55	0.31
04/05/02 15:14	20.75	0.31
04/05/02 15:14	20.81	0.31
04/05/02 15:14	20.81	0.31
04/05/02 15:14	20.82	0.30
04/05/02 15:15	20.83	0.30
04/05/02 15:15	20.83	0.32
04/05/02 15:15	20.85	0.31

APPENDIX B

WASTE WATER REPORT

(BONNER)

BONNER ANALYTICAL TESTING COMPANY  
 2703 Oak Grove Road  
 Hattiesburg, MS 39402  
 (601) 264-2854

Client: Hercules

File Number: BT75939  
 Project Number: 003827  
 Collected By: MGJ  
 Sample Type: Water

Sample Date/Time: 04/04/02 @ 1820  
 Date/Time Received: 04/05/02 @ 1600  
 Date/Time Begun: 04/17/02 @ 2013  
 Analyst: MGJ

Trip Blank

Analytical Parameter

Results  
ug/L ppb

MDL  
ug/L ppb

Ethylene Oxide

ND

20.00

Surrogate Recoveries: (%)

1,2-Dichloroethane-d4  
 Dibromofluoromethane

98.9  
 100.4

Method 8260B, SW - 846.

\* Total BTEX is the sum of the Benzene, Toluene, Ethylbenzene and Xylenes concentrations.

MDL = Method Detection Limit  
 ND = Not Detected

Certified by: \_\_\_\_\_

Michael S. Bonner, Ph.D  
 BONNER ANALYTICAL TESTING COMPANY

BONNER ANALYTICAL TESTING COMPANY  
 2703 Oak Grove Road  
 Hattiesburg, MS 39402  
 (601) 264-2854

Client: Hercules

File Number: BT75940  
 Project Number: 003827  
 Collected By: MGJ  
 Sample Type: Water

Sample Date/Time: 04/05/02 @ 1500  
 Date/Time Received: 04/05/02 @ 1600  
 Date/Time Begun: 04/18/02 @ 0946  
 Analyst: MGJ

Ethylene Oxide Scrubber Blowdown

Analytical Parameter

Results  
ug/L ppb

MDL  
ug/L ppb

Ethylene Oxide

ND

20.00

Surrogate Recoveries: (%)

1,2-Dichloroethane-d4  
 Dibromofluoromethane

103.4  
 100.4

Method 8260B, SW - 846.

\* Total BTEX is the sum of the Benzene, Toluene, Ethylbenzene and Xylenes concentrations.

MDL = Method Detection Limit  
 ND = Not Detected

Certified by: \_\_\_\_\_  
 Michael S. Bonner, Ph.D.  
 BONNER ANALYTICAL TESTING COMPANY



APPENDIX C

ETHYLENE OXIDE ANALYSIS  
(ENTHALPY REPORT)

# Environmental Monitoring Laboratories

624 Ridgewood Road  
Ridgeland, MS 39158

Hercules

Analytical Report  
(0402-37)

*EPA Method 18 Type*  
Ethylene oxide



**Enthalpy Analytical, Inc.**

Phone: 919-850-4392 / Fax: 919-850-9012 / [www.enthalpy.com](http://www.enthalpy.com)  
2202 Ellis Road Durham, NC 27703 - 5518

I certify that to the best of my knowledge all analytical data presented in this report:

- Have been checked for completeness
- Are accurate, error-free, and legible
- Have been conducted in accordance with approved protocol, and that all deviations and analytical problems are summarized in the appropriate narrative(s)

*Michael Steven Schapira*

QA Review Performed by: Michael Steven Schapira



# Summary of Results



Company Environmental Monitoring Labs  
 Analyst Initials JRC  
 Parameters EPA Method 18 Type  
 # Samples 6 Summa canisters

Client # Hercules  
 Job # 0402-37  
 PO # Verbal  
 Report Date 4/23/2002

Compound	Sample ID / Sample Conc (Canister) (ppm)					
Ethylene oxide	<i>Run 1 Inlet</i>	<i>Run 2 Inlet</i>	<i>Run 3 Inlet</i>	<i>Run 1 Outlet</i>	<i>Run 2 Outlet</i>	<i>Run 3 Outlet</i>
	44,265	71,256	33,476	6.01	4.02 J	1.97 ND

# Results



Company Environmental Monitoring Laboratories  
 Analyst Initials JRC  
 Parameters EPA Method 18 Type  
 # Samples 6 Summa canisters

Client # Hercules  
 Job # 0402-37  
 PO # Verbal  
 Report Date 4/23/2002

MDL 1.00 (ppm) Lower Curve Limit 6.04 (ppm)  
 LOQ 2.00 (ppm) Upper Curve Limit 2,020 (ppm)  
 Compound Ethylene oxide

Sample ID	Lab ID # 1	Lab ID # 2	Lab ID # 3	Analysis Method	Ret Time # 1	Ret Time # 2	Ret Time # 3	% Diff Ret	Conc # 1	Conc # 2	Conc # 3	% Diff Conc	Avg Conc (ppm)	DF	Tank Dilution	Sample Conc (ppm)	Qual
Run 1 Inlet	SIG20014.D	SIG20015.D	SIG20016.D	0402-37B.	1.57	1.57	1.57	0.0	1,998	2,027	2,053	1.4	2,026	10	2,185	44,265	
Run 2 Inlet	SIG20018.D	SIG20019.D	SIG20020.D	0402-37B.	1.57	1.57	1.57	0.0	1,695	1,578	1,659	4.0	1,644	20	2,167	71,256	
Run 3 Inlet	SIG20021.D	SIG20022.D	SIG20023.D	0402-37B.	1.57	1.57	1.57	0.0	767	744	762	1.8	758	20	2,209	33,476	
Run 1 Outlet	SIG20036.D	SIG20037.D	SIG20038.D	0402-37C.	1.57	1.57	1.57	0.2	3.03	3.12	3.17	2.5	3.11	1	1,935	6.01	
Run 2 Outlet	SIG20039.D	SIG20040.D	SIG20041.D	0402-37C.	1.57	1.57	1.57	0.1	1.81	1.83	1.87	1.7	1.84	1	2,188	4.02	J
Run 3 Outlet	SIG20042.D	SIG20043.D	SIG20044.D	0402-37C.	NA	NA	NA	NA	1.00	1.00	1.00	NA	1.00	1	1,968	1.97	ND

Company Environmental Monitoring Labs  
 Analyst JRC  
 Parameters Tank Dilution  
 # Samples 6 Summa canisters

Client # Hercules  
 Job # 0402-37  
 PO # Verbal  
 Report Date 04/23/2002

Sample ID	Tank ID	Tank Dilution	Pretest			Initial			Final		
			Gauge Field (mmHg)	Temp Field (F)	Pbar Field (mmHg)	Gauge Lab/Field (mmHg)	Temp Lab/Field (F)	Pbar Lab/Field (mmHg)	Gauge Lab (mmHg)	Temp Lab (F)	Pbar Lab (mmHg)
Inlet R1	1037	2.185	-752	66	767	-100	66.0	767	686	74.3	761
Inlet R2	1044	2.167	-753	68	766	-95	68.0	766	682	74.3	761
Inlet R3	1108	2.209	-740	69	765	-86	69.0	765	698	74.3	761
Outlet R1	1003	1.935	-746	66	767	-14	66.0	767	678	74.3	761
Outlet R2	1016	2.188	-658	68	766	-8	68.0	766	678	74.3	761
Outlet R3	1035	1.968	-757	69	765	-38	69.0	765	668	74.3	761



# Narrative Summary



## Enthalpy Analytical Narrative Summary

<b>Company:</b>	Environmental Monitoring Labs	<b>Enthalpy #:</b>	0402-37
<b>Client #:</b>	Hercules	<b>Analyst:</b>	JRC
<b>PO #:</b>	Verbal	<b>Parameters:</b>	EPA Method 18 Type

**Custody**            Scott Grosshandler of Enthalpy Analytical, Inc. received 6 Summa canisters on 4/11/2002 after being relinquished by Environmental Monitoring Laboratories.. The samples were received with no noticeable container problems. Prior to analysis they were kept under lock with access only to authorized personnel of Enthalpy Analytical, Inc.

**Analysis**            The tank samples were analyzed using EPA Method 18 analytical procedures. Upon receipt, the tank pressures were measured and recorded. The tanks were then pressurized and a dilution ratio was calculated for each tank (see Tank Dilution).

All tanks were analyzed using a Hewlett Packard 5890 Series II gas chromatograph equipped with a flame ionization detector (FID). Samples and calibration standards were injected into the GC using a VICI six port valve with a gas sample loop. All analytes were referenced to gas phase standards.

**Separation**            All samples were separated using a Restek 30 m x 0.32 mm RTX-1 capillary column. Hydrogen was used as the carrier gas. Ethylene oxide eluted at approximate 1.6 minutes, separated well and was easily identified.

**Chromatographic Conditions**

Initial temperature:	45°C
Ramp:	17.5°C per minute to 185°C
Net Run Time:	8.0 minutes
Pressure Constant:	5.5 psi at 45°C
Detector temperature:	200°C
Injector temperature:	125°C

**Reproducibility**        All standards were within 10% of their tag value.

**Tank Dilution**        All tanks were adjusted from "as analyzed" concentrations to "as sampled" concentrations using a dilution factor which was calculated based on the following formula:

$$\frac{\frac{(GP_F + Pbar_F)}{(Temp_F + 460)}}{\frac{(GP_I + Pbar_I)}{(Temp_I + 460)}} = \frac{(GP_P + Pbar_P)}{(Temp_P + 460)}$$

where:

GP<sub>F</sub> = Final Gauge Pressure, mmHg  
 Pbar<sub>F</sub> = Final Barometric Pressure, mmHg  
 Temp<sub>F</sub> = Final Temperature, degrees F  
 GP<sub>I</sub> = Initial Gauge Pressure, mmHg  
 Pbar<sub>I</sub> = Initial Barometric Pressure, mmHg  
 Temp<sub>I</sub> = Initial Temperature, degrees F  
 GP<sub>P</sub> = Pretest Gauge Pressure, mmHg  
 Pbar<sub>P</sub> = Pretest Barometric Pressure, mmHg  
 Temp<sub>P</sub> = Pretest Temperature, degrees F

### Narrative Summary (Cont.)

#### Reporting Notes

The symbols *MDL* and *LOQ* represent the Minimum Detection Limit and the Limit of Quantification.

The symbols *ND* following a value indicate a non-detect or analytical result below the MDL.

The symbol *J* following a value indicates an analytical result between the MDL and the LOQ.

The symbol *E* following a value indicates an analytical result exceeding 125% of the highest calibration point.

# Sample Custody






# Sample Chromatograms



```

=====
Injection Date   : 4/16/2002 1:58:09 PM
Sample Name     : Run 1 Inlet *10           Location  : -
Acq. Operator  : jrc
Acq. Instrument : Zeppo                    Inj Volume : External
Acq. Method    : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M
Last changed   : 4/16/2002 1:46:43 PM by jrc
                (modified after loading)
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M
Last changed   : 4/19/2002 5:31:46 PM by ajr
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier    : 1.0000
Dilution      : 1.0000
    
```

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	BB	9.74451e4	2.05059e-2	1998.20244		Ethylene oxide


Totals : 1998.20244

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 4/16/2002 2:01:51 PM
Sample Name     : Run 1 Inlet *10
Acq. Operator  : jrc
Acq. Instrument : Zeppo
Acq. Method    : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M
Last changed   : 4/16/2002 1:46:43 PM by jrc
                 (modified after loading)
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M
Last changed   : 4/19/2002 5:31:46 PM by ajr
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier    : 1.0000
Dilution      : 1.0000
    
```

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	PB	9.88473e4	2.05054e-2	2026.90538		Ethylene oxide

Totals : 2026.90538

Results obtained with enhanced integrator!


\*\*\* End of Report \*\*\*



```

=====
Injection Date   : 4/16/2002 2:05:36 PM
Sample Name     : Run 1 Inlet *10           Location  :   -
Acq. Operator   : jrc
Acq. Instrument : Zeppo                    Inj Volume: External
Acq. Method     : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M
Last changed    : 4/16/2002 1:46:43 PM by jrc
                  (modified after loading)
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M
Last changed    : 4/19/2002 5:31:46 PM by ajr
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	PB	1.00119e5	2.05050e-2	2052.93173		Ethylene oxide

```
Totals :                               2052.93173
```

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 4/16/2002 2:22:42 PM
Sample Name    : Run 2 Inlet *20           Location : -
Acq. Operator  : jrc
Acq. Instrument : Zeppo                    Inj Volume : External
Acq. Method    : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M
Last changed   : 4/16/2002 2:22:55 PM by jrc
                (modified after loading)
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M
Last changed   : 4/19/2002 5:31:46 PM by ajr
=====

```



External Standard Report

```

=====
Sorted By      : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier    : 1.0000
Dilution      : 1.0000

```

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	PB	8.26492e4	2.05124e-2	1695.33470		Ethylene oxide


Totals : 1695.33470

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date : 4/16/2002 2:27:10 PM
Sample Name    : Run 2 Inlet *20           Location : -
Acq. Operator  : jrc
Acq. Instrument : Zeppo                   Inj Volume : External
Acq. Method    : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M
Last changed   : 4/16/2002 2:22:55 PM by jrc
                (modified after loading)
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M
Last changed   : 4/19/2002 5:31:46 PM by ajr
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier     : 1.0000
Dilution       : 1.0000
    
```

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	PB	7.68950e4	2.05156e-2	1577.54682		Ethylene oxide


Totals : 1577.54682

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date : 4/16/2002 2:33:03 PM
Sample Name    : Run 2 Inlet *20           Location : -
Acq. Operator  : jrc
Acq. Instrument : Zeppo                   Inj Volume : External
Acq. Method    : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M
Last changed   : 4/16/2002 2:22:55 PM by jrc
                (modified after loading)
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M
Last changed   : 4/19/2002 5:31:46 PM by ajr
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier     : 1.0000
Dilution       : 1.0000
    
```

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	BB	8.08809e4	2.05133e-2	1659.13742		Ethylene oxide


Totals : 1659.13742

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 4/16/2002 2:38:19 PM
Sample Name     : Run 3 Inlet *20           Location  :  -
Acq. Operator   : jrc
Acq. Instrument : Zeppo                    Inj Volume : External
Acq. Method     : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M
Last changed    : 4/16/2002 2:22:55 PM by jrc
                (modified after loading)
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M
Last changed    : 4/19/2002 5:31:46 PM by ajr
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier     : 1.0000
Dilution       : 1.0000
    
```

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.571	BB	3.73200e4	2.05642e-2	767.45574		Ethylene oxide

Totals : 767.45574


Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date : 4/16/2002 2:50:13 PM
Sample Name    : Run 3 Inlet *20           Location : -
Acq. Operator  : jrc
Acq. Instrument : Zeppo                    Inj Volume : External
Acq. Method    : G:\GC2002Q2\ZEPP0\METHODS\0402-37.M
Last changed   : 4/16/2002 2:50:36 PM by jrc
                (modified after loading)
Analysis Method : G:\GC2002Q2\ZEPP0\METHODS\0402-37B.M
Last changed   : 4/19/2002 5:31:46 PM by ajr
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier    : 1.0000
Dilution      : 1.0000

```

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.571	BB	3.61876e4	2.05671e-2	744.27492		Ethylene oxide

Totals : 744.27492

Results obtained with enhanced integrator!


```

=====
*** End of Report ***
=====

```

```

=====
Injection Date : 4/16/2002 2:53:55 PM
Sample Name    : Run 3 Inlet *20           Location : -
Acq. Operator  : jrc
Acq. Instrument : Zeppo                    Inj Volume : External
Acq. Method    : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M
Last changed   : 4/16/2002 2:50:36 PM by jrc
                (modified after loading)
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M
Last changed   : 4/19/2002 5:31:46 PM by ajr
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier    : 1.0000
Dilution      : 1.0000
    
```

Signal 1: FID2 B,


RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.571	BB	3.70376e4	2.05649e-2	761.67519		Ethylene oxide

Totals : 761.67519

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

=====  
 Injection Date : 4/16/02 4:08:59 PM  
 Sample Name : Run 1 Outlet Vial : -  
 Acq. Operator : jrc  
 Inj Volume : External  
 Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
 Last changed : 4/16/02 3:12:06 PM by jrc  
 (modified after loading)  
 Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
 Last changed : 4/22/02 3:17:39 PM by jrc



=====  
 External Standard Report  
 =====

Sorted By : Signal  
 Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
 Multiplier : 1.0000  
 Dilution : 1.0000

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp	Name
1.571	MM	148.68384	2.03640e-2	3.02780		Ethylene oxide


Totals : 3.02780

Results obtained with enhanced integrator!

=====  
 \*\*\* End of Report \*\*\*



=====  
Injection Date : 4/16/02 4:12:34 PM  
Sample Name : Run 1 Outlet Vial : -  
Acq. Operator : jrc  
Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 3:12:06 PM by jrc  
(modified after loading)  
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,


RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp Name
1.568	MM	153.23042	2.03640e-2	3.12039	Ethylene oxide

Totals : 3.12039

Results obtained with enhanced integrator!

=====  
\*\*\* End of Report \*\*\*

=====  
Injection Date : 4/16/02 4:16:24 PM  
Sample Name : Run 1 Outlet Vial : -  
Acq. Operator : jrc  
Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 3:12:06 PM by jrc  
(modified after loading)  
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,


RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp Name
1.569	MM	155.63316	2.03640e-2	3.16932	Ethylene oxide

Totals : 3.16932

Results obtained with enhanced integrator!

=====  
\*\*\* End of Report \*\*\*

=====  
 Injection Date : 4/16/02 4:20:13 PM  
 Sample Name : Run 2 Outlet Vial : -  
 Acq. Operator : jrc  
 Inj Volume : External  
 Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
 Last changed : 4/16/02 3:12:06 PM by jrc  
 (modified after loading)  
 Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
 Last changed : 4/22/02 3:17:39 PM by jrc



=====  
 External Standard Report  
 =====

Sorted By : Signal  
 Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
 Multiplier : 1.0000  
 Dilution : 1.0000

Signal 1: FID2 B,


RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp	Name
1.570	PP	88.96947	2.03640e-2	1.81178		Ethylene oxide

Totals : 1.81178

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

=====  
Injection Date : 4/16/02 4:32:23 PM  
Sample Name : Run 2 Outlet Vial : -  
Acq. Operator : jrc  
Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 4:30:15 PM by jrc  
(modified after loading)  
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp Name
1.568	MM	89.96803	2.03640e-2	1.83211	Ethylene oxide


Totals : 1.83211

Results obtained with enhanced integrator!

=====  
\*\*\* End of Report \*\*\*

```

=====
Injection Date : 4/16/02 4:35:49 PM
Sample Name   : Run 2 Outlet           Vial : -
Acq. Operator : jrc
                                           Inj Volume : External
Acq. Method   : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M
Last changed  : 4/16/02 4:30:15 PM by jrc
                (modified after loading)
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M
Last changed  : 4/22/02 3:17:39 PM by jrc
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM
Multiplier    : 1.0000
Dilution      : 1.0000
    
```

Signal 1: FID2 B,


RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp	Name
1.570	MM	91.80181	2.03640e-2	1.86946		Ethylene oxide

Totals : 1.86946

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

=====  
Injection Date : 4/16/02 4:40:19 PM  
Sample Name : Run 3 Outlet Vial : -  
Acq. Operator : jrc Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 4:30:15 PM by jrc  
(modified after loading)  
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,


RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp Name
1.571	-	-	-	-	Ethylene oxide

Totals : 0.00000

Results obtained with enhanced integrator!  
1 Warnings or Errors :

Warning : Calibrated compound(s) not found

=====  
Injection Date : 4/16/02 4:52:24 PM  
Sample Name : Run 3 Outlet Vial : -  
Acq. Operator : jrc  
Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 4:30:15 PM by jrc  
(modified after loading)  
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,


RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp	Name
1.571	-	-	-			Ethylene oxide

Totals : 0.00000

Results obtained with enhanced integrator!  
1 Warnings or Errors :

Warning : Calibrated compound(s) not found  
=====

=====  
Injection Date : 4/16/02 4:56:57 PM  
Sample Name : Run 3 Outlet Vial : -  
Acq. Operator : jrc  
Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 4:55:59 PM by jrc  
(modified after loading)  
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp	Name
1.571	-	-	-	-	-	Ethylene oxide

Totals : 0.00000

Results obtained with enhanced integrator!

1 Warnings or Errors :

Warning : Calibrated compound(s) not found

=====



**Curve(s)/QA Point(s)  
Chromatograms**



Method: G:\GC2002Q2ZEPPOMETHODS\0402-37.M of 4/16/02 1:28:56 PM

OVEN\DET

Runtime (min): 8.0

Temperatures:

	State	Setpoint
Inl. A	OFF	125 C.
Inl. B	OFF	125 C.
Det. A	ON	200 C.
Det. B	ON	200 C.
Aux.	OFF	50 C.

Oven Zone:

Oven max	195 C.
Equip Time	0.20 Min.
Oven State	ON
Cryo State	OFF
Ambient	25 C.
Cryo Blast	OFF

Oven Program:

	Setpoint
Initial Temp.:	45 C.
Initial Time:	0.00 Min.

Level	Rate (C/min.)	Final Temp.(C)	Final Time (min)
-------	---------------	----------------	------------------

1	17.5	185	0.00
---	------	-----	------

Inlet A Pressure Program Information

Constant Flow:	On
Pressure:	5.5 psi
Temperature:	45 C

Pressure Program:

	Setpoint
Initial Pres.:	0.0 psi
Initial Time:	650.00 min.

Level	Rate (psi/min.)	Final Pres.(psi)	Final Time (min)
1	0.00	0.0	0.00
2(A)	0.00	0.0	0.00
3(B)	0.00	0.0	0.00

Total Program Time: 650.00

Pressure Units: psi

Entered Values:

Column Length:	30.00	m.
Column Diameter:	0.320	mm.

Method: G:\GC2002Q2\ZEPPOMETHODS\0402-37.M of 4/16/02 1:28:56 PM

Gas: H2  
Vacuum Comp: Off

### Inlet B Pressure Program Information

Constant Flow: On  
Pressure: 5.5 psi  
Temperature: 45 C.  
Pressure Program:

#### Setpoint

Initial Pres.: 0.0 psi  
Initial Time: 650.00 min.

Level	Rate (psi/min.)	Final Pres.(psi)	Final Time (min)
1	0.00	0.0	0.00
2(A)	0.00	0.0	0.00
3(B)	0.00	0.0	0.00
Total Program Time:	650.00		

Column Pressure Units: psi

#### Column Values:

Column Length: 30.00 m.  
Column Diameter: 0.320 mm.  
Gas: H2  
Vacuum Comp: Off

### Purge Valve Settings

Valve A/B	Init Value	On Time (Min.)	Off Time (Min.)
A (Valve 3)	On	0.00	100.00
B (Valve 4)	On	0.00	100.00

A - Splitless Injection: No  
B - Splitless Injection: No

### Valves/Relays Information

Initial Setpoints:  
5890 Valves:  
Valve 1: Off  
Valve 2: Off  
Valve 3 (Purge A): On  
Valve 4 (Purge B): On

#### Valve/Relay Time Table:

Time	Name	State	Comment
0.00	Valve 1	On	inject
0.05	Valve 1	Off	turn off valve 1
0.15	Valve 2	On	load
0.20	Valve 2	Off	turn off valve 2

### Detector Information

Detector A:

Method: G:\GC2002Q2\ZEPPO\METHODS\0402-37.M of 4/16/02 1:28:56 PM

Type FID  
State OFF

Detector B:  
Type FID  
State ON

Save Data: Signal Information  
Signal 2

Signal 1:  
Signal Testplot  
Data rate 5.000 Hz.  
Peakwidth 0.053 min.  
Start Time 0.00 min.  
Stop Time 650.00 min.

Signal 2:  
Signal Det. B  
Data rate 10.000 Hz.  
Peakwidth 0.027 min.  
Start Time 0.00 min.  
Stop Time 650.00 min.

=====  
 Calibration Table  
 =====

Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM

Calculate : External Standard  
 Based on : Peak Area

Rel. Reference Window : 5.000 %  
 Abs. Reference Window : 0.000 min  
 Rel. Non-ref. Window : 5.000 %  
 Abs. Non-ref. Window : 0.000 min  
 Uncalibrated Peaks : not reported  
 Partial Calibration : Yes, identified peaks are recalibrated  
 Correct All Ret. Times: No, only for identified peaks

Curve Type : Linear  
 Origin : Connected  
 Weight : Equal

Recalibration Settings:  
 Average Response : Average all calibrations  
 Average Retention Time: Floating Average New 75%

Calibration Report Options :  
 Printout of recalibrations within a sequence:  
 Calibration Table after Recalibration  
 Normal Report after Recalibration  
 If the sequence is done with bracketing:  
 Results of first cycle (ending previous bracket)


Signal 1: FID2 B,

RetTime	Lvl	Amount	Area	Amt/Area	Ref Grp Name	
[min]	Sig	[ppmv]				
1.570	1	4	151.00000	7448.51628	2.02725e-2	
			1	202.00000	9738.04395	2.07434e-2
			2	1010.00000	4.86420e4	2.07640e-2
			3	2020.00000	9.87510e4	2.04555e-2

=====  
 Peak Sum Table  
 =====

\*\*\*No Entries in table\*\*\*


=====  
 Calibration Curves  
 =====



Ethylene oxide at exp. RT: 1.570  
 FID2 B,  
 Correlation: 0.99996  
 Residual Std. Dev.: 445.55214  
 Formula:  $y = mx + b$   
 m: 48.85252  
 b: -172.14123  
 x: Amount [ppmv]  
 y: Area

```

=====
Injection Date   : 4/16/2002 11:23:23 AM
Sample Name     : 202ppmv eo                Location   : -
Acq. Operator   : jrc
Acq. Instrument : Zeppo                    Inj Volume : External
Acq. Method     : G:\GC2002Q1\ZEPPO\METHODS\0302-48.M
Last changed    : 4/16/2002 11:24:43 AM by jrc
                  (modified after loading)
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M
Last changed    : 4/19/2002 5:31:46 PM by ajr
=====
    
```



External Standard Report

```

=====
Sorted By       : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier      : 1.0000
Dilution        : 1.0000
    
```

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.571	BB	9876.39453	2.08266e-2	205.69126		Ethylene oxide


Totals : 205.69126

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 4/16/2002 11:28:23 AM
Sample Name     : 202ppmv eo                Location   : -
Acq. Operator   : jrc
Acq. Instrument : Zeppo                    Inj Volume : External
Acq. Method     : G:\GC2002Q1\ZEPPO\METHODS\0302-48.M
Last changed    : 4/16/2002 11:24:43 AM by jrc
                  (modified after loading)
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M
Last changed    : 4/19/2002 5:31:46 PM by ajr
=====
    
```



External Standard Report

```

=====
Sorted By       : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier     : 1.0000
Dilution       : 1.0000
    
```

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.571	BB	9799.89453	2.08293e-2	204.12532		Ethylene oxide


Totals : 204.12532

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 4/16/2002 11:33:14 AM
Sample Name     : 202ppmv eo                Location   : -
Acq. Operator  : jrc
Acq. Instrument : Zeppo                    Inj Volume : External
Acq. Method    : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M
Last changed   : 4/16/2002 11:24:43 AM by jrc
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M
Last changed   : 4/19/2002 5:31:46 PM by ajr
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier    : 1.0000
Dilution      : 1.0000
    
```

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	BB	9537.84277	2.08392e-2	198.76118		Ethylene oxide

Totals : 198.76118


Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*



```

=====
Injection Date   : 4/16/2002 11:38:34 AM
Sample Name     : 1010ppmv eo                Location   : -
Acq. Operator   : jrc
Acq. Instrument : Zeppo                     Inj Volume : External
Acq. Method     : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M
Last changed    : 4/16/2002 11:24:43 AM by jrc
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M
Last changed    : 4/19/2002 5:31:46 PM by ajr
    
```



External Standard Report

```

Sorted By       : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier     : 1.0000
Dilution       : 1.0000
    
```

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	PB	4.77196e4	2.05436e-2	980.33236		Ethylene oxide


Totals : 980.33236

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 4/16/2002 11:42:09 AM
Sample Name     : 1010ppmv eo                Location   : -
Acq. Operator  : jrc
Acq. Instrument : Zeppo                      Inj Volume : External
Acq. Method    : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M
Last changed   : 4/16/2002 11:24:43 AM by jrc
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M
Last changed   : 4/19/2002 5:31:46 PM by ajr
=====
    
```



External Standard Report

```

Sorted By       : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier     : 1.0000
Dilution       : 1.0000
    
```

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	PB	4.93945e4	2.05411e-2	1014.61827		Ethylene oxide


Totals : 1014.61827

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 4/16/2002 11:46:11 AM
Sample Name     : 1010ppmv eo                Location   : -
Acq. Operator  : jrc
Acq. Instrument : Zeppo                      Inj Volume : External
Acq. Method    : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M
Last changed   : 4/16/2002 11:24:43 AM by jrc
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M
Last changed   : 4/19/2002 5:31:46 PM by ajr
=====
    
```



External Standard Report

```

Sorted By       : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier     : 1.0000
Dilution       : 1.0000
    
```

Signal 1: FID2 B,


RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	PB	4.88118e4	2.05420e-2	1002.69007		Ethylene oxide

Totals : 1002.69007

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

=====  
Injection Date : 4/16/2002 11:50:42 AM  
Sample Name : 2020ppmv eo Location : -  
Acq. Operator : jrc  
Acq. Instrument : Zeppo Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/2002 11:24:43 AM by jrc  
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M  
Last changed : 4/19/2002 5:31:46 PM by ajr  
=====



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,


RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	BB	9.85076e4	2.05055e-2	2019.95189		Ethylene oxide

Totals : 2019.95189

Results obtained with enhanced integrator!

=====  
\*\*\* End of Report \*\*\*  
=====

=====  
Injection Date : 4/16/2002 11:55:17 AM  
Sample Name : 2020ppmv eo Location : -  
Acq. Operator : jrc  
Acq. Instrument : Zeppo Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/2002 11:24:43 AM by jrc  
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M  
Last changed : 4/19/2002 5:31:46 PM by ajr



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,


RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	PB	9.90766e4	2.05053e-2	2031.60015		Ethylene oxide

Totals : 2031.60015

Results obtained with enhanced integrator!

=====  
\*\*\* End of Report \*\*\*

=====  
Injection Date : 4/16/2002 11:59:55 AM  
Sample Name : 2020ppmv eo Location : -  
Acq. Operator : jrc  
Acq. Instrument : Zeppo Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPP0\METHODS\0402-37.M  
Last changed : 4/16/2002 11:24:43 AM by jrc  
Analysis Method : G:\GC2002Q2\ZEPP0\METHODS\0402-37B.M  
Last changed : 4/19/2002 5:31:46 PM by ajr



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,


RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	PB	9.86687e4	2.05055e-2	2023.25008		Ethylene oxide

Totals : 2023.25008

Results obtained with enhanced integrator!

=====  
\*\*\* End of Report \*\*\*

=====  
Injection Date : 4/16/2002 5:01:13 PM  
Sample Name : 151ppmv eo Location : -  
Acq. Operator : jrc  
Acq. Instrument : Zeppo Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPP0\METHODS\0402-37.M  
Last changed : 4/16/2002 4:55:59 PM by jrc  
(modified after loading)  
Analysis Method : G:\GC2002Q2\ZEPP0\METHODS\0402-37B.M  
Last changed : 4/19/2002 5:31:46 PM by ajr



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	BB	7403.42920	2.09457e-2	155.07022		Ethylene oxide

Totals : 155.07022


Results obtained with enhanced integrator!

=====  
\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 4/16/2002 5:08:40 PM
Sample Name     : 151ppmv eo
Acq. Operator   : jrc
Acq. Instrument : Zeppo
Acq. Method     : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M
Last changed    : 4/16/2002 4:55:59 PM by jrc
                  (modified after loading)
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37B.M
Last changed    : 4/19/2002 5:31:46 PM by ajr
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	BB	7490.01855	2.09402e-2	156.84268		Ethylene oxide

Totals : 156.84268

Results obtained with enhanced integrator!


```

=====
*** End of Report ***

```



=====  
Injection Date : 4/16/2002 5:13:10 PM  
Sample Name : 151ppmv eo Location : -  
Acq. Operator : jrc  
Acq. Instrument : Zeppo Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPP\METHODS\0402-37.M  
Last changed : 4/16/2002 4:55:59 PM by jrc  
(modified after loading)  
Analysis Method : G:\GC2002Q2\ZEPP\METHODS\0402-37B.M  
Last changed : 4/19/2002 5:31:46 PM by ajr



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Friday, April 19, 2002 5:31:45 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area	Amount [ppmv]	Grp	Name
1.570	PB	7452.10107	2.09426e-2	156.06652		Ethylene oxide

Totals : 156.06652

Results obtained with enhanced integrator!

=====  
\*\*\* End of Report \*\*\*

=====  
Calibration Table  
=====

Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM

Calculate : External Standard  
Based on : Peak Area

Rel. Reference Window : 5.000 %  
Abs. Reference Window : 0.000 min  
Rel. Non-ref. Window : 5.000 %  
Abs. Non-ref. Window : 0.000 min  
Uncalibrated Peaks : not reported  
Partial Calibration : Yes, identified peaks are recalibrated  
Correct All Ret. Times: No, only for identified peaks

Curve Type : Linear  
Origin : Connected  
Weight : Equal

Recalibration Settings:  
Average Response : Average all calibrations  
Average Retention Time: Floating Average New 75%

Calibration Report Options :  
Printout of recalibrations within a sequence:  
Calibration Table after Recalibration  
Normal Report after Recalibration  
If the sequence is done with bracketing:  
Results of first cycle (ending previous bracket)


Signal 1: FID2 B,

RetTime [min]	Lvl Sig	Amount [ppmv]	Area	Amt/Area	Ref Grp Name
1.571	1 1	6.04000	307.57238	1.96377e-2	Ethylene oxide
2	15.10000	733.45176	2.05876e-2		
3	75.50000	3744.16479	2.01647e-2		

=====  
Peak Sum Table  
=====


\*\*\*No Entries in table\*\*\*  
=====

=====  
Calibration Curves  
=====



Ethylene oxide at exp. RT: 1.571  
FID2 B,  
Correlation: 0.99998  
Residual Std. Dev.: 16.80070  
Formula:  $y = mx + b$   
m: 49.61011  
b: -3.04391  
x: Amount[ppmv]  
y: Area

=====  
Injection Date : 4/16/02 3:27:00 PM  
Sample Name : 6.04ppmv eo Vial : -  
Acq. Operator : jrc  
Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 3:12:06 PM by jrc  
(modified after loading)  
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp	Name
1.571	MM	316.98975	2.03507e-2	6.45098		Ethylene oxide

Totals : 6.45098


Results obtained with enhanced integrator!

=====  
\*\*\* End of Report \*\*\*

Injection Date : 4/16/02 3:32:18 PM  
Sample Name : 6.04ppmv eo Vial : -  
Acq. Operator : jrc

Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 3:12:06 PM by jrc  
(modified after loading)

Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



External Standard Report

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp	Name
1.572	BP	303.73572	2.03592e-2	6.18381		Ethylene oxide

Totals : 6.18381

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

Injection Date : 4/16/02 3:37:33 PM

Sample Name : 6.04ppmv eo

Vial : -

Acq. Operator : jrc

Inj Volume : External


Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M

Last changed : 4/16/02 3:12:06 PM by jrc

(modified after loading)

Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M

Last changed : 4/22/02 3:17:39 PM by jrc



External Standard Report

Sorted By : Signal

Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM

Multiplier : 1.0000

Dilution : 1.0000

Signal 1: FID2 B,


RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp	Name
1.572	MM	306.65033	2.03573e-2	6.24256		Ethylene oxide

Totals : 6.24256

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

=====  
Injection Date : 4/16/02 3:44:04 PM  
Sample Name : 15.1ppmv eo Vial : -  
Acq. Operator : jrc  
Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 3:12:06 PM by jrc  
(modified after loading)  
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,


RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp	Name
1.572	BB	730.23010	2.02412e-2	14.78074		Ethylene oxide

Totals : 14.78074

Results obtained with enhanced integrator!

=====  
\*\*\* End of Report \*\*\*  
=====

=====  
Injection Date : 4/16/02 3:47:26 PM  
Sample Name : 15.1ppmv eo Vial : -  
Acq. Operator : jrc  
Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 3:12:06 PM by jrc  
(modified after loading)  
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp	Name
1.571	PB	758.61908	2.02381e-2	15.35298		Ethylene oxide

Totals : 15.35298

Results obtained with enhanced integrator!


=====  
\*\*\* End of Report \*\*\*



=====  
Injection Date : 4/16/02 3:51:39 PM  
Sample Name : 15.1ppmv eo Vial : -  
Acq. Operator : jrc

Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 3:12:06 PM by jrc  
(modified after loading)

Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



=====  
**External Standard Report**  
=====

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp	Name
1.571	BB	711.50610	2.02434e-2	14.40332		Ethylene oxide

Totals : 14.40332


Results obtained with enhanced integrator!

=====  
\*\*\* End of Report \*\*\*  
=====

Injection Date : 4/16/02 3:57:20 PM  
Sample Name : 75.5ppmv eo Vial : -  
Acq. Operator : jrc

Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 3:12:06 PM by jrc  
(modified after loading)

Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



External Standard Report

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp	Name
1.571	BB	3744.16479	2.01736e-2	75.53317		Ethylene oxide

Totals : 75.53317


Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

Injection Date : 4/16/02 4:01:42 PM  
Sample Name : 75.5ppmv eo Vial : -  
Acq. Operator : jrc

Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 3:12:06 PM by jrc  
(modified after loading)

Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



External Standard Report

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,


RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp Name
1.570	BB	3754.75708	2.01735e-2	75.74668	Ethylene oxide

Totals : 75.74668

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

=====  
Injection Date : 4/16/02 4:05:23 PM  
Sample Name : 75.5ppmv eo Vial : -  
Acq. Operator : jrc  
Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 3:12:06 PM by jrc  
(modified after loading)  
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp Name
1.571	BB	3801.48145	2.01733e-2	76.68851	Ethylene oxide

Totals : 76.68851


Results obtained with enhanced integrator!

=====  
\*\*\* End of Report \*\*\*

```

=====
Injection Date : 4/16/02 5:01:13 PM
Sample Name   : 151ppmv eo           Vial : -
Acq. Operator : jrc
Inj Volume   : External
Acq. Method  : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M
Last changed  : 4/16/02 4:55:59 PM by jrc
                (modified after loading)
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M
Last changed  : 4/22/02 3:17:39 PM by jrc
=====

```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM
Multiplier    : 1.0000
Dilution      : 1.0000

```

Signal 1: FID2 B,


RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp Name
1.570	BB	7403.42920	2.01655e-2	149.29364	Ethylene oxide

Totals : 149.29364

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

=====  
Injection Date : 4/16/02 5:08:40 PM  
Sample Name : 151ppmv eo Vial : -  
Acq. Operator : jrc  
Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 4:55:59 PM by jrc  
(modified after loading)  
Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



=====  
External Standard Report  
=====

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp	Name
1.570	BB	7490.01855	2.01654e-2	151.03903		Ethylene oxide

Totals : 151.03903


Results obtained with enhanced integrator!

=====  
\*\*\* End of Report \*\*\*

Injection Date : 4/16/02 5:13:10 PM  
Sample Name : 151ppmv ec Vial : -  
Acq. Operator : jrc

Inj Volume : External  
Acq. Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37.M  
Last changed : 4/16/02 4:55:59 PM by jrc  
(modified after loading)

Analysis Method : G:\GC2002Q2\ZEPPO\METHODS\0402-37C.M  
Last changed : 4/22/02 3:17:39 PM by jrc



External Standard Report

Sorted By : Signal  
Calib. Data Modified : Monday, April 22, 2002 3:17:38 PM  
Multiplier : 1.0000  
Dilution : 1.0000

Signal 1: FID2 B,

RetTime [min]	Type	Area counts*s	Amt/Area [ppmv]	Amount	Grp	Name
1.570	PB	7452.10107	2.01654e-2	150.27472		Ethylene oxide

Totals : 150.27472

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*